



Environmental Protection Division
PO Box 1663, MS J978
Los Alamos, New Mexico 87545
505-667-2211/Fax 505-665-8858

Date: January 22, 2008
Refer To: ENV-DO-08-003

Ms. Debra McElroy
Section Chief – Enforcement/Compliance
New Mexico Environment Department
Air Quality Bureau
1301 Siler Road
Building B
Santa Fe, New Mexico 87507

**SEMI-ANNUAL MONITORING REPORT FOR JULY – DECEMBER, 2007
AIR QUALITY TITLE V OPERATING PERMIT P100-M2
IDEA ID NO. 856 – LOS ALAMOS NATIONAL LABORATORY (LANL)**

Dear Ms. McElroy:

Enclosed is Los Alamos National Laboratory's Title V Operating Permit Semi-annual Monitoring Report for the period **July 1 – December 31, 2007** (Enclosure-1). This submission is required by permit condition 4.2 of NMED Operating Permit P100-M2 and is transmitted within the allowed 45 days after the end of the reporting period as specified in permit condition 4.3. Included with this report are attachments A through I. Each attachment is labeled with its contents and provides monitoring data to support compliance with conditions listed in the monitoring sections of the permit. No deviations were identified during this reporting period.

If you have any questions or comments regarding this submittal or would like to discuss the submittal in greater detail, please contact Steve Story at 665-2169 or David Paulson at 665-8884.

Sincerely,

A handwritten signature in black ink, appearing to read "V. George".

Victoria A. George
Division Leader
Environmental Protection Division

DLP:tav

ENV-DO-08-003
Ms. McElroy

January 22, 2008

Enc: a/s

Cy: w/o opacity reports

M. Mallory, ADPADOPS, A102
R. Watkins, ADESH&Q, K491
S. Fong, DOE-LA-AO, A316
P. Wardwell, LC-ESH, A187
D. Wilburn, ENV-EAQ, J978
S. Story, ENV-EAQ, J978
D. Paulson, ENV-EAQ, J978
J. Stanton, SSS-AE-V02, A199

Cy: with opacity reports

ENV-DO FILE
IRM-RMSSO, A150
ENV-EAQ Title V Monitoring Report File



**New Mexico Environment Department
Air Quality Bureau
Compliance and Enforcement Section
2048 Galisteo
Santa Fe, NM 87505
Phone (505) 827-1494
Fax (505) 827-1523**



Version 11.22.06

REPORTING SUBMITTAL FORM

NMED USE ONLY	
Staff	_____
Admin	_____

PLEASE NOTE: ® - Indicates required field

SECTION I - GENERAL COMPANY AND FACILITY INFORMATION					
® Company Name: Los Alamos National Security			® Facility Name: Los Alamos National Laboratory		
® Company Address: P.O. Box 1663 MS J978			® Facility Address: Same as Company		
® City: Los Alamos	® State: NM	® Zip: 87545	® City:	® State:	® Zip:
® Company Environmental Contact: Dianne Wilburn		® Title: EAQ Group Leader		® Facility Contact: Steve Story	
® Title: Air Compliance Team Leader		® Phone Number: 505 667 6952		® Fax Number: 505 665 8858	
® Email Address: dianne@lanl.gov		® Phone Number: 505 665 2169		® Fax Number: 505 665 8858	
® Email Address: story@lanl.gov		® Title: Associate Director ESH&Q		® Phone Number: 505 667 4218	
® Title: Richard S. Watkins		® Fax Number: 505 665 3811		® Phone Number: 505 667 4218	
® AI Number: 856	Title V Permit Number: P100M2	Title V Permit Issue Date: July 16, 2007	NSR Permit Number: 2195	NSR Permit Issue Date: Various	
® Date of Submittal: January 23, 2008	Reporting Period: July through December 2007	OR	Proposed Test Date:	OR	Actual Test Date:

SECTION II - TYPE OF SUBMITTAL (check one that applies)					
A. <input type="checkbox"/>	Title V Annual Compliance Certification	Permit Condition(s):	Description:		
B. <input checked="" type="checkbox"/>	Title V Semi-annual Monitoring Report	Permit Condition(s): All Monitoring	Description: LANL Semi-annual Monitoring Report for July through December 2007.		
C. <input type="checkbox"/>	NSPS Requirement (40CFR60)	Regulation:	Section(s):	Description:	
		Test Protocol <input type="checkbox"/>	Test Report <input type="checkbox"/>	Other <input type="checkbox"/>	
D. <input type="checkbox"/>	MACT Requirement (40CFR63)	Regulation:	Section(s):	Description:	
		Test Protocol <input type="checkbox"/>	Test Report <input type="checkbox"/>	Other <input type="checkbox"/>	
E. <input type="checkbox"/>	NMAC Requirement (20.2.xx) or NESHAP Requirement (40CFR61)	Regulation:	Section(s):	Description:	
		Test Protocol <input type="checkbox"/>	Test Report <input type="checkbox"/>	Other <input type="checkbox"/>	
F. <input type="checkbox"/>	Permit Requirement	Permit No.:	Condition(s):	Description:	
		Test Protocol <input type="checkbox"/>	Test Report <input type="checkbox"/>	Other <input type="checkbox"/>	
G. <input type="checkbox"/>	Requirement of a Settlement Agreement or Compliance Order	NOV or SFO No.:	Section(s):	Description:	
		Test Protocol <input type="checkbox"/>	Test Report <input type="checkbox"/>	Other <input type="checkbox"/>	

SECTION III - CERTIFICATION			
After reasonable inquiry, I <u>Victoria A. George</u> certify that the information in this submittal is true, accurate and complete. <small>(name of reporting official)</small>			
® Signature of Reporting Official: 	® Title: Environmental Protection Division Leader	® Date: 1/22/08	® Responsible Official for Title V? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Reviewed By: _____

Date Reviewed: _____

Enclosure - 1

Los Alamos National Laboratory's
Title V Operating Permit
Monitoring Report for the period
July 1 – December 31, 2007

LA-UR-08-0360

Approved for public release;
distribution is unlimited.

Title: Semi-Annual Monitoring Report
July 1 - December 31, 2007
Air Quality Title V Operating Permit P100M2
Los Alamos National Laboratory

Author(s): David Paulson, ENV-EAQ

Intended for: Ms. Debra McElroy
Section Chief, Enforcement/Compliance
New Mexico Environment Department - Air Quality Bureau
1301 Siler Road, Building B
Santa Fe, New Mexico 87507



Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007

Identifying Information

Source Name: Los Alamos National Laboratory County: Los Alamos

Source Address:

City: Los Alamos State: NM Zip Code: 87545

Responsible Official: Victoria A. George Ph No. (505) 667-2211 Fax No. (505) 665-8858

Technical Contact: Steven L. Story Ph No. (505) 665-2169 Fax No. (505) 665-8858


Principal Company Product or Business: National Security and Nuclear Weapons Research Primary SIC Code: 9711

Permit No. P100 {IDEA/Tempo ID No. 856} Permit Issued Date: April 30, 2004
P100M1 (June 15, 2006), P100M2 (July 16, 2007)

Certification of Truth, Accuracy, and Completeness

I, Victoria A. George certify that, based on information and belief formed after reasonable inquiry, the statements and information contained in the attached semi-annual monitoring report are true, accurate, and complete.

Signature



Date:

1/22/08

Title: Division Leader, Environmental Protection Division

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Sources (by permit section)

- 1. Asphalt Production**
- 2. Beryllium Activities**
- 3. Boilers and Heaters**
- 4. Carpenter Shops, TA-3-38 & TA-15-563**
- 5. Chemical Usage**
- 6. Degreasers**
- 7. Internal Combustion Sources**
- 8. Data Disintegrator, TA-52-11**
- 9. Power Plant at Technical Area 3 (TA-3-22)**

Deviations

Attachments

- A: Asphalt Plant Opacity Reports**
- B: Beryllium HEPA Filter Tests Results**
- C: Boilers and Heaters Natural Gas Usage**
- D: Carpenter Shop Hours of Operation**
- E: Degreaser Solvent Usage**
- F: Internal Combustion Generator Hours of Operation**
- G: Data Disintegrator Box Throughput**
- H: Power Plant Natural Gas and Fuel Oil Usage**
- I: Power Plant Opacity Reports**

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

1. Asphalt Production

Permit Section	Monitoring Required	Monitoring Performed
2.1.4.1	Perform monthly six (6) minute opacity readings for each emission point having opacity greater than zero as determined by EPA Method 22.	<p>Monthly opacity reports are provided as Attachment A.</p> <p>Monthly six minute opacity readings are taken using the required EPA Methods.</p>
2.1.4.2	Monitor the differential pressure (inches of water) across the baghouse by the use of a differential pressure gauge, in accordance with condition IV.C.2 of NSR permit number GCP-3-2195G.	<p>A differential pressure gauge is in place to continuously monitor the differential pressure across the baghouse as required by NSR permit GCP-3-2195G condition IV.C.2.</p> <p>The differential pressure is recorded twice each day during operations, once at the beginning of the production run and once at the end. This is consistent with NSR permit GCP-3-2195G condition IV.D.2(e).</p> <p>Records are available on-site for NMED inspection.</p>
2.1.4.3	40 CFR Part 60, Appendix A, Method 9 shall be used to determine compliance with the opacity limitation.	LANL has certified opacity readers on-site who perform opacity readings using 40 CFR 60, Appendix A, Method 9 to determine compliance with the opacity limitation.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

2. Beryllium Activities (Permit Section 2.2.4)

Source	Monitoring Required	Monitoring Performed
TA-3-29 Chemistry and Metallurgy Research Facility	A log shall be maintained during operations which indicate the number of Be samples processed.	<p>The registration for this source has been cancelled. Beryllium work is no longer performed at this location. A letter was sent to NMED on June 5, 2007 making this request.</p> <p>All previous records/logs containing the number of Be samples processed will be kept for at least five (5) years as required by permit condition 3.2 and will be available on-site for NMED inspection.</p>
TA-3-66 Sigma Facility	A log shall be maintained during operations which show the number of metallographic specimens used in the polishing operation and the weight of Be samples processed in the electroplating/chemical milling, machining, and arc melting/casting operations.	<p>A log is maintained showing the number of metallographic specimens used in the polishing operation.</p> <p>Logs are maintained showing the weight of Be samples processed in the electroplating/chemical milling, machining, and arc melting/casting operations.</p> <p>Logs are available on-site for NMED inspection.</p>
TA-3-141 Beryllium Technology Facility (BTF)	Facility exhaust stack will be equipped with a continuous emission monitor used to measure beryllium emissions.	<p>The BTF is equipped with a continuous emissions monitor to measure beryllium emissions. The monitoring system is operated in accordance with LANL Quality Assurance Project Plans and emission results are provided to NMED quarterly.</p> <p>Submissions for this period were provided to NMED in reports dated August 9, 2007 [ENV-EAQ:07-185] and October 30, 2007 [ENV-EAQ:07-258]</p>

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Source	Monitoring Required	Monitoring Performed
TA-3-141 BTF (Continued)	Cartridge and HEPA filters will be equipped with differential pressure gauges that measure the differential pressure across the cartridge and HEPA filters while the exhaust fans are in operation.	Cartridge and HEPA filters are equipped with differential pressure gauges that measure the differential pressure across the cartridge and HEPA filters while the exhaust fans are in operation.
TA-16-207	Project files shall be maintained of components prepared for testing.	Project files are maintained of components prepared for testing. Files are available on-site for NMED inspection.
TA-35-87	A log shall be maintained during operations which show the number of beryllium filters cut.	A log is maintained showing the number of beryllium filters cut. The log is available on-site for NMED inspection.
TA-35-213 Target Fabrication Facility	Records of the stack emission test results (see Condition 2 of NSR Permit No. 632) and other data needed to determine total emissions shall be retained at the source and made available for inspection by the Department.	Records of stack emission test results are maintained on-site and are available for NMED inspection. Stack emission test results are used to determine total emissions from this facility.
TA-55-PF-4 Plutonium Facility	The HEPA filtration systems shall be equipped with a differential pressure gauge that measures the differential pressure (inches of water) across the HEPA filters while the exhaust fans are in operation.	The HEPA filtration systems are equipped with differential pressure gauges that measure the differential pressure across the HEPA filters while the exhaust fans are in operation.
	Control efficiency shall be verified by daily HEPA filter pressure drop tests and annual HEPA filter challenge tests of accessible filters.	Control efficiency is verified by daily HEPA filter pressure drop readings. Readings are recorded in the TA-55 Operations Center. Annual HEPA filter challenge tests of accessible filters are performed. Test results are summarized in Attachment B.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

3. Boilers and Heaters

Permit Section	Monitoring Required	Monitoring Performed
2.3.4.1	Emission units TA-21-357-1, TA-21-357-2, and TA-21-357-3: A volumetric flow meter shall be utilized to measure the total amount of natural gas being used on a monthly basis.	The TA-21 Steam Plant did not operate during this reporting period. The plant was officially and permanently shut-down as of September 28, 2007. This information was communicated to NMED in a letter dated October 16, 2007.
2.3.4.2	Emission units TA-55-6-BHW-1 and TA-55-6-BHW-2: A volumetric flow meter shall be utilized to measure the total amount of natural gas being used on a monthly basis.	<p>Volumetric flow meters are utilized to measure the total amount of natural gas being used by units TA-55-6-BHW-1 and TA-55-6-BHW-2 on a monthly basis.</p> <p>Natural gas usage is summarized in Attachment C.</p>
2.3.4.3	40 CFR Part 60, Appendix A, Method 9 shall be used to determine compliance with the opacity limitation.	LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine compliance with the opacity limitation.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

4. Carpenter Shops, TA-3-38 & TA-15-563

Permit Section	Monitoring Required	Monitoring Performed
2.4.4.1	The permittee shall maintain logs of the hours the carpenter shops are in operation.	<p>A log is maintained of the hours of operation at the TA-3-38 shop. During this reporting period, hour meters for the cyclone separators were utilized to monitor hours of shop operation. Readings are collected and recorded monthly.</p> <p>The TA-15-563 carpenter shop is equipped with an hour meter on the cyclone separator. The hour meter is read and recorded monthly.</p> <p>Hours of operation are provided in Attachment D.</p>

5. Chemical Usage

Permit Section	Monitoring Required	Monitoring Performed
2.5.4.1	Maintain records of chemical purchasing through facility-wide chemical tracking system, and use the data to calculate the emissions on a semi-annual basis in accordance with Condition 4.1.	Records are maintained in LANL's facility wide chemical tracking system (ChemLog). The data is used to calculate emissions which are submitted in the Semi-Annual Emission Report.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

6. Degreasers

Permit Section	Monitoring Required	Monitoring Performed
2.6.4.1	Record the amount of solvent added to the degreaser, and calculate the emissions on a semi-annual basis in accordance with Condition 4.1.	Records are maintained of the amount of solvent added to the degreaser. This data is used to calculate emissions on a semi-annual basis. LANL's "Historical Solvent Usage Data" report for July 1 through December 31, 2007 is provided in Attachment E.
2.6.4.2	Complete checklist for work practice standards.	LANL completes work practice checklists for the degreaser operation. The checklists are available on-site for NMED inspection.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

7. Internal Combustion Sources

Permit Section	Monitoring Required	Monitoring Performed
2.7.4 [Stationary Standby Generators]	Track and record hours of operation for stationary standby generators on a semi-annual basis.	LANL tracks and records generator hours of operation on a semi-annual basis. Stationary generator hours of operation for this reporting period are provided in Attachment F.
2.7.4 [TA-33-G-1]	Track hourly and 12-month rolling total kWh. Record hours of operation and the time operation begins and ends each day.	On May 18, 2006, LANL started the TA-33 diesel generator. Other than the start up test, the generator has not run. A form has been created and will be used for tracking generator start and stop times as well as hours of operation. These hourly readings will be used in tracking the 12-month rolling total of kWh.
2.7.4.1	40 CFR Part 60, Appendix A, Method 9 shall be used to determine compliance with the opacity limitation.	LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine compliance with the opacity limitation.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

8. Data Disintegrator, TA-52-11

Permit Section	Monitoring Required	Monitoring Performed
2.8.4.1	The permittee shall maintain a log of the number of boxes of media that are destroyed and calculate the emissions on a semi-annual basis in accordance with Condition 4.1.	<p>LANL maintains a log of the number of boxes of media that are shredded and calculates the emissions on a semi-annual basis.</p> <p>The actual number of boxes shredded during this reporting period is included in Attachment G.</p>
2.8.4.2	The permittee shall perform regular maintenance and repair on the cyclone and cloth tube filter(s) per manufacturer's recommendations.	The Data Disintegrator and associated pollution control devices are maintained under a preventative maintenance contract. LANL maintains documentation of all maintenance and repairs performed on the cyclone and cloth tube filters.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

9. Power Plant at Technical Area 3 (TA-3-22)

Permit Section	Monitoring Required	Monitoring Performed
2.9.4.1	Total fuel oil consumption shall be monitored so that combined fuel oil usage of Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 can be calculated on a rolling 365-day total.	Total fuel oil consumption is monitored on a daily basis. These daily readings are used to calculate a 365-day rolling total. Attachment H contains a summary of monthly fuel oil consumption. Records of daily fuel oil use are available on-site for NMED inspection.
2.9.4.2	Natural gas consumption shall be monitored so that combined natural gas usage of Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 can be calculated on a rolling 365-day total.	A volumetric flow meter is used to measure the total amount of natural gas used on a daily basis. These daily readings are used to calculate a 365-day rolling total. Attachment H contains a summary of monthly natural gas usage. Daily totals are available on-site for NMED inspection.
2.9.4.3	Natural gas consumption shall be monitored so that natural gas usage for Unit TA-3-22 CT-1 can be calculated on a rolling 365-day total.	The Combustion Turbine started operation on September 23, 2007. A monthly gas consumption report, containing daily turbine gas use, is generated by the plant operator. This data is used to calculate a rolling 365-day total.
2.9.4.4	A certification of total sulfur content of the No. 2 fuel oil used by Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 shall be obtained from the supplier whenever No. 2 fuel oil is delivered to the facility.	No fuel oil was purchased or delivered during this reporting period.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Permit Section	Monitoring Required	Monitoring Performed
2.9.4.5	If the certification as specified by Condition 2.9.4.4 is not available at delivery, the permittee shall analyze the No. 2 fuel oil to determine the total sulfur content. The analysis shall be conducted using Department approved methods and standards for determining total sulfur content of No. 2 fuel oil.	No fuel oil was purchased or delivered during this reporting period.
2.9.4.6	The operating load of Unit TA-3-22 CT-1 specified by Condition 2.9.3.7 shall be monitored and recorded hourly during normal operations of that unit. Periods of startup and shutdown shall not be included in the hourly monitoring but shall be recorded separately.	A tracking log was created that contains the hours of start-up, normal operation, shut-down, and the hourly operating load during normal operation.
2.9.4.7	Compliance with NOx pound per hour emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the daily total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.1029 pounds NOx per thousand SCF of gas burned (applicable for worst-case conditions of negative 18 degrees Fahrenheit) and divided by the number of hours of operation of the unit during that day as recorded pursuant to Condition 2.9.3.8. Compliance with NOx annual emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the 365 day total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.1029 pounds NOx per thousand SCF of gas burned (applicable for annual average conditions of 47.9 degrees F).	An emission calculation spreadsheet was created, using the formula in this permit condition, to calculate the NOx pound per hour and ton per year emission rates. This data is compared with the permit emission limits.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Permit Section	Monitoring Required	Monitoring Performed
2.9.4.8	<p>Compliance with CO pound per hour emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the daily total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.731 pounds CO per thousand SCF of gas burned (applicable for worst-case conditions of negative 18 degrees Fahrenheit), and divided by the number of hours of operation of the unit during that day as recorded pursuant to Condition 2.9.3.8). Compliance with CO annual emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the 365 day total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.0613 pounds CO per thousand SCF of gas burned (applicable for annual average conditions of 47.9 degrees Fahrenheit).</p>	<p>An emission calculation spreadsheet was created, using the formula in this permit condition, to calculate the CO pound per hour and ton per year emission rates. This data is compared with the permit emission limits.</p>
2.9.4.9	<p>At least once each calendar quarter the permittee shall use the method specified in Conditions 2.9.4.7 and 2.9.4.8 to determine compliance of Unit TA-3-22 CT-1 with the hourly and annual emission limits specified in this permit.</p>	<p>Monthly gas use data is entered into the above mentioned spreadsheet which uses the required method to automatically calculate both NOx and CO hourly and annual emissions. The resulting data is used to determine compliance with emission limits.</p>

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Permit Section	Monitoring Required	Monitoring Performed
2.9.4.10	<p>Visible emissions from stationary combustion equipment shall not equal or exceed an opacity of 20%. Use of pipeline quality natural gas fuel as defined in Conditions 2.9.3.1 and 2.9.3.4 constitutes compliance with 20.2.61 NMAC unless opacity exceeds 20%. At such time as No. 2 fuel oil as defined in Condition 2.9.3.1 is used, opacity shall be measured in accordance with the procedures at 40 CFR 60, Appendix A, Method 9. Opacity measurements shall continue on a quarterly basis per calendar year for each effected unit until such time as pipeline quality natural gas is used.</p>	<p>LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine compliance with the opacity limitation.</p> <p>Delivery of pipeline quality natural gas is specified in the transportation contract with the supplier.</p> <p>Opacity measurements performed at the Power Plant are provided in Attachment I.</p>
2.9.4.11	<p>Initial compliance tests are required on Unit TA-3-22 CT-1 for NO_x and CO. These tests shall be conducted within sixty (60) days after the unit achieves the maximum normal production. If the maximum normal production rate does not occur within one hundred twenty (120) days of source startup, then the tests must be conducted no later than one hundred eighty (180) days after initial startup of the source. The tests shall be conducted in accordance with EPA Reference Methods 1 through 4, Method 7E for NO_x, and Method 10 for CO contained in CFR Title 40, Part 60, Appendix A, and with the requirements of Subpart A, General Provisions, 60.8(f). Alternative test method(s) may be used if the Department approves the change. The permittee shall submit a testing protocol to the Department at least thirty (30) days prior to the test date, and provide notification to the Department at least thirty (30) days prior to the test date.</p>	<p>An initial compliance test was performed on the combustion turbine within 60 days following the unit achieving maximum normal production. The unit achieved its maximum normal production rate on September 27, 2007, and the compliance test was performed on October 5, 2007. The test report was provided to NMED on October 22, 2007. The test consisted of the EPA test methods identified in this permit condition.</p>

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Permit Section	Monitoring Required	Monitoring Performed
2.9.4.12	The permittee shall comply with fuel sulfur monitoring requirements at 40 CFR 60.334(h) applicable to Unit TA-3-22 CT-1 by making the required demonstration which shows the fuel combusted in the turbine meets the definition of natural gas at 40 CFR 60.331(u).	The natural gas used by the combustion turbine meets the definition of natural gas in 60.331(u). The sulfur monitoring requirement is met under 40 CFR 60.334(h)(3)(i), which allows the use of a current and valid transportation contract that specifies the maximum total sulfur content is 20 grains per 100 scf or less. The transportation contract specifies a sulfur content not to exceed 2 grains of total sulfur per 100 scf. A copy of the transportation contract is available at the facility.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

Deviations

Permit Section 4.2 requires that all instances of deviations from permit conditions, including emergencies, be clearly identified. Listed below are permit deviations this period:

1. No deviations occurred during this reporting period.

----- Last Entry -----

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment A
Asphalt Plant Opacity Reports**

Summary Table, Reports Attached

	Source	Date	Time	Average Opacity	EPA Method
July	Entire Plant	07/09/07	8:56 am	0	22 ^(b)
Aug.	Entire Plant	08/21/07	10:04 am	0	22 ^(b)
Sept.	Top of Shaker	09/06/07	8:30 am	0	9 ^(a)
Oct.	Top of Shaker	10/11/07	8:37 am	0	9 ^(a)
Nov.	Top of Shaker	11/07/07	8:48 am	0	9 ^(a)
Dec.	Top of Shaker	12/05/07	9:25 am	0	9 ^(a)


(a) EPA Method 9 was used. Average opacity for the Asphalt Plant is the sum of the highest consecutive 24 readings divided by 24 (6 minutes of readings). The method is in accordance with 20.2.61 NMAC and condition 2.1.4.1 of the Los Alamos National Laboratory (LANL) Operating Permit P100M2.

(b) EPA Method 22 was used to determine if any visible emissions greater than zero were present at the plant. If any emissions are observed using Method 22, a Method 9 observation will be performed on those points. Use of Method 22 is in accordance with condition 2.1.4.1 of the Los Alamos National Laboratory (LANL) Operating Permit P100M2.

**Los Alamos National Laboratory
METHOD 22 FUGITIVE OPACITY EMISSION INSPECTION FORM**

Location: LANL Asphalt Plant	Observer Affiliation: KSL-ENV
Representative: Donald Stone	Date of Inspection: 07/09/07
Sky Conditions: Clear	Wind Direction: From NNW
Precipitation: None	Wind Speed: 3 -7 mph
Industry: National Defense	Process Unit: All potential fugitive sources

Sketch of Process Unit:
Indicate:
 * observer position relative to source * wind direction
 * potential emission and/or actual emission points * North direction
 * sun location



Observations:

	Clock Time	Observation period duration (min:sec)	Accumulated emission time (min:sec)
Begin	_0856_	_11 min_	_0_
	_____	_____	_____
	_____	_____	_____
End Observation	_0907_		

Notes: During the observation period, there were no visible emissions. All probable fugitive sources at the plant were observed.

This form is used to determine if any fugitive emission with opacity greater than zero is observed. If an emission is observed during the Method 22 inspection observation period (which must be at least 6 minutes for the Asphalt Plant and 10 minutes for all other LANL sources), a method 9 visible emission test may need to be performed.

Signature of observer Inspector: *Donald Stone* **Date:** 7-9-07


**Los Alamos National Laboratory
METHOD 22 FUGITIVE OPACITY EMISSION INSPECTION FORM**

Location: LANL Asphalt Plant	Observer Affiliation: KSL-ENV
Representative: Donald Stone	Date of Inspection: 8-21-07
Sky Conditions: Clear	Wind Direction: From NNE
Precipitation: None	Wind Speed: 3-5 mph
Industry: National Defense	Process Unit: All potential fugitive sources

Sketch of Process Unit:

Indicate:

- * observer position relative to source
- * potential emission and/or actual emission points
- * sun location
- * wind direction
- * North direction



Observations:

	Clock Time	Observation period duration (min:sec)	Accumulated emission time (min:sec)
Begin	_ 1004 _	_ 10 min _	_ 0 _
	_____	_____	_____
	_ 1014 _	_____	_____
End Observation	_____	_____	_____

Notes: *During the observation period, there were no visible emissions. All probable fugitive sources at the plant were observed.*


This form is used to determine if any fugitive emission with opacity greater than zero is observed. If an emission is observed during the Method 22 inspection observation period (which must be at least 6 minutes for the Asphalt Plant and 10 minutes for all other LANL sources), a method 9 visible emission test may need to be performed.

Signature of observer Inspector: *Donald Stone* **Date:** *8-21-07*

**LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)**

Source Name: LANL Asphalt Plant	
Source Location: TA-60 (Sigma Mesa)	
Type of Source: Asphalt Plant	Type of Control Equipment: Baghouse
Describe Emission Point (Top of stack, etc.) Top of Shaker Stack	
Height Above Ground Level: 45 Feet	Height Relative to Observer: 45 Feet
Distance From Observer: 55 Feet	Direction of Source From Observer: NW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color: NO emission	Plume Type: <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 10 to 12 inches above stack	
Describe Background (i.e. blue sky, trees, etc.) Partly cloudy sky	
Background Color: Blue Gray	Sky Conditions: Partly cloudy
Wind Speed: 1-2 mph	Wind Direction: from NE (provide from/to, i.e. from North to South)
Ambient Temperature: 62 °F	Relative Humidity: 66 %
Additional Comments/Information: all emission points clear	

Observation Date		Start Time				End Time
9-6-07		0830				0836
Min	Sec	0	15	30	45	Comments
	1		0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						




Average 6-Minute Opacity: 0%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: Don Stone Title: Engineer	
Signature: Don Stone	Date: 9-6-07
Observer Organization: KSL	
Certified by: ETA	Certification Date: 8-29-07

**LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)**

Source Name: LANL Asphalt Plant	
Source Location: TA-60 (Sigma Mesa)	
Type of Source Asphalt Plant	Type of Control Equipment Baghouse
Describe Emission Point (Top of stack, etc.) Top of shaker stack	
Height Above Ground Level 45 Feet	Height Relative to Observer 45 Feet
Distance From Observer 55 Feet	Direction of Source From Observer NNW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color NO EMISSION	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES IF YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 3/2" above top of stack	
Describe Background (i.e. blue sky, trees, etc.) Blue Sky	
Background Color BLUE	Sky Conditions Clear
Wind Speed 5-9 mph	Wind Direction (provide from/to, i.e. from North to South) From NW
Ambient Temperature 55 °F	Relative Humidity 53 %
Additional Comments/Information: ALL EMISSION POINTS CLEAR	

Observation Date 10-11-07		Start Time 0837		End Time 0842	Comments
Min	Sec	0	15	30	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					




Average 6-Minute Opacity 0%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: Don Stone Title: Engineer	
Signature: Don Stone	Date: 10-11-07
Observer Organization: KSL	
Certified by: ETA	Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: LANL Asphalt Plant	
Source Location: TA-60 (Sigra Mesa)	
Type of Source: Asphalt Plant	Type of Control Equipment: Baghouse
Describe Emission Point (Top of stack, etc.): TOP OF SHAKER STACK	
Height Above Ground Level: 45 Feet	Height Relative to Observer: 45 Feet
Distance From Observer: 55 Feet	Direction of Source From Observer: NW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color: NO EMISSION	Plume Type: <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 ft above top of stack	
Describe Background (i.e. blue sky, trees, etc.): Blue sky	
Background Color: Blue	Sky Conditions: Clear
Wind Speed: 2-5 mph	Wind Direction: (provide from/to, i.e. from North to South) From SE
Ambient Temperature: 51 °F	Relative Humidity: 30 %
Additional Comments/Information: All emission points clear	

Observation Date		Start Time				End Time
11-7-07		0848				0854
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						




Average 6-Minute Opacity: 0%	Range of Opacity Readings: Min. 0% Max. 0%
OBSERVER (please print) Name: Von Stone Title: Engineer	
Signature:	Date: 11-7-07
Observer Organization: KSL	
Certified by: ETA	Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: LANL Asphalt Plant	
Source Location: TA-60 (Sigma Mesa)	
Type of Source: Asphalt Plant	Type of Control Equipment: Baghouse
Describe Emission Point (Top of stack, etc.) TOP OF SHAKER STACK	
Height Above Ground Level: 45 Feet	Height Relative to Observer: 45 Feet
Distance From Observer: 55 Feet	Direction of Source From Observer: NW
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color: NO EMISSION	Plume Type: <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 FT. ABOVE TOP STACK	
Describe Background (i.e. blue sky, trees, etc.) Blue Sky	
Background Color: Blue	Sky Conditions: Partly Cloudy
Wind Speed: 5-7 mph	Wind Direction: (provide from/to, i.e. from North to South) FROM SSE
Ambient Temperature: 42 °F	Relative Humidity: 53 %
Additional Comments/Information: ALL EMISSION POINTS CLEAR	

Min	Sec				Comments
	0	15	30	45	
1	00	00	00	00	
2	00	00	00	00	
3	00	00	00	00	
4	00	00	00	00	
5	00	00	00	00	
6	00	00	00	00	
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 6-Minute Opacity: 00%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: Don Stone Title: ENGINEER	
Signature:	Date: 12-5-07
Observer Organization: KSL	
Certified by: ETA	Certification Date: 8-29-07

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment B
Beryllium HEPA Filter Tests Results**

Summary Table, Reports Attached

Unit	Date	Pass/Fail
TA-55 (H-5-1450) (FF-854)	7/10/2007	Pass
TA-55 (H-5-1460) (FF-855)	7/10/2007	Pass
TA-55 (H-5-5870) (FF-858)	7/10/2007	Pass
TA-55 (H-5-5880) (FF-859)	7/10/2007	Pass

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

ATTACHMENT A
300 Area Glovebox Exhaust FF-854 Data Sheet

Date: 07-10-07 (8.4.1) LAS Calibration Expiration Date: 03-06-08 (8.4.3) Diluter Calibration Expiration Date: 10-02-07 (8.4.4) Dilution Ratio: 2063 (8.4.2)

Step Number	Item	FF-854 H-5-1450
9.1.12.2	Background concentration (part./cc)	2.825×10^{-2} part concentration
9.1.12.3	Upstream concentration (part./cc)	2.149×10^6 part concentration
9.1.12.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	<i>PO</i> Initials
9.1.12.5	1 st stage downstream concentration (part./cc)	2.616×10^2 part concentration
9.1.12.6	2 nd /3 rd stage downstream concentration (part./cc)	3.884×10^{-2} part concentration
9.1.12.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	1.217×10^{-4}
9.1.12.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	4.428×10^{-9}
9.1.13.2 9.1.13.3	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<i>PO</i> Initials <i>MMW</i> Independent Verification

Valve	Required Position	Initials	Independent Verification
HV-854-J	Closed and Locked	<i>PO</i>	<i>MMW</i>
HV-854-G	Closed	<i>PO</i>	<i>MMW</i>
HV-854-H	Closed	<i>PO</i>	<i>MMW</i>
HV-854-D	Closed	<i>PO</i>	<i>MMW</i>
HV-854-C	Closed	<i>PO</i>	<i>MMW</i>
HV-854-B	Closed	<i>PO</i>	<i>MMW</i>
HV-854-A	Closed	<i>PO</i>	<i>MMW</i>
HV-854-AA	Closed	<i>PO</i>	<i>MMW</i>

FOR INFORMATION ONLY

Comments:

Surveillance Personnel: *[Signature]* Date: 07-10-07 OC On-duty Supervisor: *[Signature]* Date: 7/10/07

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

ATTACHMENT C
300 Area Glovebox Exhaust FF-855 Data Sheet

Date: 07-10-07 (8.4.1) LAS Calibration Expiration Date: 03-06-08 (8.4.3) Diluter Calibration Expiration Date: 10-2-07 (8.4.4) Dilution Ratio: 2063 (8.4.2)

Step Number	Item	FF-855 H-5-1460
9.3.12.2	Background concentration (part./cc)	7.002×10^{-3} part concentration
9.3.12.3	Upstream concentration (part./cc)	2.445×10^6 part concentration
9.3.12.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	PD Initials
9.3.12.5	1 st stage downstream concentration (part./cc)	3.107×10^1 part concentration
9.3.12.6	2 nd /3 rd stage downstream concentration (part./cc)	1.059×10^{-2} part concentration
9.3.12.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	1.270×10^{-5}
9.3.12.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	1.444×10^{-9}
9.3.13.2 9.3.13.3	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	PD Initials Independent Verification Munt

Valve	Required Position	Initials	Independent Verification
HV-855-J	Closed and Locked	PD	Munt
HV-855-G	Closed	PD	Munt
HV-855-H	Closed	PD	Munt
HV-855-D	Closed	PD	Munt
HV-855-C	Closed	PD	Munt
HV-855-B	Closed	PD	Munt
HV-855-A	Closed	PD	Munt
HV-854-AA	Closed	PD	Munt

Comments:

FOR INFORMATION ONLY

Surveillance Personnel [Signature] 07-10-07 Date

OC On-duty Supervisor [Signature] 7/10/07 Date

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

ATTACHMENT B

300 Area SRL Glovebox Exhaust FF-858 Data Sheet

Date: 7-10-07 (8.4.1) LAS Calibration Expiration Date: 03-06-08 (8.4.3) Diluter Calibration Expiration Date: 10-2-07 (8.4.4) Dilution Ratio: 2063 (8.4.2)

Step Number	Item	FF-858 H-5-5870	
9.2.9.2	Background concentration (part./cc)	0.00	part. concentration
9.2.9.3	Upstream concentration (part./cc)	2.189×10^6	part. concentration
9.2.9.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	<i>FD</i>	Initials
9.2.9.5	1 st stage downstream concentration (part./cc)	5.62×10^1	part. concentration
9.2.9.6	2 nd /3 rd stage downstream concentration (part./cc)	7.062×10^{-3}	part. concentration
9.2.9.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	2.578×10^{-5}	
9.2.9.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	3.226×10^{-9}	
9.2.10.3 9.2.10.4	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<i>FD</i>	Initials Independent Verification <i>WME</i>

Valve	Required Position	Initials	Independent Verification
HV-858-8	Closed	<i>FD</i>	<i>WME</i>
HV-858-7	Closed	<i>FD</i>	<i>WME</i>
HV-858-5	Closed	<i>FD</i>	<i>WME</i>
HV-858-3	Closed	<i>FD</i>	<i>WME</i>
HV-858-2	Closed	<i>FD</i>	<i>WME</i>
HV-858-1	Closed	<i>FD</i>	<i>WME</i>
HV-854-AA	Closed	<i>FD</i>	<i>WME</i>

Comments:

FOR INFORMATION ONLY

Surveillance Personnel: *[Signature]* 7-10-07 Date
 OC On-duty Supervisor: *[Signature]* 7/10/07 Date

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

ATTACHMENT D
300 Area SRL Glovebox Exhaust FF-859 Data Sheet

Date: 07-10-07 (8.4.1) LAS Calibration Expiration Date: 03-06-08 (8.4.3) Diluter Calibration Expiration Date: 10-02-07 (8.4.4) Dilution Ratio: 2063 (8.4.2)

Step Number	Item	FF-859 H-5-5880
9.4.9.2	Background concentration (part./cc)	3.531×10^{-3} part. concentration
9.4.9.3	Upstream concentration (part./cc)	2.095×10^6 part. concentration
9.4.9.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	PO Initials
9.4.9.5	1 st stage downstream concentration (part./cc)	6.434×10^1 part. concentration
9.4.9.6	2 nd /3 rd stage downstream concentration (part./cc)	7.062×10^{-3} part. concentration
9.4.9.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	3.070×10^{-5}
9.4.9.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	1.685×10^{-9}
9.4.10.3 9.4.10.4	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	PO Initials Independent Verification <i>[Signature]</i>

Valve	Required Position	Initials	Independent Verification
HV-859-8	Closed	PO	<i>[Signature]</i>
HV-859-7	Closed	PO	<i>[Signature]</i>
HV-859-5	Closed	PO	<i>[Signature]</i>
HV-859-3	Closed	PO	<i>[Signature]</i>
HV-859-2	Closed	PO	<i>[Signature]</i>
HV-859-1	Closed	PO	<i>[Signature]</i>
HV-854-AA	Closed	PO	<i>[Signature]</i>

Comments:

FOR INFORMATION

Surveillance Personnel: *[Signature]* Signature 07-10-07 Date OC On-duty Supervisor: *[Signature]* Signature 7/10/07 Date

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment C
Boilers and Heaters Natural Gas Usage**

2007 Small Boilers Data Entry / Gas Use

Data Entry	Metered Boilers			Total Gas Use ^(a)		Non-Metered Gas Use	12-Month Rolling Total for all Small Boilers (MMSCF) ^(e)
	TA-55 Boiler Gas Use (MSCF) ^(c)		TA-50-2 ^(d) (MSCF)				
	Month	BHW-1B (B-602)	BHW-2B (B-603)	BS-1	(MSCF)	(MMSCF)	
January	1	2657		81,782	81.78	79.12	502.42
February	676	1261		66,101	66.10	64.16	508.94
March	1609	1		54,352	54.35	52.74	505.10
April	1248	797		44,215	44.22	42.17	513.53
May	1379	1836		29,468	29.47	26.25	521.07
June	348	379	0.1	13,530	13.53	12.80	518.20
July	333	128		13,687	13.69	13.23	519.25
August	415	1297		8,794	8.79	7.08	514.87
September	345	1160		19,691	19.69	18.19	511.34
October	345	1537		36,509	36.51	34.63	506.16
November	702	798		54,213	54.21	52.71	502.26
December	769	814	0.0	79,717	79.72	78.13	502.06
TOTAL	8170	12665	0.1	502,059	502.06	481.22	Permit Limit : 870

2006 Non Metered Boiler Pool Capacity: 304.3 MMBTU/hr^(f)

Estimated Gas-Use per MMBtu rating Jan-June: 0.91 MMscf/MMBtu/hr
 Estimated Gas-Use per MMBtu rating July-Dec: 0.67 MMscf/MMBtu/hr
 Estimated Gas-Use per MMBtu - Annual: 1.58 MMscf/MMBtu/hr

Definitions: MMSCF= Million Standard Cubic Feet
 MSCF = Thousand Standard Cubic Feet
 Metered/Non-metered: Metered boilers are those units that have unit specific volumetric flow meters for the boiler(s) only.

AIRS Stack #	Gas Use Non-Metered ^(g) (MMSCF)								Insignificant Units ^(h)
	015	016	017	018	019	020	021	024	
Location:	TA-48-1	TA-48-1	TA-48-1	TA-53-365	TA-53-365	TA-59-1	TA-59-1	TA-16-1484	Lab Wide
ID:	BS-1	BS-2	BS-6	BHW-1	BHW-2	BHW-1	BHW-2	Plant 5	Various
Design Rate⁽ⁱ⁾ (MMBTU/hr)	5.336	5.335	7.140	7.115	7.115	5.335	5.335	12.700	249
Calculated Gas Use-Jan-June	4.862	4.861	6.505	6.482	6.482	4.861	4.861	11.571	226.769
Calculated Gas Use-July-Dec	3.577	3.576	4.786	4.769	4.769	3.576	3.576	8.513	166.826
Calculated Gas Use-Annual	8.439	8.438	11.291	11.251	11.251	8.438	8.438	20.084	393.595

2007 TA-21 Steam Plant Data Entry / Fuel Use

DATA ENTRY						
Monthly Fuel Use						
TA-21-357						
Month	Natural Gas	Fuel Oil	Converted	Month	Natural Gas Use	Fuel Oil Use
	(MCF)	(gallons)	Natural Gas		12-Month Rolling Total	12-Month Rolling Total
			(MMscf)		(MMscf)	(Gallons)
January	3184	0	3.184	January	29.16	402
February	2895	9	2.895	February	28.58	411
March	2853	10	2.853	March	27.87	421
April	2297	6	2.297	April	27.65	427
May	2172	3	2.172	May	27.82	430
June	1803	41	1.803	June	27.91	471
July	0	0	0.000	July	26.21	137
August	0	0	0.000	August	24.62	118
September	0	0	0.000	September	22.91	118
October	0	0	0.000	October	20.70	95
November	0	0	0.000	November	18.20	75
December	0	0	0.000	December	15.20	69
Annual Totals:	15204	69	15.204			
Jan. - June	15204	69	15.204			
July - Dec.	0	0	0.000			

Permit Limit = 60 MMScf/yr natural gas (12 month rolling total)
and 10,000 gal/yr fuel oil (12 month rolling total)

In August, 2007, the TA-21 Steam Plant was placed on the D&D list and will no longer be operated. No further entries will be made on this calculation sheet after that date. A letter was sent to NMED in October informing them that the plant has closed.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment D
Carpenter Shop Hours of Operation**

2007 TA-3 & TA-15 Carpenter Shops

TA-3	Data Entry
Month	Hours of Operation ¹
	TA-3
January	3.1
February	4.3
March	25.6
April	4.6
May	3.4
June	2.3
6 mo. Total	43.3

TA-3	Data Entry
Month	Hours of Operation ¹
	TA-3
July	2.9
August	9.9
September	2.3
October	4.9
November	1.5
December	1.4
6 mo. Total:	22.9

TA-15	Data Entry
Month	Hours of Operation ¹
	TA-15
January	9.4
February	17.4
March	47.2
April	13.6
May	20.6
June	8.9
6 mo. Total	117.1

TA-15	Data Entry
Month	Hours of Operation ¹
	TA-15
July	12.3
August	10.3
September	8.8
October	10.2
November	13.0
December	4.8
6 mo. Total:	59.4

Saws, drills, shaping and sanding equipment shall each not operate in excess of 4368 hours per year.

Reference
1. Based on information provided monthly by the shop foreman from each shop.

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment E
Degreaser Solvent Usage**

Historical Solvent Usage Data

The usage information for Emission Unit TA-55-DG-1, ultrasonic cold batch degreaser, from Jul-01-2007 through Dec-31-2007 is displayed below.

General Degreaser Information

Degreaser	Type	TA	Solvent
UT Bath	Cold Batch	55	Trichloroethylene

Date Measured	Initial Solvent Level (inches)	Volume Added (liters)	Level Added (inches)	Volume Removed (liters)	Level Removed (inches)
Jul-16-2007	7.4	0	0	14.55	7.4
Jul-23-2007	0	14.74	7.5	0	0
Aug-27-2007	7.5	0	0	1	0.5
Sep-27-2007	6.5	0	0	0	0
Oct-24-2007	6.5	0	0	0	0
Nov-27-2007	6.5	0	0	0	0
Dec-18-2007	6	0	0	0	0

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment F
Internal Combustion Generator Hours of Operation**

2007 Generator Hours

TA	Bldg	Manufacturer	MODEL	KW	Fuel Type	Previous Reading Date	Previous Reading	First 6 Month Readings			Second 6 Month Readings		
								6 Month Reading Date	Reading	Hours Run	12 Month Reading Date	Reading	Hours Run
3	38	Onan Sons	H1750DSG15	175	Diesel	Dec-06	3054.4	May-07	3057.0	2.6	Nov-07	3070	13
3	38	Onan Sons	350DFCC	350	Diesel	Dec-06	2619.4	May-07	2629.4	10.0	Nov-07	2636.5	7.1
3	38	Cummins	150DGFA	150	Diesel	Dec-06	1147.0	May-07	1158.9	11.9	Nov-07	1170.6	11.7
3	40	Onan Sons	1500DVE15R31374B	150	Diesel	Dec-06	3.2	May-07	6.1	2.9	Dec-07	6.6	0.5
3	223	Onan Sons	45.OEM-15R/10742D	45	Nat. Gas	Dec-06	478.0	May-07	481.1	3.1	Dec-07	489.5	8.4
3	440	Cummins	500FDR5051	150	Diesel	Dec-06	121.8	May-07	121.8	0.0	Dec-07	121.8	121.8
3	440	Cummins	DFGA-5005210	500	Diesel	Dec-06	69.5	May-07	74.8	5.3	Dec-07	81.8	7
3	1076	Cummins	DGBB-5601289	35	Diesel	Dec-06	101.2	Jun-07	116.7	15.5	Dec-07	129.7	13
3	1400	Cummins	DFEH-5699616	400	Diesel	Apr-07	14.0	May-07	14.1	0.1	Dec-07	33	18.9
3	1404	Cummins	DFLC-5554001	1250	Diesel	Dec-05	287.9	Jun-07	324.2	36.3	Dec-07	336.5	12.3
3	1498	Caterpillar	SR-4	600	Diesel	Nov-05	303.0	May-07	315.0	12.0	Dec-07	326	11
3	2322	Onan Sons	DGDA-5005757	80	Diesel	Nov-05	329.1	May-07	336.8	7.7	Nov-07	339.8	3
16	980	Cummins	KTA50-G2	1100	Diesel	Dec-05	226.3	Jun-07	276.2	49.9	Dec-07	293.4	17.2
16	1374	Onan Sons	60ENA	60	Nat. Gas	Nov-05	1039.4	May-07	1058.9	19.5	Dec-07	1092.9	34
18	31	Onan Sons	275DFML29807N	275	Diesel	Dec-05	173.4	Jun-07	180.8	7.4	Dec-07	180.8	0
21	357	Caterpillar	SR-4	125	Diesel	Nov-05	497.5	May-07	541.0	43.5	Jan-08	558.2	17.2
60	yard	Cummins	DFHD-4964979	1000	Diesel	Feb-07	272.4	Jul-07	293.9	21.5	Dec-07	648.4	354.5
35	2	Onan Sons	100DGDB	100	Diesel	Dec-05	115.5	Jun-07	115.3	0.0	Dec-07	115.5	0.2
35	402	Cummins	DGCB-5674244	60	Diesel	Jun-07	107.4	Jun-07	107.4	0.0	Dec-07	138.4	31
43	1	Cummins	4BT3.9-GC	50	Diesel	Nov-05	369.4	May-07	379.0	9.6	Dec-07	383.9	4.9
43	1	Onan Sons	DVE	150	Diesel	Nov-05	562.6	May-07	589.1	26.5	Dec-07	620.2	31.1
46	335	Onan Sons	300DEFCEB	300	Diesel	Nov-05	873.8	May-07	900.4	26.6	Dec-07	959.5	59.1
48	45	Onan Sons	DFCB-5740130	300	Diesel	Nov-05	16.0	May-07	24.9	8.9	Dec-07	53.5	28.6
50	37	Cummins	680FDR5059FF	500	Diesel	Nov-05	485.1	May-07	489.1	4.0	Nov-07	502.9	13.8
50	184	Onan Sons	DGFA-568741	150	Nat. Gas	Nov-05	153.6	May-07	209.7	56.1	Dec-07	212.7	3
50	188	Onan Sons	L940563879	1250	Diesel	Nov-05	149.0	Jun-07	149.0	0.0	Dec-07	149	0
53	1	Onan Sons	60ENA	60	Nat. Gas	Nov-05	1165.4	May-07	1195.1	29.7	Dec-07	1234.1	39
53	2	Kato Eng.	Kamag-14	50	Diesel	Nov-05	194.3	May-07	194.3	0.0	Dec-07	194.3	0
53	M	Onan Sons	12.5JC-18R/16095AA	12.5	Nat. Gas	Nov-05	581.5	May-07	581.5	0.0	Dec-07	581.5	0
54	412	Olympian	95M-07874-F	500	Diesel	Nov-05	292.0	May-07	306.1	14.1	Dec-07	317.9	11.8
55	5	Kohler	100RZ71	100	Nat. Gas	Dec-05	71.3	May-07	74.4	3.1	Nov-07	79.3	4.9
55	8	Delco/Detroit	E7014DD	600	Diesel	Dec-05	805.3	Jun-07	814.3	9.0	Dec-07	822.2	7.9
55	364	Onan Sons	1250DFLC-4987	1250	Diesel	Dec-05	52.6	Jun-07	62.0	9.4	Dec-07	82.8	20.8
55	28	Onan Sons	40DL6T	40	Diesel	Dec-05	47.3	Jun-07	47.3	0.0	Dec-07	66.5	19.2
55	47	Onan Sons	1465	200	Diesel	Nov-05	515.6	May-07	526.6	11.0	Nov-07	540	13.4
55	142	Cummins	DFEB-4963414	400	Diesel	Dec-05	88.8	May-07	96.1	7.3	Dec-07	105	8.9
59	1	Allis Chalmers	2884-0703	90	Diesel	Nov-05	749.3	Jun-07	750.0	0.7	Dec-07	750	0
63	Yard	Murphy	3166-0084	20	Diesel	Nov-05	715.9	Jun-07	715.9	0.0	Dec-07	716	0.1
64	1	Onan Sons	250DVG	250	Diesel	Nov-05	148.0	May-07	153.1	5.1	Dec-07	166.9	13.8
64	39	Onan Sons	20.0DL4-15R	20	Diesel	Dec-05	189.9	Jun-07	189.9	0.0	Dec-07	189.9	0
69	33	Cummins	DFLC-5568730	1250	Diesel	Nov-05	53.2	May-07	62.5	9.3	Dec-07	71.3	8.8

41 Generators in use

12548

TOTAL

479.6

TOTAL

970.9

N/R = Not Read

First half average hours per unit

11.7

Second half average hours per unit

23.7

Annual Average of hours per unit

17.7

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment G
Data Disintegrator Box Throughput**

2007 TA-52 Data Disintegrator

Data Entry			Data Entry		
Month	Boxes ^(c) Shredded	12-Month Rolling Total	Month	Boxes ^(c) Shredded	12-Month Rolling Total
January	484	9257	July	1188	10900
February	542	8759	August	634	10066
March	2206	10199	September	977	10444
April	799	10293	October	535	10651
May	1719	10989	November	751	11387
June	992	10602	December	593	11420
6 mo. Total	6,742		6 mo. Total:	4,678	

Annual Boxes (2007):	11,420
----------------------	--------

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment H
Power Plant Natural Gas and Fuel Oil Usage**

TA-3 Power Plant Fuel Use Totals 2007 (Data Entry)

DATA ENTRY								
Month	TA-3-22 Power Plant ^b Boiler # 1 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant ^b Boiler # 2 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant ^b Boiler # 3 (Union Iron Works, 210 MMBTU/hr)		Monthly Totals	
	Natural Gas (MCF) ^a	Fuel Oil (gallons) ^a	Natural Gas (MCF) ^a	Fuel Oil (gallons) ^a	Natural Gas (MCF) ^a	Fuel Oil (gallons) ^a	Natural Gas (MMCF) ^a	Fuel Oil (gallons) ^a
January	11,719	319	31,832	0	31,733	0	75.284	319
February	36,598	0	21,940	347	611	0	59.149	347
March	38,858	438	4,328	212	8,387	406	51.573	1056
April	9,160	0	3,101	603	29,807	0	42.068	603
May	362	27,893	10,074	438	24,198	50,133	34.634	78464
June	0	0	0	0	0	0	0.000	0
July	25	0	0	0	0	0	0.025	0
August	15,215	0	146	0	0	0	15.361	0
September	24,466	438	1,230	0	88	0	25.784	438
October	19,297	384	17,033	0	1,124	438	37.454	822
November	2,830	274	40,509	24	2,446	274	45.785	572
December	1,475	384	60,327	0	2,709	329	64.511	713
Annual Totals:	160,005	30,130	190,520	1,624	101,103	51,580	451.628	83334
Jan. - June	96,697	28,650	71,275	1,600	94,736	50,539	262.708	80789
July - Dec.	63,308	1,480	119,245	24	6,367	1,041	188.920	2545

Month	12-Mo. Rolling Total Natural Gas (MMscf)	12-Mo. Rolling Total Fuel Oil (gallons)
January	615.3	21463
February	616.0	21097
March	609.8	21231
April	601.9	21456
May	602.6	99269
June	573.2	98611
July	546.3	97448
August	534.6	97448
September	526.9	97886
October	482.3	98270
November	463.3	82840
December	451.6	83334

Totals by Fuel Type		
	Natural Gas (MMscf)	Fuel Oil (Gallons)
Annual Totals:	451.63	83334.00
Jan. - June	262.71	80789.00
July - Dec.	188.92	2545.00

Permit Limits:	2000 MMscf	500,000 gallons
----------------	------------	-----------------

2007 Daily Turbine Gas Use (MCF), 365 Day Rolling Total Gas Use, & Hours of Operation

Day	Jan		Feb		Mar		Apr		May		Jun		Jul		Aug		Sep		Oct		Nov		Dec	
	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours	Gas Use	Hours
1																			0	0.0	0	0	0	0
2																			0	0.0	0	0	0	0
3																			165	0.8	0	0	0	0
4																			15	0.3	0	0	0	0
5																			1441	6.5	0	0	0	0
6																			0	0.0	0	0	0	0
7																			0	0.0	0	0	0	0
8																			0	0.0	0	0	0	0
9																			0	0.0	0	0	0	0
10																			0	0.0	0	0	0	0
11																			0	0.0	0	0	0	0
12																			0	0.0	0	0	0	0
13																			0	0.0	0	0	0	0
14																			0	0.0	0	0	0	0
15																			0	0.0	0	0	0	0
16																			0	0.0	0	0	0	0
17																			0	0.0	0	0	0	0
18																			0	0.0	0	0	0	0
19																			0	0.0	0	0	0	0
20																		9	0.25	0	0.0	0	0	0
21																		0	0	0	0.0	0	0	0
22																		130	0.75	0	0.0	0	0	0
23																		34	0.25	0	0.0	0	0	0
24																		430	2	0	0.0	0	0	0
25																		966	4.5	0	0.0	0	0	0
26																		972	4.5	0	0.0	0	0	0
27																		920	4.25	0	0.0	0	0	0
28																		329	2	0	0.0	0	0	0
29																		639	3	0	0.0	0	0	0
30																		396	2	0	0.0	0	0	0
31																		0	0.0				0	0
SUM																		4825		1621		0		0

First Half Gas Use: 0 MCF
 Second Half Gas Use: 6446 MCF
 Annual Gas Use: 6446 MCF

365 day rolling total: **6446** MCF

6.446 MMSCF

Permit Limit (365 day rolling total): 646 MMSCF

Gray shaded areas are prior to the initial startup of the turbine generator unit.

The SCFH value in the cell equation is from the compliance test report (223620 SCFH or 223.6 MSCFH)

**Los Alamos National Laboratory
Operating Permit P100M2
Semi-Annual Monitoring Report
July 1 – December 31, 2007**

**Attachment I
Power Plant Opacity Reports**

Summary Table, Reports Attached

Source	Date	Time	Average Opacity ^(a)
TA-3-22 Power Plant	July 2007	N/A	(b)
	August 2007	N/A	(b)
	09-11-07	10:57 am	0%
	09-11-07	11:08 am	0.125%
	09-18-07	10:55 am	0%
	09-18-07	11:08 am	0%
	10-02-07	10:24 am	0.625%
	10-02-07	10:35 am	0%
	10-16-07	10:39 am	0%
	10-23-07	10:25 am	0%
	10-23-07	11:36am	0%
	11-06-07	10:20 am	0%
	11-13-07	11:14 am	0%
	12-12-07	10:35 am	0%
	12-19-07	10:55 am	0%

- (a) Average opacity for the Power Plant is the sum of the highest consecutive 40 readings divided by 40 (10 minutes of readings). The method is in accordance with EPA Method 9 and 20.2.61 NMAC.
- (b) There were no visible emission readings taken in July or August due to a scheduled Power Plant steam outage. No fuel oil was used during these months.

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 3 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #3 STACK

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: NO EMISSION Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
 2" ABOVE TOP OF STACK


Describe Background (i.e. blue sky, trees, etc.): BLUE SKY

Background Color: BLUE Sky Conditions: CLEAR

Wind Speed: 3-4 mph Wind Direction: FROM SSE
 (provide from/to, i.e. from North to South)

Ambient Temperature: 59.4°F Relative Humidity: 65%

Additional Comments/Information:
 BURNER LIGHT-OFF EXERCISES WITH FUEL OIL



Observation Date		Start Time				End Time
9-11-07		1057				1107
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	MILITARY
2		0	0	0	0	START & END
3		0	0	0	0	TIME USED
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print): DON STONE Title: ENGINEER

Signature: Date: 9-11-07


Observer Organization: KSL-ENV

Certified by: ETA Certification Date: 8-29-07

**LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)**

Source Name: Power Plant at TA-3	
Source Location: TA-3-22	
Type of Source: Boiler # 3	Type of Control Equipment: No Particulate Control
Describe Emission Point (Top of stack, etc.) TOP OF BOILER #3 STACK	
Height Above Ground Level: 150 Feet	Height Relative to Observer: 140 Feet
Distance From Observer: 200 Feet	Direction of Source From Observer: NE
Description of Plume (stack exit only) <input checked="" type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input type="checkbox"/> No Plume Present	
Emission Color: BLACK TO CLEAR	Plume Type <input type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input checked="" type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 5-12" ABOVE TOP OF STACK	
Describe Background (i.e. blue sky, trees, etc.) BLUE SKY	
Background Color: BLUE	Sky Conditions: CLEAR
Wind Speed: 3-4 mph	Wind Direction (provide from/to, i.e. from North to South) FROM SSE
Ambient Temperature: 59.4°F	Relative Humidity: 65%
Additional Comments/Information: BURNER LITE-OFF EXERCISES WITH FUEL OIL	

Observation Date		Start Time		End Time	Comments
9-11-07		1108		1118	
Min	Sec				
	0	15	30		
1	0	0	0	0	MILITARY
2	0	0	0	0	START/END
3	0	0	0	0	TIME USED
4	0	0	5	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 10-Minute Opacity: 0.125%	Range of Opacity Readings Min. 0% Max. 5%
OBSERVER (please print) Name: DON STONE Title: ENGINEER	
Signature: Don Stone	Date: 9-11-07
Observer Organization: KSL-FNY	
Certified by: ETA	Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler #1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): Top of Boiler #1 stack

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: No Emission Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
 ~ 12" above top of stack

Describe Background (i.e. blue sky, trees, etc.): Blue sky


Background Color: Blue Sky Conditions: clear

Wind Speed: 4-6 mph Wind Direction: FROM ESE
 (provide from/to, i.e. from North to South)

Ambient Temperature: 61 °F Relative Humidity: 45%

Additional Comments/Information:
 Fuel oil burn exercise
 Boiler tripped at 1106, re-lit
 at 1107

Observation Date		Start Time				End Time
9-18-07		1055				1105
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	No plume start & end time used
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print)
 Name: Don Stone Title: Engineer

Signature: Date: 9-18-07

Observer Organization: KSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): Top of Boiler #1 Stack

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: NO EMISSION Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present? NO YES IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined? 2" above top of stack

Describe Background (i.e. blue sky, trees, etc.): Blue sky


Background Color: Blue Sky Conditions: clear

Wind Speed: 4-6 mph Wind Direction: FROM ESE (provide from/to, i.e. from North to South)

Ambient Temperature: 61 °F Relative Humidity: 45%

Additional Comments/Information: Fuel Oil burn exercise Boiler tripped at 1106, re-lit at 1107. Very stable burn

Observation Date		Start Time				End Time
9-18-07		1108				1118
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	Military stack # end time used
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print): Don Stone Title: Engineer

Signature: Date: 9-18-07

Observer Organization: KSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 3 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #3 STACK

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 250 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only):
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: BLACK Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present? NO YES IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined? 2' 12" ABOVE TOP OF STACK

Describe Background (i.e. blue sky, trees, etc.): BLUE SKY

Background Color: BLUE Sky Conditions: PARTLY CLOUDY

Wind Speed: 13 mph Wind Direction: FROM NNW
 (provide from/to, i.e. from North to South)

Ambient Temperature: 59 °F Relative Humidity: 46%

Additional Comments/Information: FUEL OIL BURN EXERCISES

Observation Date		Start Time				End Time
10-2-07		1024				1034
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	5	10	5	
8		5	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Average 10-Minute Opacity: 0.625%


Range of Opacity Readings: Min. 0% Max. 10%

OBSERVER (please print): DON STONE Title: ENGINEER

Signature: *Don Stone* Date: 10-2-07

Observer Organization: KSL


Certified by: ETA Certification Date: 8-29-07



LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3	
Source Location: TA-3-22	
Type of Source Boiler # 3	Type of Control Equipment No Particulate Control
Describe Emission Point (Top of stack, etc.) TOP OF BOILER #3 STACK	
Height Above Ground Level 150 Feet	Height Relative to Observer 140 Feet
Distance From Observer 250 Feet	Direction of Source From Observer NE
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color NO EMISSION	Plume Type <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent <input type="checkbox"/> No Plume Present
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? ~12" ABOVE TOP OF STACK	
Describe Background (i.e. blue sky, trees, etc.) BLUE SKY	
Background Color BLUE	Sky Conditions PARTLY CLOUDY
Wind Speed 11-13 mph	Wind Direction (provide from/to, i.e. from North to South) FROM NNW
Ambient Temperature 59 °F	Relative Humidity 46 %
Additional Comments/Information: FUEL OIL BURN EXERCISES	

Observation Date		Start Time		End Time	Comments	
10-2-07		10:35		10:45		
Min	Sec	0	15	30	45	
	1		0	0	0	0
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity 0%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: DON STONE Title: ENGINEER	
Signature <i>Don Stone</i>	Date 10-2-07
Observer Organization KSL	
Certified by ETA	Certification Date 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 3 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #3 STACK

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 250 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: NO EMISSION Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
 1 FT. ABOVE TOP OF STACK

Describe Background (i.e. blue sky, trees, etc.): BLUE SKY


Background Color: BLUE Sky Conditions: CLEAR

Wind Speed: 5-10 mph Wind Direction: FROM SE
 (provide from/to, i.e. from North to South)

Ambient Temperature: 53 °F Relative Humidity: 36 %

Additional Comments/Information:
 FUEL OIL BURN EXERCISE

Observation Date		Start Time				End Time
10-16-07		1039				1049
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0 % Range of Opacity Readings: Min. 0 % Max. 0 %

OBSERVER (please print): DON STONE Title: ENGINEER

Signature: *Don Stone* Date: 10-16-07

Observer Organization: HSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #1 STACK

Height Above Ground Level: 150 Feet Height Relative to Observer: 130 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: NO EMISSION Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES. If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
 1 FT ABOVE TOP OF STACK

Describe Background (i.e. blue sky, trees, etc.): BLUE SKY


Background Color: Blue Sky Conditions: Clear

Wind Speed: 4-8 mph Wind Direction: From N
 (provide from/to, i.e. from North to South)

Ambient Temperature: 50 °F Relative Humidity: 26 %

Additional Comments/Information:
 FUEL OIL Burn exercise

Observation Date	Start Time				End Time
10-23-07	1025				1035
Min	Sec	0	15	30	45
1		0	0	0	0
2		0	0	0	0
3		0	0	0	0
4		0	0	0	0
5		0	0	0	0
6		0	0	0	0
7		0	0	0	0
8		0	0	0	0
9		0	0	0	0
10		0	0	0	0
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 10-Minute Opacity: 0%

Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print)
 Name: Don Stone Title: Engineer
 Signature: *Don Stone* Date: 10-23-07

Observer Organization: KSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #1 STACK

Height Above Ground Level: 155 Feet Height Relative to Observer: 130 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: NO EMISSION Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present? NO YES IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined? 1/2 above top of stack

Describe Background (i.e. blue sky, trees, etc.): Blue sky


Background Color: Blue Sky Conditions: Clear

Wind Speed: 6-8 mph Wind Direction: From N
 (provide from-to, i.e. from North to South)

Ambient Temperature: 52 °F Relative Humidity: 25 %

Additional Comments/Information:
 Fuel Oil Burn exercise
 Re-light at 1136

Observation Date		Start Time				End Time
10-23-07		1136				1145
Min	Sec	0	15	30	45	Comments
	1		0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print): Don Stone Title: Engineer

Signature: *Don Stone* Date: 10-23-07

Observer Organization: KSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3

Source Location: TA-3-22

Type of Source: Boiler # 3
 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): TOP OF BOILER #3 STACK

Height Above Ground Level: 150 Feet
 Height Relative to Observer: 140 Feet

Distance From Observer: 250 Feet
 Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: No EMISSION
 Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES. IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
 1/2 ft above top of stack

Describe Background (i.e. blue/sky, trees, etc.): GRAY SKY


Background Color: Gray
 Sky Conditions: Cloudy

Wind Speed: 5-8 mph
 Wind Direction (provide from/to, i.e. from North to South): From S

Ambient Temperature: 38 °F
 Relative Humidity: 55 %

Additional Comments/Information:
 FUEL OIL BURN EXERCISE

Min	Sec				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 10-Minute Opacity: 0 %

Range of Opacity Readings: Min. 0 % Max. 0 %

OBSERVER (please print):
 Name: Don Stone
 Title: Engineer

Signature: *Don Stone* Date: 11-6-07


Observer Organization: KSL

Certified by: ETA Certification Date: 8-29-07

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3	
Source Location: TA-3-22	
Type of Source Boiler # 2	Type of Control Equipment No Particulate Control
Describe Emission Point (Top of stack, etc.) TOP OF BOILER #2 STACK	
Height Above Ground Level 150 Feet	Height Relative to Observer 140 Feet
Distance From Observer 200 Feet	Direction of Source From Observer NE
Description of Plume (stack exit only) <input type="checkbox"/> Lifting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color NO EMISSION	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES IF YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 5 FT. ABOVE TOP OF STACK	
Describe Background (i.e. blue sky, trees, etc.) BLUE SKY	
Background Color BLUE	Sky Conditions CLEAR
Wind Speed 4-6 mph	Wind Direction (provide from-to, i.e. from North to South) FROM E
Ambient Temperature 52 °F	Relative Humidity 40 %
Additional Comments/Information: FUEL OIL BURN EXERCISE	


Observation Date		Start Time		End Time	Comments
11-13-07		1114		1124	
Min	Sec			30	45
	0	15			
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 10-Minute Opacity 0%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: Von Stone Title: Engineer	
Signature [Signature]	Date 11-13-07
Observer Organization KSL	
Certified by ETA	Certification Date 8-29-07

**LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)**

Source Name: Power Plant at TA-3	
Source Location: TA-3-22	
Type of Source Boiler # 1	Type of Control Equipment No Particulate Control
Describe Emission Point (Top of stack, etc.) TOP OF BOILER #1 STACK	
Height Above Ground Level 150 Feet	Height Relative to Observer 140 Feet
Distance From Observer 200 Feet	Direction of Source From Observer NE
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color NO EMISSION	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 FT. ABOVE TOP STACK	
Describe Background (i.e. blue sky, trees, etc.) BLUE SKY	
Background Color BLUE	Sky Conditions PARTLY CLOUDY
Wind Speed 3.5 mph	Wind Direction (provide from/to, i.e. from North to South) FROM ESE
Ambient Temperature 26 °F	Relative Humidity 68 %
Additional Comments/Information: FUEL OIL BURN EXERCISES	




Observation Date		Start Time				End Time
12-12-07		1035				1645
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Average 10-Minute Opacity		Range of Opacity Readings				
0%		Min.	0%		Max.	
OBSERVER (please print)						
Name: Don Stone				Title: ENGINEER		
Signature:				Date: 12-12-07		
Observer Organization: KSL						
Certified by: ETA				Certification Date: 8-29-07		

LOS ALAMOS NATIONAL LABORATORY (LANL)
 VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: Power Plant at TA-3	
Source Location: TA-3-22	
Type of Source Boiler # 3	Type of Control Equipment No Particulate Control
Describe Emission Point (Top of stack, etc.) TOP OF BOILER #3 STACK	
Height Above Ground Level 150 Feet	Height Relative to Observer 140 Feet
Distance From Observer 80 Yards	Direction of Source From Observer NE
Description of Plume (stack exit only) <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present	
Emission Color NO EMISSION	Plume Type <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached	
At what point in the plume was opacity determined? 2 1/2 FT. ABOVE TOP OF STACK	
Describe Background (i.e. blue sky, trees, etc.) BLUE SKY	
Background Color BLUE	Sky Conditions PARTLY CLOUDY
Wind Speed 3-5 mph	Wind Direction (provide from/to, i.e. from North to South) FROM SE
Ambient Temperature 35 °F	Relative Humidity 37 %
Additional Comments/Information: FUEL OIL BURN EXERCISE	

Min	Sec				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					



Average 10-Minute Opacity 0%	Range of Opacity Readings Min. 0% Max. 0%
OBSERVER (please print) Name: Don Stone Title: Engineer	
Signature: Don Stone	Date: 12-19-07
Observer Organization: KSL	
Certified by: ETA	Certification Date: 8-29-07