

LA-14408-SR  
Status Report

Approved for public release;  
distribution is unlimited.

---

Emissions Inventory Report Summary  
for Los Alamos National Laboratory for  
Calendar Year 2008

Edited by Hector Hinojosa, Group IRM-CAS.

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by Los Alamos National Security, LLC, for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396.



This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither Los Alamos National Security, LLC, the U.S. Government nor any agency thereof, nor any of their employees make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by Los Alamos National Security, LLC, the U.S. Government, or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of Los Alamos National Security, LLC, the U.S. Government, or any agency thereof. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

LA-14408-SR  
Status Report  
Issued: October 2009

---

Emissions Inventory Report Summary  
for Los Alamos National Laboratory for  
Calendar Year 2008

Ecology and Air Quality Group



## CONTENTS

<b>ABSTRACT</b> .....	<b>1</b>
<b>1.0 INTRODUCTION</b> .....	<b>1</b>
1.1 REGULATORY BASIS.....	1
1.2 CONTENTS OF ANNUAL EMISSIONS INVENTORY SUBMITTAL .....	3
1.3 CONTENTS OF THE SEMIANNUAL TITLE V OPERATING PERMIT EMISSIONS REPORTS .....	3
<b>2.0 REPORTED EMISSION SOURCES</b> .....	<b>4</b>
2.1 POWER PLANT .....	4
2.2 SMALL BOILERS AND HEATERS .....	6
2.3 ASPHALT PLANT .....	7
2.4 DATA DISINTEGRATOR.....	7
2.5 DEGREASERS .....	8
2.6 CARPENTER SHOP.....	8
2.7 OIL STORAGE TANKS .....	8
2.8 PERMITTED BERYLLIUM-MACHINING OPERATIONS.....	9
2.9 GENERATORS .....	9
2.10 COMBUSTION TURBINE .....	10
2.11 EMISSIONS FROM CHEMICAL USE ACTIVITIES.....	10
2.11.1 VOC Emissions .....	11
2.11.2 HAP Emissions.....	12
2.12 EMISSIONS SUMMARY BY SOURCE.....	13
<b>3.0 REPORTING EXEMPTIONS</b> .....	<b>15</b>
3.1 BOILERS .....	15
3.2 GENERATORS .....	15
3.3 VOC EMISSIONS.....	16
3.4 HAP EMISSIONS .....	17
3.5 PAINTS .....	17
<b>4.0 EMISSIONS SUMMARY</b> .....	<b>18</b>
4.1 2008 EMISSIONS SUMMARY.....	18
4.2 EMISSION TRENDS AND TITLE V PERMIT LIMITS .....	20
<b>REFERENCES</b> .....	<b>22</b>
<b>Attachment A</b> Emission Calculation Worksheets for Individual Emission Units .....	A-1
<b>Attachment B</b> 2008 Annual Emissions Inventory Submittal to NMED .....	B-1
<b>Attachment C</b> 2008 Semiannual Emissions Reports Submitted Under Title V Operating Permit Requirements .....	C-1

**Figures**

Figure 2.1-1 TA-3 power plant. ....6  
 Figure 2.11-1 Example of a laboratory fume hood at LANL.....11  
 Figure 4.1-1 Emissions of criteria pollutants by source in 2008.....19  
 Figure 4.1-2 Comparison of facility-wide annual reported emissions from 1999–2008. ....20  
 Figure 4.1-3 VOC and HAP emissions from chemical use, 1999–2008.....21

**Tables**

Table 2.0-1 Sources Included in LANL’s 2008 Annual Emissions Inventory and Semiannual Emissions Reports.....5  
 Table 2.6-1 Emissions for Carpenter Shops.....8  
 Table 2.7-1 Unit Emission Rates for Oil Storage Tanks.....9  
 Table 2.12-1 Summary of LANL 2008 Reported Emissions for Annual Emissions Inventory .....14  
 Table 2.12-2 Summary of LANL 2008 Semiannual Emissions as Reported Under Title V Operating Permit Requirements .....14  
 Table 3.3-1 Exemptions Applied for Chemical Use Activities.....17  
 Table 4.1-1 LANL Facility-Wide Criteria Pollutant Emissions for 2008 .....18  
 Table 4.1-2 LANL HAP Emissions from Top Five Chemicals Used in 2008 .....19

**Acronyms**

AIRS	Aerometric Information Retrieval System
AQB	Air Quality Bureau
CAS	Chemical Abstracts Service
CO	carbon monoxide
CO <sub>2</sub>	carbon dioxide
EPA	U.S. Environmental Protection Agency
FGR	flue gas recirculation
HAP	hazardous air pollutant
HCl	hydrochloric acid
LANL	Los Alamos National Laboratory
MSDS	material safety data sheet
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NO <sub>x</sub>	nitrogen oxides
PM	particulate matter
PM <sub>2.5</sub>	particulate matter with diameter less than 2.5 micrometers
PM <sub>10</sub>	particulate matter with diameter less than 10 micrometers
PSD	Prevention of Significant Deterioration
R&D	research and development
SO <sub>x</sub>	sulfur oxides
SO <sub>2</sub>	sulfur dioxide
TA	Technical Area
TSP	total suspended particulates
VOC	volatile organic compound

## **EMISSIONS INVENTORY REPORT SUMMARY FOR LOS ALAMOS NATIONAL LABORATORY FOR CALENDAR YEAR 2008**

by

### **ECOLOGY AND AIR QUALITY GROUP**

#### **ABSTRACT**

Los Alamos National Laboratory (LANL) is subject to annual emissions reporting requirements for regulated air pollutants under Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The applicability of the requirements is based on the Laboratory's potential to emit 100 tons per year of suspended particulate matter, nitrogen oxides, carbon monoxide, sulfur oxides, or volatile organic compounds. Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the New Mexico Environment Department/Air Quality Bureau, under 20.2.70 NMAC. This permit was modified and reissued on July 16, 2007. This Title V Operating Permit (Permit No. P-100M2) includes emission limits and operating limits for all regulated sources of air pollution at LANL. The Title V Operating Permit also requires semiannual emissions reporting for all sources included in the permit. This report summarizes both the annual emissions inventory reporting and the semiannual emissions reporting for LANL for calendar year 2008. LANL's 2008 emissions are well below the emission limits in the Title V Operating Permit.

---

## **1.0 INTRODUCTION**

### **1.1 Regulatory Basis**

Los Alamos National Laboratory (LANL or the Laboratory) has reported on air pollutants generated from its operations since the 1970s when Air Quality Control Regulation 703, Registration of Air Contaminant Sources, was promulgated. According to the regulation, the Laboratory was required to register air pollutant sources that emitted more than 2,000 lb per year of any air contaminant. This regulatory requirement later evolved into Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The objective of the reporting requirement is to provide emissions data to the New Mexico Environment Department (NMED)/Air Quality Bureau (AQB) so its staff can determine whether LANL meets state and federal air pollutant standards.

Annual emissions inventory reporting requirements under 20.2.73 NMAC apply to any stationary source which

- has been issued a construction permit under 20.2.72 NMAC;

- has been required to file a Notice of Intent under 20.2.73.200 NMAC; or
- emits in excess of
  - 1 ton per year of lead or
  - 10 tons per year of
    - total suspended particulates (TSP);
    - particulate matter (PM) with diameter less than 10 micrometers (PM<sub>10</sub>);
    - PM with diameter less than 2.5 micrometers (PM<sub>2.5</sub>);
    - sulfur dioxide (SO<sub>2</sub>);
    - nitrogen oxides (NO<sub>x</sub>);
    - carbon monoxide (CO); or
    - volatile organic compounds (VOCs).

The annual emissions inventory must be submitted to NMED/AQB by May 1 of each year. The NMED/AQB enters the data in the Aerometric Information Retrieval System (AIRS) (EPA 2008a). This nationwide system, administered by the U.S. Environmental Protection Agency (EPA), is used to help ensure ambient air quality standards are maintained and to track the state's air pollutant emissions. AIRS is a large air pollution database that contains information, requirements, and data on air pollution and air quality in the United States and various World Health Organization member countries. The program is operated by the EPA and state/local air pollution control agencies. The AIRS database tracks each state's progress towards achieving and maintaining National Ambient Air Quality Standards for criteria pollutants. The database is also used as a tool to help improve each state's air quality programs by enabling program members to access and compare past data and view data from other states. For 2008 emissions inventory reporting, NMED imported existing facility data from the AIRS database into spreadsheets and requested facilities to update the sheets with 2008 facility emissions information.

Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the NMED/AQB, under 20.2.70 NMAC. This permit was modified and reissued on July 16, 2007 (P-100M2) from the NMED/AQB (NMED 2007). A condition of the Title V Operating Permit is that LANL must submit semiannual emissions reports to NMED documenting that emissions from all permitted sources are below permitted emission levels. Section 4.0 of the permit states:

*Reports of actual emissions from permitted sources in Section 2.0 of the permit shall be submitted on a 6 month basis. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.11 of the permit. The reports shall be submitted within 90 days from the end of the reporting period. The reporting periods are January 1 through June 30, and July 1 through December 31. This condition is pursuant to 20.2.70.302.E.1 NMAC.*

Therefore, in 2004 the Laboratory began submitting the semiannual emissions reports as well as the annual emissions inventory. There are a few differences in which sources are included in the two emissions reports. These differences are explained in the following sections.



Furthermore, LANL submitted carbon dioxide (CO<sub>2</sub>) emissions from all stationary combustion sources in the Emissions Inventory Report as required by 20.2.87 NMAC, Greenhouse Gas Emissions Reporting, and in accordance with New Mexico's 2009 Greenhouse Mandatory Emissions Inventory Emissions Quantification Procedure. The estimated actual CO<sub>2</sub> emissions were reported for each combustion source in tons per year.

## **1.2 Contents of Annual Emissions Inventory Submittal**

NMED requested that LANL submit annual emissions inventory data for 2008 via electronic format for entry into AIRS. The information required for submittal includes the following:

- company name, address, and physical location for the facility;
- facility contact information;
- signed certification statement by a responsible facility official; and
- specific information for each emission unit such as stack and exhaust parameters, type and efficiency of control equipment, schedule of operation, annual process or fuel combustion rates, and estimated actual emissions for 2008.

This annual emissions inventory submittal includes air pollutant data for PM, PM<sub>10</sub>, CO, NO<sub>x</sub>, sulfur oxides (SO<sub>x</sub>), VOCs, beryllium, hazardous air pollutants (HAPs), and aluminum.

For 2008, LANL is required to report PM<sub>2.5</sub> emissions. LANL previously reported PM<sub>2.5</sub> emissions at the request of NMED for 2006 and 2007. Further, ammonia is a precursor to PM<sub>2.5</sub> formation. It contributes to the secondary aerosol formation of PM<sub>2.5</sub> by combining with NO<sub>x</sub> and SO<sub>x</sub> to form ammonium nitrate and fine sulfate particles. LANL is also required to report emissions of ammonia for 2008.

In the 2008 annual emissions inventory submittal, LANL provided PM<sub>2.5</sub> emissions data for all combustion sources and other emission sources where PM<sub>2.5</sub> emission factors were readily available. In the absence of PM<sub>2.5</sub> emission factors, PM or PM<sub>10</sub> emissions were assumed to be equivalent to PM<sub>2.5</sub>. The Laboratory does not operate any emission units that are sources of ammonia emissions. Ammonia was included in the facility-wide emission estimates for chemical use.

The Laboratory's 2008 Emissions Inventory Report also includes direct CO<sub>2</sub> emissions from stationary combustion sources in tons per year. This satisfies the Laboratory's reporting requirement under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.

## **1.3 Contents of the Semiannual Title V Operating Permit Emissions Reports**

The semiannual Title V Operating Permit emissions reports include actual estimated emissions for the reporting period for each emission source or source category included in the Title V Operating Permit. For each source category, the actual emissions are compared to emission limits listed in the permit. The emissions are calculated using operating data from logbooks and records maintained on-site. All emission calculations are consistent with calculation methods used for the annual emissions inventory.

The semiannual emissions reports include a few source categories not included in the annual emissions inventory. The Laboratory requested emission limits in their Title V Operating Permit for two source categories that are considered insignificant sources for the annual emissions inventory. These source categories are 1) small boilers and heaters and 2) stationary standby generators. LANL requested emission limits for these source categories to obtain federally enforceable limits that would keep the Laboratory under the major source threshold for Prevention of Significant Deterioration (PSD) applicability (20.2.74 NMAC). LANL's actual emissions from these insignificant sources have historically been very low; however, without federally enforceable limits on their operation, the potential to emit from these sources was quite high. To demonstrate that LANL is below the PSD applicability and is in compliance with the emission limits placed on these emission sources, LANL now must include these emissions in the semiannual Title V Operating Permit emissions reports.

## **2.0 REPORTED EMISSION SOURCES**

Table 2.0-1 shows the emission sources included in the Laboratory's 2008 annual emissions inventory (LANL 2009a) and the 2008 semiannual emissions reports (LANL 2008 and 2009b). The source categories and the methodology used to calculate emissions are described in the following sections.

The following subsections describe emission sources included in the 2008 emissions inventory and semiannual emissions reports and emission calculation methodology for each source type. A summary table of actual reported emissions by source is included at the end of this section (Section 2.12). Attachment A includes worksheets showing detailed emission calculations for individual emissions sources. A copy of the 2008 emissions inventory as submitted to NMED is presented in Attachment B. The 2008 semiannual emissions reports are included as Attachment C.

### **2.1 Power Plant**

The Laboratory operates a power plant at TA-3. The power plant produces steam for heating and electricity for much of the Laboratory when sufficient power from outside sources is not available. The heat produced from the power plant is used for comfort heat and hot water and to support facility processes. The power plant has three boilers that are fueled primarily with natural gas with No. 2 fuel oil as a backup. In the past, the Laboratory operated a second power plant at TA-21 and it was shut down in 2007.

For the 2008 emissions inventory, NMED requested that emissions from natural gas and No. 2 fuel oil be reported separately for the boilers located at each of the power plants. The TA-3 power plant was originally included in LANL's emissions inventory as a single unit. When a modification to the plant was made in 2001, the TA-3 power plant was separated into three separate units for emissions reporting purposes. Because each of the three boilers has the capability of burning either natural gas or No. 2 fuel oil, the TA-3 power plant is now reported as six units. The boilers at the TA-21 power plant were included in the emissions inventory as two units, one for natural gas and one for No. 2 fuel oil.

**Table 2.0-1  
Sources Included in LANL's 2008 Annual Emissions  
Inventory and Semiannual Emissions Reports**

Included in Annual Emissions Inventory	Included in Semiannual Emissions Reports	Comment
Power Plant (TA-3*)	Power Plant (TA-3)	n/a**
Boilers greater than 5 MMBTU/hr (14 units)	All small and large boilers and heaters (approximately 175 units)	Small boilers less than 5 MMBTU/hr are exempt from annual emissions inventory requirements (see Section 3.1), but are not exempt for greenhouse gas reporting
Asphalt Plant	Asphalt Plant	n/a
Degreasers	Degreasers	n/a
Air Curtain Destructors (shut down)	Not included	Air curtain destructors were shut down before issuance of the Title V Operating Permit.
Carpenter Shops	Carpenter Shops	n/a
Oil Storage Tanks	No tanks included	Applicability of the New Source Performance Standard for storage tanks changed in 2004 and the LANL oil storage tanks were not required to be included in the Title V Operating Permit.
Permitted Beryllium Sources	Permitted Beryllium Sources	n/a
Facility-wide Chemical Use	Facility-wide Chemical Use	n/a
Process Generators	Process Generators and Stationary Standby Generators (approximately 45 units)	Stationary standby generators are exempt from annual emissions inventory requirements (see Section 3.2), but are not exempt for greenhouse gas reporting.
TA-3 Turbine	TA-3 Turbine	n/a

\*TA = Technical Area \*\*n/a = Not Applicable

The 2008 emissions inventory reporting year used the updated emission factors for fuel oil for PM, PM<sub>10</sub>, and PM<sub>2.5</sub> as described for the TA-3 power plant boilers.

Actual estimated emissions are calculated on the basis of metered fuel consumption and emission factors. The primary source of emission factors is AP-42, the EPA's Compilation of Air Pollutant Emission Factors (EPA 1998). However, emission factors from stack tests conducted at the TA-3 power plant when burning natural gas were also used, as appropriate.

The TA-3 power plant has historically been the largest source of NO<sub>x</sub> emissions at the Laboratory. In 2002, a voluntary project to install pollution control equipment on the three boilers at the TA-3 power plant was completed. The three boilers were fitted with flue gas recirculation (FGR) equipment to reduce NO<sub>x</sub> emissions. Stack testing for NO<sub>x</sub> and CO was conducted before FGR equipment was installed and again after it was operational. Based on these stack test results, FGR reduced NO<sub>x</sub> emissions by approximately 64 percent. In 2008, there was no new fuel delivered to the TA-3 power plant. Figure 2.1-1 shows a picture of the TA-3 power plant building and stacks.

For the 2008 Emissions Inventory Report, the Laboratory reported direct CO<sub>2</sub> emissions from the TA-3 power plant in tons per year. This satisfies the Laboratory's reporting requirement under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.



**Figure 2.1-1 TA-3 power plant.**

## **2.2 Small Boilers and Heaters**

The Laboratory operates approximately 200 small boilers and heaters, used primarily for seasonal comfort heat. Most of the boilers are exempt from permitting requirements because of their small size and use as comfort boilers and are not included in the annual emissions inventory. The exemption analysis applied to boilers is discussed in Section 3.1 of this report. While most boilers are exempt from the annual emissions inventory, 160 boilers are being reported for direct CO<sub>2</sub> emissions, as required under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.

The boilers that are not exempt and reported in the 2008 annual emissions inventory include the following:

- three boilers at TA-48 (Eqpt 8, 9, and 10);
- two boilers at TA-53 (Eqpt 11 and 12);
- two boilers at TA-59 (Eqpt 13 and 14);
- two boilers at TA-55 (Eqpt 29 and 30);
- one process-related boiler at TA-50 (Eqpt 133);
- one boiler at TA-16 (Eqpt 134); and
- 160 boilers at various locations for CO<sub>2</sub> emissions only (Eqpt 140).

All of the reported boilers burn natural gas. Operating logs of actual fuel used for the TA-55 and TA-50 boilers were used to quantify emissions from these units. Fuel use for all other boilers was

estimated based on the total amount of natural gas used by the Laboratory minus the amount supplied to metered sources. The amount of natural gas left after subtracting out metered sources was apportioned to the various boilers based on their size. Since virtually all of the small boilers are seasonal boilers used for building heating, it was assumed they would all operate approximately the same amount of time over the course of the year. Some emission factors were available from stack tests (TA-55), some were provided by the boiler manufacturer (Sellers Engineering Company), and the rest were taken from AP-42 (EPA 1998). Copies of spreadsheets showing fuel use and emission factors for each boiler are included in Attachment A.

For the semiannual emissions reports, emissions from all small boilers and heaters are included as a source category. The Title V Operating Permit includes emissions limits for this group of emission sources. To estimate emissions, all un-metered fuel use was multiplied by AP-42 emission factors for small boilers burning natural gas (EPA 1998). Total emissions of each pollutant from all boilers and heaters in this source category were then summed and reported on the semiannual emissions reports.

### **2.3 Asphalt Plant**

The TA-60 asphalt plant began operations in July 2005. This unit replaced the TA-3 asphalt plant which has not operated since June 2003. The TA-3 asphalt plant was dismantled and removed in September 2003. Information on the amount of asphalt produced and the duration of daily operation at the TA-60 asphalt plant was provided as part of a monthly site support contractor data deliverable. The total asphalt produced in 2008 was 2,153 tons.

Per NMED request, direct CO<sub>2</sub> emissions from stationary combustion sources in tons per year are being reported for the first time in 2008. This satisfies the Laboratory's reporting requirement under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.

The emissions from the asphalt plant include criteria pollutants, HAPs and CO<sub>2</sub>. None of the emissions were significant in regard to the overall Laboratory emissions. The largest pollutant emitted from the asphalt plant was CO at 0.43 tons per year.

### **2.4 Data Disintegrator**

The data disintegrator is included in the 2008 emissions inventory as Eqpt 89. Operation of this source started in August 2004. Emissions are calculated using the methodology described in the permit application dated June 23, 2003. Emissions of PM, PM<sub>10</sub>, and PM<sub>2.5</sub> are calculated based on the number of boxes shredded, the amount of dust estimated to enter the exhaust (provided by the manufacturer), and the control efficiency of the cyclone and baghouse (also provided by the manufacturer). The permit application included PM<sub>2.5</sub> emission estimates. Therefore, an emission methodology had to be developed for the emission inventory reporting. No specific PM size distribution data were available. However, the manufacturer reported that dust into the exhaust would be in the size range of 5 to 20 μm. Based on visual observation and engineering judgment, a particle size distribution in the exhaust was estimated as follows:

- PM<sub>2.5</sub> 15%
- PM<sub>10</sub> 90%
- TSP 100%

The number of boxes of material shredded is provided on a monthly data deliverable from the site support contractor. The total number of boxes shredded at the data disintegrator in 2008 was 7,382.

## 2.5 Degreasers

The halogenated solvent cleaning machine at TA-55 has a capacity of 18 liters and is registered with NMED/AQB as required under the National Emissions Standards for Hazardous Air Pollutants, 40 CFR 63 Subpart T, Halogenated Solvent Cleaning. The solvent used in the machine, trichloroethylene (Chemical Abstracts Service [CAS] No. 79-01-6), is a VOC and a HAP. This emission unit is included in the annual emissions inventory as Eqpt 21. LANL uses a mass balance approach to estimate emissions. Logbooks are kept on the amount of solvent added and removed from the machine. Additionally, solvent levels in the machine are logged monthly. LANL has two additional halogenated solvent cleaning machines registered with NMED (Eqpt 29 and 30). These units were not operational in 2008. The emissions from the TA-55 degreaser for this reporting period are 30.3 lbs or 0.015 tons per year. This source category is reported in both the annual emissions inventory and the semiannual emissions reports.

## 2.6 Carpenter Shop

LANL operates a carpenter shop at TA-3 which was operated intermittently throughout the year. This carpenter shop was built before 1960 and is not subject to 20.2.72 NMAC construction permitting. However, LANL included carpenter shops in the Title V Operating Permit. Therefore, this source category is included in the annual emissions inventory as Area 3 and is included on the semiannual emissions reports. Additionally, a carpenter shop located at TA-15 is included in the Operating Permit and began operations in June 2005.

Emissions from the carpenter shops were calculated based on the flow rate out of the cyclone, the estimated concentration of particulate in the exhaust, AP-42 emission factors, and the hours of operation of the cyclones.

In 2008, total operation of the TA-3 carpenter shop was 50 hours and the total operation of the TA-15 carpenter shop was 110 hours. The emissions for both shops can be found in Table 2.6-1.

**Table 2.6-1  
Emissions for Carpenter Shops**

Carpenter Shop	PM <sub>10</sub> (tons)	PM <sub>2.5</sub> (tons)	TSP (tons)
TA-3	0.008	0.008	0.017
TA-15	0.014	0.013	0.030

## 2.7 Oil Storage Tanks

Two large diesel storage tanks are located at the TA-3 power plant for backup fuel to the boilers. These tanks are included in the annual emissions inventory as Eqpt 27 and 28. Emissions from these tanks are estimated using software developed by EPA for estimating emissions from storage tanks (EPA 2008b). The TANKS 4.0 software requires inputs for tank parameters, site-specific meteorological conditions, and actual fuel throughputs.

The Laboratory included 15 storage tanks in their recently updated Title V permit application because they were subject to 40 CFR 60, Subpart Kb, New Source Performance Standards. Fourteen of the 15 tanks store mineral oil, scintillation oil, or dielectric oil, which all have vapor pressures of <0.01 mm Hg. Applicability of Subpart Kb was modified by EPA in 2003 and these tanks are no longer subject to this regulation and were subsequently removed from the draft LANL Title V permit application.

Emissions from these smaller oil storage tanks were included for the first time in the 2002 annual emissions inventory. With agreement from NMED, emissions from the 14 tanks were summed and listed as one stack entry in the emissions inventory report due to the small quantity of emissions (email correspondence with Jim Shively, NMED/AQB, dated February 3, 2003). This “composite” mineral oil tank was assigned Eqpt 108. Because an equipment number is now assigned, emissions from these tanks will continue to be included in the annual emissions inventory submittal. However, these tanks are not included in the Title V Operating Permit semiannual emissions reports. Based on the most conservative tank parameters and actual throughput from chemical inventory records, a unit emission rate was calculated. The TANKS 4.0 software was used to estimate emissions for both vertical and fixed-roof tanks (EPA 2008b). Unit emission rates in lb/yr were multiplied by the number of active horizontal and vertical tanks (Table 2.7-1) to provide an estimate of total annual emissions from all of the active tanks.

**Table 2.7-1  
Unit Emission Rates for Oil Storage Tanks**

<b>Type of Tank</b>	<b>Total Annual Emissions per tank (lb)</b>	<b>No. of Oil Storage Tanks</b>	<b>Annual Emissions Estimates (lb)</b>	<b>Annual Emissions Estimates (ton)</b>
Horizontal Tank	1.24	11	13.64	0.0068

## **2.8 Permitted Beryllium-Machining Operations**

The Laboratory operates four permitted beryllium-machining operations that are subject to 40 CFR 61, Subpart C, and National Emission Standards for Beryllium. Beryllium-machining operations are reported in the emissions inventory under Act 2, 3, and 6 and Eqpt 5. Emissions reported for the Beryllium Test Facility (Act 3) are from actual stack emissions measurements. Emissions for the Target Fabrication Facility (Act 2) are from initial compliance stack testing and are reported as permitted emission levels. In addition, emissions from the Plutonium Facility (Act 6 and Eqpt 5) are reported at permitted emission levels. Foundry operations within the Plutonium Facility did not occur during this reporting period. Total emissions from all permitted beryllium operations are included in the semiannual emissions reports.

## **2.9 Generators**

LANL has four permitted generators with internal combustion engines located at TA-33 to support research activities. NMED issued a construction permit (Permit No. 2195-F) in October 2002 for installing the initial generator, and this unit is included in LANL's Title V Operating Permit. The unit first operated in May 2006. The unit operated for 25 hours in 2008. Three more units were

permitted in August 2007 at TA-33 (Permit No. 2195-P); they operated for a total of 75 hours in 2008.

The Laboratory maintains approximately 45 stationary standby generators that are considered exempt sources under the Construction Permit regulations (20.2.72.202.b NMAC) and the annual emissions inventory requirements. However, the generators were included in the 2008 Emissions Inventory report in order to report CO<sub>2</sub> emissions in accordance with greenhouse gas regulations. These sources are also included in LANL's Title V Operating Permit with operating limits and emission limits. Therefore, these sources must be included in the semiannual emissions reports. All stationary standby generators at LANL are exercised on a routine schedule to ensure they are operational and will function properly if needed. All units are equipped with hour meters to document how many hours they are used. The Laboratory maintains records on a semiannual basis to document hour meter readings. The number of hours each generator is used in a reporting period is multiplied by AP-42 emission factors for diesel-fired internal combustion engines or natural-gas-fired internal combustion engines (EPA 1996). Emissions are then summed for each pollutant and reported on the semiannual emissions reports for this source category. A new Eqpt ID (139) has been issued that includes approximately 40 generators for CO<sub>2</sub> emissions to be included in the Emissions Inventory report.

## **2.10 Combustion Turbine**

LANL has one combustion turbine located at the TA-3 power plant. A revised construction permit was issued by NMED July 2004 to add the TA-3 combustion turbine as a new permitted source. This unit started operations in September 2007. Emission calculations are based on the initial stack compliance tests performed in 2007, AP-42, Tables 3.1-2a and 3.1-3, and information provided by the manufacturer. In 2008 this combustion turbine operated for 96 hours.

## **2.11 Emissions from Chemical Use Activities**

The majority of the Laboratory's work is devoted to research and development (R&D) activities. Varying operating parameters, as well as amounts and types of chemicals, are used in these activities. R&D activities occur at virtually all technical areas within the Laboratory, typically in small quantities in laboratory settings. Figure 2.11-1 shows a typical laboratory at LANL where chemicals are used.

For the purposes of annual emissions inventory reporting, one equipment number has been assigned for all R&D chemical use (Act 7). Facility-wide chemical use emissions are reported on both the annual emissions inventory and the semiannual emissions reports. The methods used to quantify emissions of VOC and HAPs from R&D activities are discussed below.





**Figure 2.11-1 Example of a laboratory fume hood at LANL.**

### **2.11.1 VOC Emissions**

The Laboratory tracks chemical purchases through a facility-wide chemical tracking system called ChemLog. A download from the ChemLog inventory system was created that included all chemical containers added to LANL's inventory between January 1, 2008, and December 31, 2008. This dataset included 38,074 separate line items of chemicals purchased.

The dataset was reviewed electronically to identify all VOCs purchased and received at LANL in 2008. With the exception of specific listed chemicals, VOCs are any compounds of carbon that participate in atmospheric photochemical reactions. VOCs include commonly used chemicals such as ethanol, methanol, trichloroethylene, and isopropanol. The general assumption used in estimating VOC emissions from chemical use is

$$\text{Purchasing} = \text{Use} = \text{Emissions}$$

From the dataset of chemicals purchased in 2008, certain categories of chemicals were separated and eliminated from the analysis. The classifications assigned and corresponding reasons (noted in parentheses) for exclusion of chemicals from inventory records are noted below.

- Solid materials (not a significant source of air emissions based on their low vapor pressure);

- Non-VOC materials as defined by 40 CFR 51.100 (specific chemicals in 40 CFR 51.100 are listed as having negligible photochemical reactivity and are exempt from the definition of VOC);
- Paints (paints were evaluated separately—see Section 3.5);
- Inorganic chemicals (inorganics are not compounds of carbon);
- Oils (not a significant source of air emissions based on low vapor pressure and primarily used for maintenance);
- Fuels used for combustion purposes (emissions from fuel combustion are reported for each combustion unit).

Furthermore, the following categories of chemicals were eliminated based on guidance from NMED (letter from Mary Uhl, NMED/AQB, dated January 30, 2001):

- Container sizes of 1 lb or less;
- Chemicals with vapor pressures less than 10 mmHg;
- Chemicals used to calibrate equipment;
- Maintenance chemicals;
- Use of office equipment and products;
- Chemicals used for boiler water treatment operations;
- Chemicals used for oxygen scavenging (deaeration) of water; and
- Chemicals used in bench-scale chemical analysis.\*

After elimination of chemicals and categories of chemicals listed above, the remaining chemical inventory records were matched with a list of known VOCs by CAS number. For mixtures (chemicals without CAS numbers), material safety data sheets (MSDSs) were reviewed to determine if any VOCs were present and, if so, to determine the associated percent volatile. As a conservative estimate, VOCs identified in ChemLog records were assumed to be 100 percent emitted to air. Estimated emissions of VOCs from chemical use in 2008 totaled 9.0 tons.

### **2.11.2 HAP Emissions**

Section 112(b) of the 1990 Clean Air Act Amendments listed 189 unique HAPs identified for potential regulation by EPA. In 1995, caprolactam was delisted as a HAP and methyl ethyl ketone was delisted in 2005. Of the remaining 187 listed HAPs, 17 are classes of compounds (e.g., nickel compounds). Use of the 187 listed chemicals in activities at the Laboratory was evaluated and quantified for the annual emissions inventory submittal to NMED.

The ChemLog inventory system 2008 dataset was analyzed to identify HAPs. The identification process was similar to that used for VOCs. Pure chemicals (i.e., chemicals with CAS numbers), classes of compounds, and mixtures were evaluated to determine if the chemicals themselves were HAPs or if they contained HAP constituents. For mixtures, MSDSs were reviewed to determine if any HAPs were present and, if so, to determine the associated HAP percentages. Listed below are

---

\*This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied (see Table 3.3-1).

certain chemical types or categories that were identified and removed from this analysis (refer to Section 2.11.1 and Table 3.3-1 for explanations on removal of these chemicals):

- Paints;
- Oils;
- Maintenance chemicals;
- Chemicals used to calibrate equipment;
- Container sizes of 1 lb or less;
- Chemicals used in bench-scale chemical analysis;
- Use of office equipment and products;
- Chemicals used for boiler water treatment operations; and
- Chemicals used for oxygen scavenging (deaeration) of water.

Total HAP emissions were estimated by summing 1) pure HAP chemicals, 2) classes of compounds that are HAPs, and 3) the HAP constituents from mixtures. The resulting total amount of HAPs from chemical use reported for 2008 was 4.5 tons.

The HAP emissions reported generally reflect quantities procured in the calendar year. In a few cases procurement values and operational processes were further evaluated so that actual air emissions could be reported instead of procurement quantities. Additional analyses for certain metals and acids were performed and are described below.

### **HAP Metals**

Purchases of beryllium, chromium, lead, manganese, mercury, and nickel compounds were evaluated to determine usage and potential air emissions. Several of the purchases were identified as laboratory calibration standards containing only parts per million quantities of the metals. These were exempt from emissions inventory requirements because of their use as standards for calibrating laboratory equipment. Other purchasers of relatively large quantities of metal compounds that were contacted confirmed that the material was still in use or in storage and had not resulted in air emissions.

### **Hydrochloric Acid**

In 2008, the largest purchases of hydrochloric acid (HCl) were made by a variety of operating groups within the Chemistry Division. The major users of HCl primarily purchased it in 2.5- or 4-liter bottles of concentrated acid. This HCl was primarily used for cleaning labware and for certain analytical processes. The remaining procurements consisted of numerous small purchases from a variety of operating groups. Additional analysis of these numerous small purchases was not done. As a conservative assumption, all of this HCl was assumed to be emitted resulting in a reported total of 1.0 tons of HCl emissions.

## **2.12 Emissions Summary by Source**

Table 2.12-1 provides a summary of LANL's 2008 actual emissions, as submitted for the annual emissions inventory. The table presents emissions by pollutant and by source, with a facility total at the bottom of the table. Attachment A provides detailed information on how emissions were calculated for each emission unit.

**Table 2.12-1**  
**Summary of LANL 2008 Reported Emissions for Annual Emissions Inventory**

	NO <sub>x</sub> (tons/yr)	SO <sub>x</sub> (tons/yr)	PM <sub>10</sub> (tons/yr)	PM <sub>2.5</sub> (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)	CO <sub>2</sub> (metric tons/yr)
TA-3 Power Plant Boilers	14.07	0.15	1.85	1.85	9.7	1.34	0.46	27001.60
Non-Exempt Boilers	5.45	0.03	0.50	0.50	3.77	0.32	0.11	6310.50
Asphalt Plant	0.03	0.01	0.01	0.01	0.43	0.01	0.01	146.20
Data Disintegrator	n/a*	n/a	0.28	0.19	n/a	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.02	0.02	n/a
Carpenter Shops	n/a	n/a	0.02	0.02	n/a	n/a	n/a	n/a
Oil Storage Tanks	n/a	n/a	n/a	n/a	n/a	0.01	n/a	n/a
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	9.00	4.50	n/a
TA-33 Generators	0.80	0.10	0.04	n/a	0.50	0.03	2.01E-04	46.60
TA-3 Turbine	0.43	0.03	0.06	0.06	0.09	0.02	0.01	942.50
Exempt Boilers (GHG** only)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	22,445.10
Stationary Standby Generators (GHG only)	n/a	n/a	n/a	n/a	n/a	n/a	n/a	214.4
<b>TOTAL</b>	<b>20.78</b>	<b>0.32</b>	<b>2.76</b>	<b>2.63</b>	<b>14.49</b>	<b>10.75</b>	<b>5.1</b>	<b>57,106.90</b>

\* n/a = Not Applicable. \*\* GHG = greenhouse gas

Table 2.12-2 provides a summary of 2008 emissions as reported on the semiannual emissions reports required by the Title V Operating Permit. Attachment A provides detailed information on how emissions were calculated for each emission source category.

**Table 2.12-2**  
**Summary of LANL 2008 Semiannual Emissions as Reported Under  
Title V Operating Permit Requirements**

	NO <sub>x</sub> (tons/yr)	SO <sub>x</sub> (tons/yr)	PM <sub>10</sub> (tons/yr)	PM <sub>2.5</sub> (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)
TA-3 Power Plant Boilers	14.07	0.15	1.85	1.85	9.7	1.34	0.46
All Small Boilers & Heaters	25.58	0.16	2.03	2.03	20.69	1.42	0.49
Asphalt Plant	0.03	0.01	0.01	0.01	0.43	0.01	0.01
Data Disintegrator	n/a*	n/a	0.28	0.19	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.02	0.02
Carpenter Shops	n/a	n/a	0.02	0.02	n/a	n/a	n/a
Oil Storage Tanks**	n/a	n/a	n/a	n/a	n/a	0.01	n/a
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	9.0	4.5
Stationary Standby Generators	4.97	0.17	0.21	0.21	1.12	0.22	1.45 E-3
TA-33 Generators	0.80	0.10	0.04	n/a	0.50	0.03	2.01E-04
TA-3 Turbine	0.43	0.03	0.06	0.06	0.09	0.02	0.01
<b>TOTAL</b>	<b>45.88</b>	<b>0.62</b>	<b>4.50</b>	<b>4.37</b>	<b>32.53</b>	<b>12.07</b>	<b>5.49</b>

\* n/a = Not Applicable. \*\* Source category not included in Title V Operating Permit.

### 3.0 REPORTING EXEMPTIONS

Specific activities that are determined to be insignificant under NMED's Operating Permit program (20.2.70 NMAC) are exempt from reporting under the emissions inventory requirements (20.2.73.300 NMAC). NMED has designated exempt sources, activities, or thresholds in the following lists:

- List of Insignificant Activities, March 25, 2005 (NMED 2005) and
- List of Trivial Activities, January 10, 1996 (NMED 1996).

Laboratory sources and activities that qualify as insignificant or trivial as specified in these lists are not included in the annual emissions inventory. The following subsections of this report provide information and examples of the Laboratory's exempt activities as well as analyses performed to determine exempt status.

#### 3.1 Boilers

The Laboratory's boiler inventory was evaluated against the List of Insignificant Activities (NMED 2005). Specifically, boilers were exempted from emissions inventory reporting requirements if they met one of the following requirements:

- Fuel-burning equipment which uses gaseous fuel, has a design rate less than or equal to five million BTU per hour, and is used solely for heating buildings for personal comfort or for producing hot water for personal use, or
- Any emissions unit . . . that has the potential to emit no more than **one ton per year** of any regulated pollutant . . . .

Any boiler that was not used exclusively for comfort heating or hot water was evaluated for the one ton per year exemption. For purposes of determining exemptions, boiler design ratings were used to estimate potential to emit. Any boiler not qualifying for one of these two exemptions is included in the annual emissions inventory with its own unique equipment number.

Although these exempt boilers are not required on the Emissions Inventory report, they are required for the Greenhouse Gas Emissions reporting. Per NMED request, direct CO<sub>2</sub> emissions from stationary combustion sources in tons per year are being reported for the first time in 2008. This satisfies LANL's reporting requirement under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.

For the semiannual emissions reports, emissions from all boilers and heaters were summed and reported for the entire source category.

#### 3.2 Generators

The Laboratory maintains an inventory of approximately 135 portable generators. Portable generators are used at the Laboratory for temporary operations requiring remote power or to provide emergency backup power during power outages at various sites. The portable generators are fueled by gasoline and/or diesel fuel.

In addition to portable generators, the Laboratory maintains and operates approximately 45 stationary standby generators. Stationary generators are used on standby (emergency) status to provide power to critical systems at the Laboratory during power outages. The stationary generators are fueled by natural gas, propane, gasoline, or diesel.

The insignificant activity exemptions applicable to the Laboratory's generators are the following:

- Portable engines and portable turbines that have a design capacity . . . less than or equal to
  - 200-horsepower engine if fueled by diesel or natural gas, and
  - 500-horsepower engine if fueled by gasoline.
- Emergency generators which on a temporary basis replace equipment used in normal operation, and which either have an allowable emission rate or potential to emit for each pollutant that is equal to or less than the equipment replaced, or which do not operate for a period exceeding 500 hours per calendar year.

On the basis of size, portable generators used for temporary power at remote locations are exempt from emissions inventory reporting requirements. Further, LANL's small portable generators are considered trivial activities and are not included in the Title V Operating Permit or semiannual emissions reports. All stationary generators are designated as standby equipment under the Operating Permit Program and are used solely to provide emergency backup power for less than 500 hours per year. Therefore, they are considered insignificant sources and are also exempt from annual emissions inventory reporting requirements. However, the stationary standby generators were voluntarily included as a source category in the Title V Operating Permit and are included in the semiannual emissions reports.

Direct CO<sub>2</sub> emissions from stationary combustion sources are being reported for the first time in 2008. Therefore, generators that are exempt for the Emissions Inventory report are now being declared in the Greenhouse Gas Emissions report, as required by 20.2.87 NMAC, Greenhouse Gas Emissions Reporting

### **3.3 VOC Emissions**

A number of insignificant and trivial activities were applicable for exempting materials from the VOC chemical use total in the emissions inventory. The basis of the exemptions and corresponding insignificant or trivial activities are explained in Table 3.3-1.

Fuels such as propane, kerosene, and acetylene were analyzed separately and are not listed in Table 3.3-1. When fuels are burned in an open flame, almost all of the fuels are consumed and VOC emissions are minimal. Emissions from fuel combustion are accounted for using emission factors for each fuel-burning unit.

**Table 3.3-1  
Exemptions Applied for Chemical Use Activities**

Basis of Exemption	Activity Type	Activity
Container sizes of 1 pound or less	Trivial	Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16-oz. capacity or less.
Chemicals with vapor pressures less than 10 mmHg	Insignificant	Any emissions unit, operation, or activity that handles or stores a liquid with vapor pressure less than 10 mmHg or in quantities less than 500 gal.
Calibration chemicals	Trivial	Routine calibration and maintenance of laboratory equipment or other analytical instruments, including gases used as part of those processes.
Maintenance chemicals and oils	Trivial	Activities that occur strictly for maintenance of grounds or buildings, including lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas.  Activities for maintenance and repair of equipment, pollution-control equipment, or motor vehicles either inside or outside of a building.
Use of office equipment and products	Trivial	Use of office equipment and products, not including printers or businesses primarily involved in photographic reproduction.
Chemicals used for boiler water treatment	Trivial	Boiler water treatment operations, not including cooling towers.
Chemicals used for oxygen scavenging	Trivial	Oxygen scavenging (deaeration of water).
Chemicals used in bench-scale chemical analysis	Trivial	Bench-scale laboratory equipment used for physical or chemical analysis but not lab fume hoods or vents. <i>Note: This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied.</i>

### 3.4 HAP Emissions

The HAP chemical use exemption analysis, similar to the VOC chemical use exemption analysis, resulted in application of several of the same exemptions from NMED/AQB List of Insignificant Activities (NMED 2005) and List of Trivial Activities (NMED 1996) (refer to Table 3.3-1).

### 3.5 Paints

An analysis of VOC and HAP emissions resulting from painting activities at the Laboratory was performed to determine if certain exemptions apply. Paint information for 2008 was gathered from the ChemLog chemical inventory system. These records were evaluated for applicability of exemptions for trivial and insignificant activities.

The following exemptions from NMED/AQB Operating Permit Program List of Trivial Activities (NMED 1996) were used in the paint analysis:

- Activities that occur strictly for maintenance of grounds or buildings, including the following: lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas.
- Activities for maintenance and repair of equipment, pollution control equipment, or motor vehicles either inside or outside of a building.

- Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16 oz. or less capacity.

The corresponding amounts of paint were totaled for painting activities that did not qualify for one of the trivial activity exemptions listed above. The paint total for 2008 was determined to be 2,778 pounds (1.4 tons), which further qualified for the following insignificant activity:

- Surface coating of equipment, including spray painting and roll coating, for sources with facility-wide total cleanup solvent and coating actual emissions of less than two tons per year.
- All emissions from paints and painting activities were exempt as insignificant or trivial activities and therefore were not included in the 2008 emissions inventory.

## 4.0 EMISSIONS SUMMARY

### 4.1 2008 Emissions Summary

Table 4.1-1 presents facility-wide estimated actual emissions of criteria pollutants for 2008 as reported in the annual emissions inventory and the semiannual emissions reports. In addition, the Title V Operating Permit emissions limits are included. Table 4.1-2 presents estimated actual emissions for HAPs from chemical use. Emission unit information and detailed emissions calculations are included in Attachment A. The 2008 emissions inventory report as submitted to NMED is presented in Attachment B. Attachment C includes semiannual emissions reports for 2008.

**Table 4.1-1  
LANL Facility-Wide Criteria Pollutant Emissions for 2008**

Pollutant	Estimated actual Emissions for Annual Emissions Reporting (tons/yr)	Estimated actual Emissions for Semiannual Title V Operating Permit Reporting (tons/yr)	Title V Operating Permit Facility-Wide Emission Limits (tons/yr)
NO <sub>x</sub>	20.78	45.88	245
SO <sub>x</sub>	0.32	0.62	150
CO	14.49	32.53	225
PM	2.76	4.50	120
PM <sub>10</sub>	2.76	4.50	120
PM <sub>2.5</sub>	2.63	4.37	—*
VOC	10.75	12.07	200
CO <sub>2</sub>	57,107.90	n/a	—**

\*No Title V Operating Permit facility-wide emission limits on PM<sub>2.5</sub>.\*\*No greenhouse gas emission limit and CO<sub>2</sub> values are in metric tonnes per year.




**Table 4.1-2  
LANL HAP Emissions from Top Five Chemicals Used in 2008**

Pollutant	Chemical Use HAP Emissions* (tons/yr)
<b>Top 5 HAPs</b>	
HCl	1.0
Methylene Chloride	0.62
Hexane	0.58
Methanol	0.53
Trichloroethylene	0.35
All other HAPs from Chemical Use	1.42
<b>Total HAPs</b>	<b>3.08</b>

\*HAP emissions from combustion sources are included in the emissions reports, however, they are negligible and do not contribute significantly to facility-wide HAP emissions.

HAP emissions from combustion sources are included in the emissions reports, however, they are negligible and do not contribute significantly to facility-wide HAP emissions.

Figure 4.1-1 shows criteria air pollutant emissions by source for 2008, excluding the very small emissions sources such as the data disintegrator, asphalt plant, degreasers, and carpenter shop. As the figure shows, the TA-3 power plant and the sum of emissions from all small boilers and heaters were the largest sources of CO and NO<sub>x</sub> emissions in 2008. R&D chemical use was the largest source of VOC emissions.



**Figure 4.1-1 Emissions of criteria pollutants by source in 2008.**

## 4.2 Emission Trends and Title V Permit Limits

A comparison of historical emissions to the facility-wide emission limits in the Title V Operating Permit is provided in this section. It should be noted that the facility-wide emission limits in the Operating Permit include emissions from some sources that are not included in the annual emissions inventory, most notably small (insignificant) boilers and emergency standby generators. However, historical data are only available for emission sources that were included in the annual emissions inventory submittals.

Figure 4.1-2 provides a comparison of the past 10 years' facility-wide emissions for criteria air pollutants as reported to NMED on the annual emissions inventory submittal. The facility-wide emission limits included in LANL's Title V Operating Permit are also shown on the graph.




Figure 4.1-2 Comparison of facility-wide annual reported emissions from 1999–2008.

Figure 4.1-3 presents VOC and HAP emissions from chemical use activities for the last 10 years. The continued fluctuation in both VOC and HAP emissions is due to both variations in actual chemical purchases and improvements the Laboratory has made to the chemical tracking system.




Figure 4.1-3 VOC and HAP emissions from chemical use, 1999–2008.

## REFERENCES

- EPA (U.S. Environmental Protection Agency), 2008a. "Aerometric Information Retrieval System (AIRS)," <http://www.epa.gov/enviro/html/airs/> (Accessed January 2008).
- EPA (U.S. Environmental Protection Agency), 2008b. "TANKS Emission Estimation Software," <http://www.epa.gov/ttn/chief/software/tanks/> (Accessed January 2008).
- EPA (U.S. Environmental Protection Agency), 1998. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 1.4–Natural Gas Combustion, July 1998, and Section 1.3–Fuel Oil Combustion, <http://www.epa.gov/ttn/chief/ap42/> (September 1998).
- EPA (U.S. Environmental Protection Agency), 1996. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 3.3–Gasoline and Diesel Industrial Engines, and Section 3.4–Large Stationary Diesel and All Stationary Dual-Fuel Engines, <http://www.epa.gov/ttn/chief/ap42/> (October 1996).
- LANL (Los Alamos National Laboratory), 2009a. "2008 Emissions Inventory Report Submittal to the New Mexico Environment Department," LA-UR-09-02567 (April 2009).
- LANL (Los Alamos National Laboratory), 2009b. "Semi-Annual Emissions Report, July–December 2008," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-09-01479 (March 2009).
- LANL (Los Alamos National Laboratory), 2008. "Semi-Annual Emissions Report, January–June 2008," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-08-05553 (September 2008).
- NMED (New Mexico Environment Department, Air Quality Bureau), 2007. "Clean Air Act, Title V Operating Permit No. P-100M2" (July 2007).
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 2005. "List of Insignificant Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/InsignificantListTitleV.pdf> (March 2005).
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 1996. "List of Trivial Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/TrivialListTitleV.pdf> (January 1996).

# **Attachment A**

*Emission Calculation Worksheets  
for Individual Emission Units*



**2008 TA-60 BDM Asphalt Plant**

Data Reviewed By / Date:

Month	Data Entry Asphalt Produced (Tons)	12-Month Rolling Total	Month	Data Entry Asphalt Produced (Tons)	12-Month Rolling Total
January	86	1775	July	79	2134
February	76	1762	August	275	2334
March	223	1823	September	191	2011
April	227	1920	October	218	1951
May	243	2044	November	277	2143
June	196	2107	December	62	2153
<b>6 mo. Total</b>	<b>1,051</b>		<b>6 mo. Total:</b>	<b>1,102</b>	

**12-Month Rolling Permit Limit is 13,000 Tons**

Annual Total: **177.5**  
**Hours are Limited to 4380 per Year.**

Month	Annual Hour	
	Hours	Month
Jan	10	Jul
Feb	9.5	Aug
Mar	26.1	Sep
Apr	17.7	Oct
May	23.9	Nov
Jun	18.9	Dec
<b>Total:</b>	<b>106.1</b>	<b>Total:</b>

Annual Total: **177.5**

**Hours are Limited to 4380 per Year.**

**Emission Calculations**

**Tons/Asphalt Produced: 2,153**

Pollutant	Emission Factor (lb/ton)	Annual Emissions (tons)	Emissions (tons) Jan-June	Emissions (tons) July-Dec	Reference
NOx	0.025	0.027	0.013	0.014	(a)
SOx	0.0046	0.005	0.002	0.003	(a)
PM	0.0096	0.010	0.005	0.005	(b)
PM-10	0.006	0.006	0.003	0.003	(c)
PM-2.5	0.006	0.006	0.003	0.003	(c)
CO	0.4	0.431	0.210	0.220	(a)
VOC	0.0082	0.009	0.004	0.005	(a)
HAPs					
Acetaldehyde	0.00032	0.000	0.000	0.000	(d)
Benzene	0.00028	0.000	0.000	0.000	(d)
Ethylbenzene	0.0022	0.002	0.001	0.001	(d)
Formaldehyde	0.00074	0.001	0.000	0.000	(d)
Napthalene	0.000036	0.000	0.000	0.000	(d)
POM	0.00011	0.000	0.000	0.000	(d)
Quinone	0.00027	0.000	0.000	0.000	(d)
Toluene	0.001	0.001	0.001	0.001	(d)
Xylene	0.0027	0.003	0.001	0.001	(d)
<b>TOTAL HAPS</b>		<b>0.008</b>	<b>0.004</b>	<b>0.004</b>	
<b>EPCRA 313</b>		<b>tons</b>	<b>lbs./year</b>		
Lead	8.90E-07	9.58E-07	0.0019		(e)
Sulfuric Acid	0.0046	4.95E-03	9.90		(f)
Mercury	4.10E-07	4.41E-07	0.0009		(e)
PACs	2.70E-08	2.91E-08	5.81E-05		(d)
Benzo(g,h,i) perylene	5.00E-10	5.38E-10	1.08E-06		(g)

Reference
(a) AP-42, Sec 11.1, Hot Mix Asphalt Plants, Table 11.1-5 & 11.1-6, Updated 4/2004
(b) Calculated using AP-42 uncontrolled emission factor and applying manufacturer's suggested control efficiencies for cyclone & baghouse.
(c) PM-10 emission factor is calculated as 64% of the PM emission factor, using the same ratio of PM to PM-10 as provided in AP-42, Table 11.1-1. No data provided for PM-2.5, assume same as PM-10.
(d) AP-42, Table 11.1-9, Hot Mix Asphalt Plants, Updated 4/2004
(e) AP-42, Table 11.1-11, Hot Mix Asphalt Plants, Updated 4/2004
(f) Assume all SOx is converted to sulfuric acid
(g) EPCRA PAC Guidance Document, EPA-260-B-01-03, June 2001, Table 2-3

## Carpenter Shop Emissions Calculations for 2008

<b>ANNUAL EMISSIONS</b>			
Operation Parameters	TSP Prior to Cyclone	TSP Post Cyclone	PM Post Cyclone Emissions (tons/year)
Exhaust Flow (ft <sup>3</sup> /min)	Hours of <sup>(b)</sup> Operation (hr/yr)	(tons/year)	(PM) (PM > 40µm) (PM 5-20 µm) (PM <2.5 µm)
2706	50	0.048	0.001 0.008 0.008
2100	110	0.081	0.002 0.014 0.013
<b>January through June Emissions</b>			
Operation Parameters	TSP Prior to Cyclone	TSP Post Cyclone	PM Post Cyclone Emissions (tons)
Exhaust Flow (ft <sup>3</sup> /min)	Hours of <sup>(b)</sup> Operation (hr/period)	tons	(PM) (PM > 40µm) (PM 5-20 µm) (PM <2.5 µm)
2706	17	0.016	0.000 0.003 0.003
2100	52	0.038	0.001 0.007 0.006
<b>July through December Emissions</b>			
Operation Parameters	TSP Prior to Cyclone	TSP Post Cyclone	PM Post Cyclone Emissions (tons)
Exhaust <sup>(1)</sup> Flow (ft <sup>3</sup> /min)	Hours of <sup>(b)</sup> Operation (hr/period)	tons	(PM) (PM > 40µm) (PM 5-20 µm) (PM <2.5 µm)
2706	33	0.032	0.001 0.006 0.005
2100	58	0.043	0.001 0.008 0.007

**Conversions:**

lb/ton	lb/grain	min/hr	ton/lb
2000	0.00014	60	0.0005

**Assumptions:**

PM < 2.5 PM 5-20 microns PM > 40 microns	Cyclone <sup>(4)</sup> Efficiencies	% PM in Wood Dust Prior <sup>(6)</sup> to Cyclone	Flow Rate
	0.45	0.30	5000 cfm
	0.65	0.50	5471 cfm
	0.95	0.50	

**Post Cyclone Emission Factor:**

grain/ft <sup>3</sup> <sup>(2)</sup>	Shop Location
0.03	TA-3-38
	TA-15-563

**Maximum permitted exhaust flow rate is:** TA-3-38 5000 cfm  
TA-15-563 5471 cfm

**Allowable Emission Limits are:** 3.07 tpy of PM10 for the TA-3-38 shop  
2.81 tpy of PM10 for the TA-15-563 shop

**References:**

- 1.) Exhaust Rate calculated by Victor Martinez.
- 2.) Emission Factor obtained from AP-42, Section 10.4 Woodworking Waste Collection Operations, post cyclone emissions, Table 10.4.1, February 1980.
- 3.) Based on information provided monthly by the shop foreman.
- 4.) K. Wark & C.F. Warner, Air Pollution - Its Origin and Control, Table 5-9, pg 186 (1976).
- 5.) Emissions Inventory Improvement Program (EIP) Uncontrolled Emission Factor Listing for Criteria Air Pollutants, Volume II: Chapter 14, July 2001 And AP-42 Appendix B, Section 10.5 Woodworking Waste Collection Operations: Belt Sander Hood Exhaust Cyclone.

Reviewed By/Date: \_\_\_\_\_



**2008 TA-3 & TA-15 Carpenter Shops**

TA-3	Data Entry		TA-3	Data Entry
	Hours of Operation <sup>1</sup>	TA-3		
Month			Month	
January	1.7	1.1	July	1.9
February	1.0	3.3	August	1.1
March	1.1	6.0	September	17.4
April	3.3	3.7	October	4.8
May	6.0	16.8	November	6.4
June	3.7		December	1.7
<b>6 mo. Total</b>			<b>6 mo. Total:</b>	<b>33.3</b>

TA-15	Data Entry		TA-15	Data Entry
	Hours of Operation <sup>1</sup>	TA-15		
Month			Month	
January	7.6	8.3	July	12.4
February	9.8	14.4	August	14.5
March	8.3	5.2	September	9.4
April	14.4	6.4	October	8.6
May	5.2	51.7	November	7.1
June	6.4		December	6.4
<b>6 mo. Total</b>			<b>6 mo. Total:</b>	<b>58.4</b>

Saws, drills, shaping and sanding equipment shall each not operate in excess of 4368 hours per year.

Reference
1. Based on information provided monthly by the shop foreman from each shop.

Reviewed By/Date: \_\_\_\_\_

**2008 IA-52 Data Disintegrator**

Reviewed By / Date:

Data Entry		Data Entry
Month	Boxes <sup>(c)</sup> Shredded	Boxes <sup>(c)</sup> Shredded
January	876	810
February	761	1329
March	840	132
April	657	382
May	837	131
June	567	60
<b>6 mo. Total:</b>	<b>4,538</b>	<b>2,844</b>

<b>Annual Boxes:</b>	<b>7,382</b>
----------------------	--------------

**Emission Calculations**

	Emission <sup>(b)</sup> Factor	% in Exhaust <sup>(e)</sup>	Control <sup>(d)</sup> Efficiency (Cyclone)	Control <sup>(d)</sup> Efficiency (Baghouse)
PM 2.5	15%	15%	0%	95.0%
PM 10	15%	90%	75%	95.0%
TSP	15%	100%	75%	95.0%

<b>Average Box Weight<sup>(a)</sup></b>	<b>45</b>
	Pounds

	Amount Processed (pounds)	PM-2.5 Emissions (pounds)	PM-2.5 Emissions (tons)	PM-10 Emissions (pounds)	PM-10 Emissions (tons)	TSP Emissions (pounds)	TSP Emissions (tons)
Annual	332,190	373.7	0.19	560.6	0.28	622.9	0.31
January - June	204,210	229.7	0.11	344.6	0.17	382.9	0.19
July - December	127,980	144.0	0.07	216.0	0.11	240.0	0.12

Reference	(a)	(b)	(c)	(d)	(e)
Estimated maximum box weight is 45 pounds. Information provided by shredding operations. Full box weight of tightly packed paper.	Emission Factor (percentage of material shredded that will enter into the exhaust) obtained from the manufacturer of the air handling system, AGET Manufacturing Co. 15% is also listed in the construction permit application.	Information provided by the shredding operations personnel.	Information on control equipment efficiencies was provided by the manufacturer (SEM) of the Data Disintegrator. Those values not given were extrapolated using manufacturer data. Efficiencies of 75% for the Cyclone and 95% for the bag house are listed in the construction permit application. (see cyclone efficiency tab for more info.)	Information on control equipment efficiencies was provided by the manufacturer (SEM) of the Data Disintegrator. Those values not given were extrapolated using manufacturer data. Efficiencies of 75% for the Cyclone and 95% for the bag house are listed in the construction permit application. (see cyclone efficiency tab for more info.)	Manufacturer provided info that the dust into the exhaust would be in the size range of 5-20 um. Conservative assumption that 15% is PM2.5, and 90% is PM10.

**Maximum Annual emission rate is: 9.9 tpy or 2.3 lb/hr of Total Suspended Particulate (TSP) per year. 9.9 tpy or 2.3 lb/hr of Particulate Matter <10um (PM-10) per year.**

Permitted Generators													
TA Bldg	Manufacturer	Serial #	MODEL	KW	Fuel Type	Reading 2nd half of previous year.	First Half 2008			Second Half 2008			* Total Run Hours
							6 Month Reading Date	Hours Run	Reading	12 Month Reading Date	Hours Run	Reading	
33 290	Kohler	375801	160ROZD	1600	Diesel	Dec. 07 9.3	Jun-08 25.9	16.6	Dec-08 34.3	8.4	25.0		
33 151	Caterpillar	6PK01065	XO225	225	Diesel	Jan. 08 3253.0	Jun-08 3253.0	0.0	Dec-08 3307.0	54	54.0		
33 209	Kohler	2025460	20EORZ	20	Diesel	Dec. 07 393.5	Jun-08 393.5	0.0	Dec-08 394.1	0.6	0.6		
33 114	Kohler	2025461	20EORZ	20	Diesel	Dec. 07 155.2	Jun-08 175.0	19.8	Dec-08 175.9	0.9	20.7		

\* The 225 kW and the two 20 kW generators have a limit of 500 hours of operation per year. The 1600 kW unit is limited to 900 hours per year.

Permit ID	Unit	First 6 Month Emissions of 2008					Second 6 Month Emissions of 2008						
		NOx (lbs)	CO (lbs)	SOx (lbs)	PM (lbs)	VOC (lbs)	HAPs (lbs)	NOx (lbs)	CO (lbs)	SOx (lbs)	PM (lbs)	VOC (lbs)	HAPs (lbs)
TA-33-G-1	33-290	717.1	584.3	106.2	23.9	13.3	1.5E-01	362.9	295.7	53.8	12.1	6.7	7.8E-02
TA-33-G-4	33-151	0.0	0.0	0.0	0.0	0.0	0.0E+00	510.3	109.4	36.5	36.5	36.5	1.8E-01
TA-33-G-2	33-209	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.5	0.1	0.0	0.0	0.0	1.8E-04
TA-33-G-3	33-114	16.6	3.6	1.2	1.2	1.2	5.4E-03	0.8	0.2	0.1	0.1	0.1	2.4E-04
Permit ID	Unit	NOx (tons)	CO (tons)	SOx (tons)	PM (tons)	VOC (tons)	HAPs (tons)	NOx (tons)	CO (tons)	SOx (tons)	PM (tons)	VOC (tons)	HAPs (tons)
TA-33-G-1	33-290	0.359	0.292	0.053	0.012	0.007	7.73E-05	0.181	0.148	0.027	0.006	0.003	3.91E-05
TA-33-G-4	33-151	0.000	0.000	0.000	0.000	0.000	0.00E+00	0.255	0.055	0.018	0.018	0.018	8.21E-05
TA-33-G-2	33-209	0.000	0.000	0.000	0.000	0.000	0.00E+00	0.000	0.000	0.000	0.000	0.000	8.11E-08
TA-33-G-3	33-114	0.008	0.002	0.001	0.001	0.001	2.88E-06	0.000	0.000	0.000	0.000	0.000	1.22E-07

TOTAL				
Pollutant	NOx	CO	SOx	HAPs
Tons/Year	0.80	0.50	0.10	2.01E-04

Reviewed by / Date:

	NOx	CO	SOx	PM	PM <sub>10</sub>	VOC
EMISSION FACTORS	lb/kw-hr	lb/kw-hr	lb/kw-hr	lb/kw-hr	lb/kw-hr	lb/kw-hr
1600kw Generator <sup>(a)</sup>	0.027	0.022	0.004	0.0009	0.0009	0.0005
Small Diesel fired <sup>(b)</sup>	0.042	0.009	0.003	0.003	0.003	0.003

References:

- 447 kw is the size limit for determining large vs. small diesel fired generator. This information was taken from the operating permit application.
- (a) Manufacturer supplied emission factors for NOx, CO, and VOCs. Emission factors for SOx, PM, and PM<sub>10</sub> from AP-42, Table 3.3-1 & Table 3.4-1. The AP-42 (fifth edition) emissions factor uses units of lb/tp-hr. There are 1,341 hp-hrs in a kwh. Therefore, take pounds/tp-hr x 1.341 hp-hr/kwh to obtain the emission factor in lb/kwh.
- (b) Emission factors for small diesel fired boilers were taken from AP-42 (fifth edition) Tables 3.3-1 and 3.3-2.

Need to verify both a & b

TA-33-G-1  
 (1600 kW Generator, 1500 kW Derated for Altitude)  
 12-Month Rolling kilowatt-hours

Month	Hour Meter Reading	Hours Operated	Rolling Total kw-hr	Month	Hour Meter Reading	Hours Operated	Rolling Total kw-hr
January	9.3	0.0	0	July	27.0	1.1	26550
February	9.3	0.0	0	August	31.1	4.1	32700
March	9.3	0.0	0	September	33.4	2.3	36150
April	20.1	10.8	16200	October			
May	25.4	5.3	24150	November			
June	25.9	0.5	24900	December			

Generator is limited to 1,350,000 kWh/year

Emission Factors (lb/kwh)	HAPS (lbs)										Individual Generator HAP Emissions (lbs)	
	Benzene	Toluene	Xylenes	1,2-Ethadiene	Formaldehyde	Acetaldehyde	Acrolein	Naphthalene	PAH			
Diesel (small)	3.19E-06	1.40E-06	9.73E-07	1.34E-07	4.03E-06	2.62E-06	3.16E-07	2.90E-07	5.74E-07			
Diesel (large)	2.65E-06	9.60E-07	6.59E-07		2.69E-07	8.61E-08	2.68E-08	4.44E-07	7.24E-07			
Location	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half
33-290	7.04E-02	3.56E-02	1.75E-02	8.88E-03	7.16E-03	3.62E-03	7.15E-04	3.62E-04	5.97E-03	1.92E-02	1.55E-01	7.62E-02
33-151	0.00E+00	3.87E-02	0.00E+00	1.18E-02	0.00E+00	4.90E-02	0.00E+00	3.94E-03	0.00E+00	3.52E-03	0.00E+00	6.97E-03
33-209	0.00E+00	3.82E-05	0.00E+00	1.17E-05	0.00E+00	4.84E-05	0.00E+00	3.78E-06	0.00E+00	3.48E-06	0.00E+00	6.89E-06
33-114	1.20E-03	5.74E-05	3.85E-04	1.75E-05	1.60E-03	7.25E-05	1.25E-04	5.69E-06	1.15E-04	5.21E-06	2.27E-04	1.03E-05
Total Emissions (lbs)	7.17E-02	2.60E-02	1.78E-02	5.29E-05	8.75E-03	5.27E-02	8.40E-04	4.21E-03	1.19E-02	9.49E-03	1.96E-02	1.67E-02
Tons/year/HAP	3.88E-06	3.72E-05	1.30E-05	2.64E-08	4.38E-06	2.64E-06	4.20E-07	2.10E-06	5.95E-06	4.75E-06	9.73E-06	8.36E-06
Tons/year/HAP	7.30E-05	2.80E-05	1.93E-05	8.40E-07	3.07E-05	1.82E-05	2.62E-06	1.07E-05	1.81E-05			
Tons/year/Total	2.01E-04											

Emission Factors from AP-42, Volume 1, Fifth Edition (Small Diesel Engines Table 3.3-2, Large Diesel Engines Table 3.4-4, Natural Gas 4-Stroke Engines Table 3.2-3)

**2008 Small Boilers Data Entry / Gas Use**

Month	Metered Boilers			Total Gas Use <sup>(a)</sup>		Non-Metered Gas Use (MMSCF)	12-Month Rolling Total for all Small Boilers (MMSCF) <sup>(e)</sup>
	TA-55 Boiler Gas Use (MSCF) <sup>(c)</sup>	TA-50-2 <sup>(d)</sup> (MSCF)	BS-1	(MSCF)	(MMSCF)		
	BHW-7B (B-602)	BHW-2B (B-603)					
January	3441	2		84,295	84.30	80.65	504.57
February	2075	8		65,798	65.80	63.52	504.27
March	1786	2		58,027	58.03	56.04	507.94
April	1175	951		40,942	40.94	38.62	504.67
May	528	989		28,334	28.33	26.62	503.54
June	0	1210	1192.4	17,402	17.40	15.99	507.41
July	1	1312		14,028	14.03	12.62	507.75
August	35	912		15,039	15.04	14.00	514.00
September	644	763		21,266	21.27	19.76	515.57
October	552	1055		37,850	37.85	36.15	516.91
November	1633	10		58,166	58.17	56.43	520.86
December	3140	2	578.1	74,982	74.98	71.74	516.13
<b>TOTAL</b>	<b>15010</b>	<b>7216</b>	<b>1770.5</b>	<b>516,129</b>	<b>516.13</b>	<b>492.13</b>	<b>Permit Limit: 870</b>

2008 Non Metered Boiler Pool Capacity: **305.1** MMBTU/hr<sup>(b)</sup>

Estimated Gas-Use per MMBtu rating Jan-June: 0.92 MMsfc/MMBtu/hr

Estimated Gas-Use per MMBtu rating July-Dec: 0.69 MMsfc/MMBtu/hr

Estimated Gas-Use per MMBtu - Annual: 1.61 MMsfc/MMBtu/hr

**Definitions:**

MMSCF= Million Standard Cubic Feet  
 MSCF = Thousand Standard Cubic Feet

Metered/Non-metered: Metered boilers are those units that have unit specific volumetric flow meters for the boiler(s) only.

Gas Use Non-Metered <sup>(g)</sup> (MMSCF)									
AIRS Stack #	015	016	017	018	019	020	021	024	Units <sup>(h)</sup>
<b>Location:</b>	TA-48-1	TA-48-1	TA-48-1	TA-53-365	TA-53-365	TA-59-1	TA-59-1	TA-16-1484	Lab Wide
<b>ID:</b>	BS-1	BS-2	BS-6	BHW-1	BHW-2	BHW-1	BHW-2	Plant 5	Various
<b>Design Rate<sup>(i)</sup> (MMBTU/hr)</b>	<b>5,336</b>	<b>5,335</b>	<b>7,140</b>	<b>7,115</b>	<b>7,115</b>	<b>5,335</b>	<b>5,335</b>	<b>12,700</b>	<b>250</b>
Calculated Gas Use-Jan-June	4,922	4,922	6,586	6,563	6,563	4,922	4,922	11,715	230,324
Calculated Gas Use-July-Dec	3,685	3,685	4,931	4,913	4,913	3,685	3,685	8,770	172,428
Calculated Gas Use-Annual	8,608	8,606	11,517	11,476	11,476	8,606	8,606	20,485	402,752

Reviewed By / Date: \_\_\_\_\_

Emission Factors (lb/MMscf)			
Criteria Pollutant	Small Uncontrolled	TA-16 Low NOx	TA-55-6 Boilers <sup>3</sup>
NOx	100	37.08	138
SOx	0.6	0.6	0.6
PM <sup>2</sup>	7.6	7.6	14.2
PM-10 <sup>2</sup>	7.6	7.6	14.2
PM-2.5 <sup>2</sup>	7.6	7.6	14.2
CO	84	37.08	38.2
VOC	5.5	5.5	5.98
<b>HAPs<sup>5</sup></b>			
Arsenic	0.0002		
Benzene	0.0021		
BE	0.000012		
Cadmium	0.0011		
Chromium	0.0014		
Cobalt	0.000084		
Dichlorobenzene	0.0012		
Formaldehyde	0.075		
Hexane	1.8		
Lead	0.0005		
Manganese	0.00038		
Mercury	0.00026		
Napthalene	0.00061		
Nickel	0.0021		
POM	0.000088		
Selenium	0.000024		
Toluene	0.0034		

References for Emission Factors
(1) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers.
(2) Emission factors for natural gas of PM-10 and PM-2.5 are roughly equal to those of PM, Natural Gas Combustion, Table 1.4-2
(3) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers for SOx. Stack test on 3/00 for NOx. Otherwise, Emission factors from Sellers Engineering Co.
(4) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers; Emission factors for NOx and CO from Sellers Engineering Co (low-NOx boilers).
(5) AllHAP emission factors from AP-42 7/98, Section 1.4, Natural Gas Combustion, Tables 1.4-3, 1.4-4

<b>2008 Small Boilers Emission Summary Title V Semi-Annual Reporting</b>				
<b>Pollutant Criteria</b>	<b>Total Emissions (tons)</b>			
	<b>Annual Emissions (Includes Insignificant Sources)</b>	<b>Jan-June (Includes Insignificant Sources)</b>	<b>July-Dec (Includes Insignificant Sources)</b>	
NOx	25.584	14.603	10.982	
SOx	0.155	0.088	0.066	
PM	2.035	1.160	0.874	
PM-10	2.035	1.160	0.874	
PM-2.5	2.035	1.160	0.874	
CO	20.688	11.828	8.860	
VOC	1.425	0.814	0.611	
<b>HAPs</b>				
Arsenic	5.16E-05	2.96E-05	2.21E-05	
Benzene	5.42E-04	3.10E-04	2.32E-04	
BE	3.10E-06	1.77E-06	1.33E-06	
Cadmium	2.84E-04	1.62E-04	1.22E-04	
Chromium	3.61E-04	2.06E-04	1.55E-04	
Cobalt	2.17E-05	1.24E-05	9.28E-06	
Dichlorobenzene	3.10E-04	1.77E-04	1.33E-04	
Formaldehyde	1.93E-02	1.11E-02	8.29E-03	
Hexane	4.64E-01	2.66E-01	1.99E-01	
Lead	1.29E-04	7.37E-05	5.63E-05	
Manganese	9.80E-05	5.60E-05	4.20E-05	
Mercury	6.71E-05	3.83E-05	2.87E-05	
Napthalene	1.57E-04	8.99E-05	6.74E-05	
Nickel	5.42E-04	3.10E-04	2.32E-04	
POM	2.27E-05	1.30E-05	9.73E-06	
Selenium	6.19E-06	3.54E-06	2.66E-06	
Toluene	8.77E-04	5.01E-04	3.76E-04	
<b>TOTAL HAPs</b>	<b>0.487</b>	<b>0.278</b>	<b>0.209</b>	



REFERENCES
(a) Information on non-metered boilers is provided as a data deliverable from KSL and contains all gas use at LANL minus those non-LANL sources which feed from the LANL main line and is not expected to be individually metered. Total Gas use does not include TA-3 Power Plant and TA-21 Steam Plant. All other sources are included in this total.
(b) TA-16 Boilers include 2 boilers in plant 5. Gas use was difficult to obtain, so, the boilers were included in the "boiler pool" to determine gas use. Plant 6 has been taken off line and is not expected to be reused or boilers relocated. The removal of these boilers will be requested in the next operating permit revision.
(c) TA-55 has two boilers with separate AIRs numbers. Each boiler has a gas meter. The gas use information is provided monthly by the TA-55 facility personnel and is included in the KSL data deliverable.
(d) The TA-50-RLWTF boiler was added to EI as a new source in 2003. This boiler is owned and operated by a contractor and has been operated at LANL since mid-2000. Originally planned as a temporary source, but current plans are to keep operating for several more years. Therefore, decision was made to include in LANL's annual EI. Fuel use has not been tracked monthly. For 2005 and beyond, the total gas use for each 6 month reporting period is taken and used to calculate emissions.
(e) The 12-month rolling average includes all gas use from all boilers listed in this spreadsheet. Boilers not included in this report due to their large size or design are TA-21 boilers & powerplant boilers at TA-3. A gas use limit of 670 MMBscf/yr, 12-month rolling average is a permit limit in Section 2.4 of the LANL operating permit.
(f) The non-metered boiler pool capacity is the sum of all active non-metered boilers design ratings (derated value, called design rating in boiler data base) in MMBTU. This number is used to estimate the gas use rate (total non-metered gas use divided by the non-metered boiler pool capacity number). This value is taken from the boilers database (Access) on the database drive on the clearair server within ENV-EAQ.
(g) The non-metered boilers gas use section provides estimates of gas use for each boiler. This is calculated using the non-metered gas rate, as discussed in reference (f). The individual boiler design rating is multiplied by the gas use rate to provide the estimated gas used per reporting period (in MMBTU/hr, and is used for heating buildings for personal comfort or for producing hot water for personal use.
(h) NMEED List of Insignificant Activities (9/95), Item (3.) exempts fuel burning equipment which uses gaseous fuel, has a design rate less than or equal to 5 MMBTU/hr, and is used for heating buildings for personal comfort or for producing hot water for personal use.
(i) The design rate for boilers includes a correction for elevation. LANL is at approximately 7,500 feet above sea level. Corrections are made for atmospheric boilers using 4% reduction (derated) for each 1,000 feet above sea level (4% x 7.5 = 30%). For forced draft and power burner boilers, the reduction is half that of atmospheric at 15%. The correction is made using the boiler plate input rating minus the appropriate percentage.

**2008 Small Boilers Emissions by Boiler for Annual EI Reporting (Tons/Year)**

Pollutant Criteria	AIRS 015 TA-48-1 BS-1	AIRS 016 TA-48-1 BS-2	AIRS 017 TA-48-1 BS-6	AIRS 018 TA-53-365 BHW-1	AIRS 019 TA-53-365 BHW-2	AIRS 020 TA-59-1 BHW-1	AIRS 021 TA-59-1 BHW-2	AIRS 024 TA-16 Plant 5	AIRS 037 TA-55-6 BHW-1B	AIRS 038 TA-55-6 BHW-2B	AIRS New TA-50-2 BS-1	Total for Small Boilers
NOx	0.430	0.430	0.576	0.574	0.574	0.430	0.430	0.380	1.036	0.498	0.089	5.447
SOx	0.003	0.003	0.003	0.003	0.003	0.003	0.003	0.006	0.005	0.002	0.001	0.034
PM	0.033	0.033	0.044	0.044	0.044	0.033	0.033	0.078	0.107	0.051	0.007	0.504
PM-10	0.033	0.033	0.044	0.044	0.044	0.033	0.033	0.078	0.107	0.051	0.007	0.504
PM-2.5	0.033	0.033	0.044	0.044	0.044	0.033	0.033	0.078	0.107	0.051	0.007	0.504
CO	0.362	0.361	0.484	0.482	0.482	0.361	0.361	0.380	0.287	0.138	0.074	3.772
VOC	0.024	0.024	0.032	0.032	0.032	0.024	0.024	0.056	0.045	0.022	0.005	0.317
<b>HAPS</b>												
Arsenic	8.61E-07	8.61E-07	1.15E-06	1.15E-06	1.15E-06	8.61E-07	8.61E-07	2.05E-06	1.50E-06	7.22E-07	1.77E-07	1.13E-05
Benzene	9.04E-06	9.04E-06	1.21E-05	1.20E-05	1.20E-05	9.04E-06	9.04E-06	2.15E-05	1.58E-05	7.58E-06	1.86E-06	1.19E-04
BE	5.16E-08	5.16E-08	6.91E-08	6.89E-08	6.89E-08	5.16E-08	5.16E-08	1.23E-07	9.01E-08	4.33E-08	1.06E-08	6.80E-07
Cadmium	4.73E-06	4.73E-06	6.33E-06	6.31E-06	6.31E-06	4.73E-06	4.73E-06	1.13E-05	8.26E-06	3.97E-06	9.74E-07	6.24E-05
Chromium	6.03E-06	6.02E-06	8.03E-06	8.03E-06	8.03E-06	6.02E-06	6.02E-06	1.43E-05	1.05E-05	5.05E-06	1.24E-06	7.94E-05
Cobalt	3.62E-07	3.61E-07	4.84E-07	4.82E-07	4.82E-07	3.61E-07	3.61E-07	8.60E-07	6.30E-07	3.03E-07	7.44E-08	4.76E-06
Dichlorobenzene	5.16E-06	5.16E-06	6.91E-06	6.89E-06	6.89E-06	5.16E-06	5.16E-06	1.23E-05	9.01E-06	4.33E-06	1.06E-06	6.80E-05
Formaldehyde	3.23E-04	3.23E-04	4.30E-04	4.30E-04	4.30E-04	3.23E-04	3.23E-04	7.68E-04	5.63E-04	2.71E-04	6.64E-05	4.25E-03
Hexane	7.75E-03	7.75E-03	1.04E-02	1.03E-02	1.03E-02	7.75E-03	7.75E-03	1.84E-02	1.36E-02	6.49E-03	1.59E-03	1.02E-01
Lead	2.15E-06	2.15E-06	2.88E-06	2.87E-06	2.87E-06	2.15E-06	2.15E-06	5.12E-06	3.75E-06	1.80E-06	4.43E-07	2.83E-05
Manganese	1.64E-06	1.64E-06	2.19E-06	2.18E-06	2.18E-06	1.64E-06	1.64E-06	3.89E-06	2.85E-06	1.37E-06	3.36E-07	2.15E-05
Mercury	1.12E-06	1.12E-06	1.50E-06	1.49E-06	1.49E-06	1.12E-06	1.12E-06	2.66E-06	1.95E-06	9.38E-07	2.30E-07	1.47E-05
Napthalene	2.63E-06	2.62E-06	3.51E-06	3.50E-06	3.50E-06	2.62E-06	2.62E-06	6.25E-06	4.58E-06	2.20E-06	5.40E-07	3.46E-05
Nickel	9.04E-06	9.04E-06	1.21E-05	1.20E-05	1.20E-05	9.04E-06	9.04E-06	2.15E-05	1.58E-05	7.58E-06	1.86E-06	1.19E-04
POM	3.79E-07	3.79E-07	5.05E-07	5.05E-07	5.05E-07	3.79E-07	3.79E-07	9.01E-07	6.60E-07	3.18E-07	7.79E-08	4.99E-06
Selenium	1.03E-07	1.03E-07	1.38E-07	1.38E-07	1.38E-07	1.03E-07	1.03E-07	2.46E-07	1.80E-07	8.66E-08	2.12E-08	1.36E-06
Toluene	1.46E-05	1.46E-05	1.96E-05	1.95E-05	1.95E-05	1.46E-05	1.46E-05	3.48E-05	2.55E-05	1.23E-05	3.01E-06	1.93E-04
<b>TOTAL HAPS/Unit</b>	8.13E-03	8.13E-03	1.09E-02	1.08E-02	1.08E-02	8.13E-03	8.13E-03	1.93E-02	1.42E-02	6.81E-03	1.67E-03	0.11

**EPCRA 313**

Chemical	Amount in Fuel <sup>a</sup>		Emissions from all Small Boilers <sup>b</sup>	
	Conc.	Pounds	Emission Factor (lbs/MMscf)	Emissions (lbs)
Lead <sup>f</sup>			5.0E-04	0.27
Sulfuric Acid <sup>d</sup>			0.6	324.08
Mercury <sup>e</sup>			2.6E-04	0.14
PACs <sup>g</sup>			8.69E-07	4.69E-04
Benzol(g,h,i) perylene <sup>c</sup>			1.20E-06	6.48E-04

(a) Amount of EPCRA chemical in fuel is considered "otherwise used" for EPCRA 313 threshold determination

(b) Combustion compounds emitted are considered "manufactured" for EPCRA 313 threshold determinations. Lead and mercury are lead compounds and mercury compounds.

(c) Emission Factors from AP-42, Section 1.4, Natural Gas Combustion, Tables 1.4-2, 1.4-3 and 1.4-4, July 1998

(d) Assume all SOx emissions are converted to sulfuric acid in the stack.

(e) EPCRA PAC Guidance Document, Table 2-3

2008 Combustion Turbine Emissions (Actual)

Pollutant Criteria	Emission Factors (lb/MMscf)	Unit Emissions				Reference
		TA-3-2422 Combustion Turbine				
		Annual (tons)	Jan-June (tons)	July-Dec (tons)		
NOx	50.5	0.428	0.014	0.413	a	
SOx	3.5	0.030	0.001	0.029	b	
PM	6.8	0.058	0.002	0.056	c	
PM <sub>10</sub>	6.8	0.058	0.002	0.056	c	
CO	10.5	0.089	0.003	0.086	a	
VOC	2.2	0.019	0.001	0.018	d	
<b>HAPs / TRI</b>						
Acetaldehyde	4.12E-02	3.49E-04	1.18E-05	3.37E-04	e, f, g	
Acrolein	6.59E-03	5.58E-05	1.89E-06	5.39E-05	e, f, g	
Benzene	1.24E-02	1.06E-04	3.53E-06	1.01E-04	e, f, g	
Benzo (a) anthracene	3.09E-03	2.62E-05	8.84E-07	2.53E-05	f, h	
1,3-Butadiene	4.43E-04	3.75E-06	1.27E-07	3.62E-06	e, f, g	
Cadmium	7.11E-03	6.02E-05	2.03E-06	5.81E-05	f, h	
Chromium	1.34E-02	1.13E-04	3.83E-06	1.10E-04	f, h	
Copper	7.11E-02	6.02E-04	2.03E-05	5.81E-04	f, h	
Ethylbenzene	3.30E-02	2.79E-04	9.43E-06	2.70E-04	e, f, g	
Fluoranthene	1.24E-03	1.05E-05	3.53E-07	1.01E-05	f, h	
Formaldehyde	7.31E-01	6.19E-03	2.09E-04	5.98E-03	e, f, g	
Manganese	8.24E-02	6.98E-04	2.36E-05	6.74E-04	f, h	
Mercury	6.80E-03	5.76E-05	1.94E-06	5.56E-05	f, h	
Naphthalene	1.34E-03	1.13E-05	3.83E-07	1.10E-05	e, f, g	
Nickel	1.18E-01	1.00E-03	3.39E-05	9.69E-04	f, h	
PAH	2.27E-03	1.92E-05	6.48E-07	1.85E-05	e, f, g	
Phenol	1.34E-02	1.13E-04	3.83E-06	1.10E-04	e, f, h	
Propylene Oxide	2.99E-02	2.53E-04	8.54E-06	2.44E-04	e, f, g	
Toluene	1.34E-01	1.13E-03	3.83E-05	1.10E-03	e, f, g	
Xylenes (isomers)	6.59E-02	5.58E-04	1.89E-05	5.39E-04	e, f, g	
<b>TOTAL HAPs</b>	<b>1.07E+00</b>	<b>1.16E-02</b>	<b>3.93E-04</b>	<b>1.12E-02</b>		

Reviewed By: \_\_\_\_\_

Date: \_\_\_\_\_

Ton/Year Emission Calculations <sup>(i)</sup>			
Pollutant	NOx	CO	
Annual Totals	0.87	0.52	
<b>Ton/Yr Limits</b>	<b>33.2</b>	<b>19.8</b>	

References:

- (a) Values are from the initial compliance test (TRC - October 22, 2007). Test shows average NOx as 11.29 lbs/hr and CO as 2.35 lbs/hr. These were divided by the gas flow rate of 0.223620 MMscf/hr to get 50.48 lb/MMscf (rounded to 50.5) for NOx and 10.5 lb/MMscf for CO.
- (b) The SOx emission factor was taken from AP-42 Table 3.1-2a. The default value is used when percent sulfur is unknown (0.0034 lb/mmBtu). This is equivalent to converting the 2 grains per 100 scf to percent. The 0.0034 lb/mmBtu was converted to lb/mmscf by multiplying by 1030 btu/scf (the heat value of natural gas), to provide 3.5 lb/mmscf.
- (c) PM was calculated by taking the AP-42, Table 3.1-2a, EF of 6.6E-3 lb/MMBtu and multiplying it by 1030 BTU/scf to get 6.8 lb/MMscf. PM10 was calculated the same as PM, as most PM from natural gas combustion is less than 1 micrometer.
- (d) The VOC emission factor was taken from AP-42 Table 3.1-2a. The factor, 2.1 E-03 lb/mmBtu, was converted to lb/mmscf by multiplying by 1030 giving 2.2 lbs/mmscf.
- (e) These chemicals are HAPs
- (f) These chemicals are EPCRA 313 listed chemicals.
- (g) Emission factor from AP-42, table 3.1-3 (lb/mmBtu). This was multiplied by 1030 Btu/scf to provide the lb./mmscf factor.
- (h) Emission factors from EPA FIRE database (SCC: 20300202 & 20200201). These values were also converted from lb/mmBtu to lb/mmscf. Retrieved 4-14-08.
- (i) This calculations partially fulfill conditions 2.9.4.7 and 2.9.4.8 of Title V Permit P100M1.

Daily Calculations of NOx and CO Pound per Hour Emissions*																								
Day	Jan		Feb		Mar		Apr		May		Jun		Jul		Aug		Sep		Oct		Nov		Dec	
	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO	NOx	CO
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	**	4.85	34.5	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	4.32	30.7	0	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	9.6	68.2	0	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	**	**	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	**	**	0	0	**	**	0	0	0.55	3.9	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	1.5	10.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	**	**	0	0	0	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	**	**	0	0	0	0	0
13	0	0	0	0	0	0	0	0	**	**	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	1.03	7.31	0	0	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	4.53	32.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6.06	43	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0	0	15.3	108	0	0	0	0	0	6.84	49	0	0	**
18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	**	**	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	13.5	95.7	0	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.51	10.7	0	0	0	22.3	159	0	0	0
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	23.2	165	0	0	0
22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	24.3	173	0	0	0
23	**	**	0	0	0	0	0	0	0	0	**	**	0	0	0	0	0	0	0	25.4	180	0	0	0
24	**	**	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2.06	15	0	0	**
25	0	0	0	0	0	0	0	0	0	0	0	0	6.86	48.7	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.23	8.73	0	0	0	0	0	0	0	0
28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	0	0	0	0	0	0	0	0	5.15	36.6	0	0	0	0	0	0	0	0	0	0
31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

NOx	CO
23.8	171
<b>Lb/Hr Limits</b>	

\* These calculations partially fulfill conditions 2.9.4.7 and 2.9.4.8 of Title V Permit P100M1.  
 \*\* This fuel was used for compressor start-up only. No fuel went to turbine.  
 \*\*\* Unit started as a test or for training but never reached full load.  
 Deviation reported to NMED in Compliance Certification and Monitoring Report.

Reviewed by: \_\_\_\_\_ Date: \_\_\_\_\_

2008 Daily Turbine Gas Use (MCF), 365 Day Rolling Total Gas Use, & Hours of Operation																											
Day	Jan		Feb		Mar		Apr		May		Jun		Jul		Aug		Sep		Oct		Nov		Dec				
	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs			
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	35	0	0	0	0	0		
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
3	0	0	0	0	0	0	0	0	0	1	0	33	0.7	0	0	0	26	0	0	0	0	0	0	0	0		
4	0	0	0	0	0	0	0	0	0	42	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
5	0	0	0	0	0	0	0	0	0	70	0.75	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
6	0	0	0	0	8	0.75	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
7	0	0	0	0	5	0.5	0	0	1	0	0	4	0.75	0	0	0	0	0	0	0	0	0	0	0	0		
8	0	0	0	0	16	1.1	0	0	0	0	0	0	0	0	0	0	0	0	0	5	0.5	0	0	0	0		
9	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	26	0.5	0	0	0	0		
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0		
13	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
14	0	0	0	0	0	0	0	0	5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
15	0	0	0	0	0	0	0	0	110	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	103	1.75	0	0	0	0		
17	0	0	0	0	0	0	0	0	0	0	0	0	178	1.2	0	0	0	0	0	665	10	0	0	5	0		
18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0	0	0	0	0	0	0	0		
19	0	0	0	0	0	0	0	0	0	0	301	2.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	11	0.75	0	0	0	1889	8.7	0	0	0	0		
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5409	24	0	0	0	0	0		
22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5430	23	0	0	0	0	0		
23	7	1	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	2468	10	0	0	0	0	0		
24	3	1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	1	0	0	0	2	0		
25	0	0	0	0	0	0	0	0	0	0	0	0	20	0.3	0	0	0	0	0	0	0	0	0	0	0		
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8	0.67	0	0	0	0	0	0	0	0	0		
28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
30	0	0	0	0	0	0	0	0	0	0	0	0	20	0.4	0	0	0	0	0	0	0	0	0	0	0		
31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SUM	10	2.5	0	0	29	2.35	0	0	118	3	415	4.05	255	3.35	19	1.42	30	0	16050	79.5	0	0	0	7	0		

**First Half Gas Use: 572 MCF**    **Second Half Gas Use: 16361 MCF**    **Annual Gas Use: 16933 MCF**  
 Rolling Gas Use (MSCF)    **Jan. 6318**    **Feb. 6318**    **Mar. 6347**    **Apr. 6347**    **May 6465**    **June 6880**  
    **July 7135**    **Aug. 7154**    **Sep. 2498**    **Oct. 16927**    **Nov. 16927**    **Dec. 16933**    **Permit Limit (365 day rolling total): 646 MMSCF**  
    or    **646,000 MSCF**  
 The SCFH value (fuel flow rate) in the cell equation is from the compliance test report (223620 SCFH or 223.6 MSCFH)

2008 Generator Hours

TA	Bldg	Manufacturer	MODEL	KW	Fuel Type	Previous Reading Date	Previous Reading	First 6 Month Readings			Second 6 Month Readings			
								6 Month Reading Date	Reading	Hours Run	12 Month Reading Date	Reading	Hours Run	
3	40	Onan Sons	1500DVE15R31374B	150	Diesel	Dec-08	6.6	Jun-08	11.8	5.2	Dec-08	12.8	1	
3	223	Onan Sons	45.OEM-15R/10742D	45	Propane	Dec-08	489.5	Jun-08	492.5	3.0	Dec-08	492.5	0	
3	440	Cummins	500FDR5051	260	Diesel	Dec-08	121.8	Jun-08	121.8	0.0	Dec-08	121.8	0	
3	440	Cummins	DFGA-5005210	500	Diesel	Dec-08	81.8	Jun-08	93.8	12.0	Dec-08	99.9	6.1	
3	1076	Cummins	DGBB-5601289	35	Diesel	Dec-08	129.7	Jun-08	141.2	11.5	Dec-08	181.1	39.9	
3	1400	Cummins	DFEH-5699616	400	Diesel	Dec-08	33.0	Jun-08	37	4.0	Dec-08	44	7	
3	1404	Cummins	DFLC-5554001	1250	Diesel	Dec-08	336.5	Jun-08	388.4	31.9	Dec-08	393.5	25.1	
3	1498	Caterpillar	SR-4	600	Diesel	Dec-08	326.0	Jun-08	331.0	5.0	Dec-08	337	6	
3	2322	Onan Sons	DGDA-5005757	80	Diesel	Dec-08	339.8	Jun-08	352	12.2	Dec-08	358.6	6.6	
16	980	Cummins	KTA50-G2	1100	Diesel	Dec-08	293.4	Jun-08	305.2	11.8	Dec-08	318.6	13.4	
16	1374	Onan Sons	60ENA	60	Nat. Gas	Dec-08	1092.9	Jun-08	1115.8	22.9	Dec-08	1125	9.2	
18	31	Onan Sons	275DFML29807N	275	Diesel	Dec-08	180.8	Jun-08	180.8	0.0	Dec-08	180.8	0	
35	2	Onan Sons	100DGD	100	Diesel	Dec-08	115.5	Jun-08	115.5	0.0	Dec-08	115.5	0	
35	402	Cummins	DGCB-5674244	60	Diesel	Dec-08	138.4	Jun-08	158.0	19.6	Dec-08	175	17	
43	1	Cummins	4BT3.9-GC	50	Diesel	Dec-08	383.9	Jun-08	387.7	3.8	Dec-08	392.9	5.2	
43	1	Onan Sons	DVE	150	Diesel	Dec-08	620.0	Jun-08	644.4	24.4	Dec-08	671.9	27.5	
46	335	Onan Sons	300DEFCEB	300	Diesel	Dec-08	959.5	Jun-08	995.4	35.9	Dec-08	1020	24.6	
48	45	Onan Sons	DFCB-5740130	300	Diesel	Dec-08	53.5	Jun-08	69.5	16.0	Dec-08	78.5	9	
50	37	Cummins	680FDR5059FF	500	Diesel	Dec-08	502.9	Jun-08	502.9	0.0	Dec-08	502.9	0	
50	184	Onan Sons	DGFA-568741	150	Diesel	Dec-08	212.7	Jun-08	238.6	25.9	Dec-08	256	17.4	
50	188	Onan Sons	L940563879	1250	Diesel	Dec-08	149.0	Jun-08	149.0	0.0	Dec-08	149	0	
53	1	Onan Sons	60ENA	60	Nat. Gas	Dec-08	1234.1	Jun-08	1261.2	27.1	Dec-08	1271	9.8	
53	2	Kato Eng.	Kameg-14	50	Diesel	Dec-08	194.3	Jun-08	194.3	0.0	Dec-08	194.6	0.3	
53	3N	Onan	15.0JC-18R	15	Propane	Jun-08	345.3	Jun-08	345.3	0.0	Dec-08	362.3	17	
54	412	Olympian	95M-07874-F	500	Diesel	Dec-08	317.9	Jun-08	324.7	6.8	Dec-08	331.7	7	
55	5	Kohler	100RZ71	100	Propane	Dec-08	79.3	Jun-08	93.4	14.1	Dec-08	98.3	4.9	
55	8	Delco/Detroit	E7014DD	600	Diesel	Dec-08	822.2	Jun-08	831.8	9.6	Dec-08	840.6	8.8	
55	364	Onan Sons	1250DFLC-4987	1250	Diesel	Dec-08	82.8	Jun-08	101.3	18.5	Dec-08	134.3	33	
55	28	Onan Sons	40DL6T	40	Diesel	Dec-08	66.5	Jul-08	72.4	5.9	Dec-08	84.6	12.2	
55	47	Onan Sons	1465	200	Diesel	Dec-08	540.0	Jul-08	555.5	15.5	Dec-08	589	33.5	
55	142	Cummins	DFEB-4963414	400	Diesel	Dec-08	105.0	Jul-08	114.8	9.8	Dec-08	122.1	7.3	
59	1	Allis Chalmers	2884-0703	90	Diesel	Dec-08	750.0	Jul-08	750.0	0.0	Dec-08	750	0	
60	yard	Cummins	DFHD-4964979	1000	Diesel	Dec-08	648.4	Jun-08	649.4	1.0	Dec-08	650	0.6	
63	93	Murphy	3166-0084	30	Diesel	Dec-08	716.0	Jul-08	716.0	0.0	Dec-08	716	0	
64	1	Onan Sons	250DVG	250	Diesel	Dec-08	166.9	Jul-08	171.8	4.9	Dec-08	178	6.2	
69	33	Cummins	DFLC-5568730	1250	Diesel	Dec-08	71.3	Jul-08	78.6	7.3	Dec-08	85	6.4	
<b>36 Generators in use</b>											<b>TOTAL</b>	<b>365.6</b>	<b>TOTAL</b>	<b>362.0</b>

N/R = Not Read

First half average hours per unit 10.2

Second half average hours per unit 10.1

Annual Average of hours per unit 10.1

Reviewed By / Date:

2008 Generator Hours

EMISSION FACTORS	NOx	CO	Sox <sup>(e)</sup>	PM	PM10	VOC
Large Diesel fired <sup>(a)(b)</sup>	lb/kw-hr 0.032	lb/kw-hr 0.007	lb/kw-hr 5.4E-04	lb/kw-hr 0.001	lb/kw-hr 0.001	lb/kw-hr 0.001
Small Diesel fired <sup>(a)(c)</sup>	0.042	0.009	0.003	0.003	0.003	0.003
Natural Gas Fired <sup>(d)</sup>	0.008	0.013	2.0E-06	3.4E-05	3.2E-05	1.0E-04

References:

447	447 kw (600 hp) is the size limit for determining large vs. small diesel fired generator. This information was taken from the operating permit application and is also found in AP-42.
(a)	The AP-42 (fifth edition), table 3.4-1, emissions factor uses units of lb/hp-hr. There are 1,341 hp-hrs in a kw. Therefore, take pounds/hp-hr x 1,341 hp-hr/kwh to obtain the emission factor in lb/kwh.
(b)	Emission factors for large diesel fired engines were taken from AP-42 (fifth edition), Tables 3.4-1, 3.4-2, 3.4-3, and 3.4-4.
(c)	Emission factors for small diesel fired engines were taken from AP-42 (fifth edition), Tables 3.3-1 and 3.3-2.
(d)	The AP-42 (fifth edition) emission factors for natural gas burning 4-stroke rich-burn engines (Table 3.2-3) provides units of lb/MMBTU. There are 3413 Btus in a kilowatt-hr (kwh) or 2,928 x 10 <sup>4</sup> kwh per BTU. Therefore, take lb/MMBTU x 3413 / 1 x 10 <sup>6</sup> or lb/MMbtu /106/2,928 x 10 <sup>4</sup> to obtain the emissions factor in lb/kwh. The differences between the Title V application emission factors and those listed here, are that the application used the 2-stroke table, and the above emission factors are for rich burn 4-stroke engines. Most generator engines have been verified with the KSL generator crew to be 4-stroke.
(e)	The Sulfur Oxide (SOx) emission factor for large diesel engines was calculated using AP-42 Table 3.4-1 (fifth edition). The calculation requires the sulfur percent found in the fuel. It was verified in March of 2007, that future fuel supplied to the generators around LANL will be Ultra Low Sulfur Diesel (ULSD) (Sulfur <=15 ppm). Due to the low hours (and associated low fuel use) of most generators, the previous LANL tested fuel sulfur concentration of 0.05% will continue to be used for the rest of 2007 to allow for refueling of generators and use of the new ULSD. Calculation is 0.00809 * 0.05 * 0.608 * 2.2 = 5.4 x 10 <sup>-4</sup>



Emission Factors (lb/kwh)

2008 Generator Hours

Location	First 6 Month Emissions							Second 6 Month Emissions						
	NOX (lb/yr)	CO (lb/yr)	SOX (lb/yr)	PM (lb/yr)	VOC (lb/yr)	HAPs (lb/yr)		NOX (lb/yr)	CO (lb/yr)	SOX (lb/yr)	PM (lb/yr)	VOC (lb/yr)	HAPs (lb/yr)	
3-40	32.8	7.0	2.3	2.3	2.3	1.1E-02		6.3	1.4	0.5	0.5	0.5	2.0E-03	
3-223	1.1	1.8	0.0	0.0	0.0	1.3E-02		0.0	0.0	0.0	0.0	0.0	0.0E+00	
3-440	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	0.0E+00	
3-440	192.0	42.0	3.2	6.0	6.0	3.5E-02		97.6	21.4	1.6	3.1	3.1	1.8E-02	
3-1076	16.9	3.6	1.2	1.2	1.2	5.4E-03		58.7	12.6	4.2	4.2	4.2	1.9E-02	
3-1400	67.2	14.4	4.8	4.8	4.8	2.2E-02		117.6	25.2	8.4	8.4	8.4	3.8E-02	
3-1404	1276.0	279.1	21.5	39.9	39.9	2.3E-01		1004.0	219.6	16.9	31.4	31.4	1.8E-01	
3-1498	96.0	21.0	1.6	3.0	3.0	1.7E-02		115.2	25.2	1.9	3.6	3.6	2.1E-02	
3-2322	41.0	8.8	2.9	2.9	2.9	1.3E-02		22.2	4.8	1.6	1.6	1.6	7.1E-03	
16-980	415.4	90.9	7.0	13.0	13.0	7.6E-02		471.7	103.2	8.0	14.7	14.7	8.6E-02	
16-1374	11.0	17.9	0.0	0.0	0.1	1.5E-01		4.4	7.2	0.0	0.0	0.1	6.2E-02	
18-31	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	0.0E+00	
35-2	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	0.0E+00	
35-402	49.4	10.6	3.5	3.5	3.5	1.6E-02		42.8	9.2	3.1	3.1	3.1	1.4E-02	
43-1	8.0	1.7	0.6	0.6	0.6	2.6E-03		10.9	2.3	0.8	0.8	0.8	3.5E-03	
43-1	153.7	32.9	11.0	11.0	11.0	4.9E-02		173.3	37.1	12.4	12.4	12.4	5.6E-02	
46-335	452.3	96.9	32.3	32.3	32.3	1.5E-01		310.0	66.4	22.1	22.1	22.1	1.0E-01	
48-45	201.6	43.2	14.4	14.4	14.4	6.5E-02		113.4	24.3	8.1	8.1	8.1	3.7E-02	
50-37	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	0.0E+00	
50-184	163.2	35.0	11.7	11.7	11.7	5.3E-02		109.6	23.5	7.8	7.8	7.8	3.5E-02	
50-188	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	0.0E+00	
53-1	13.0	21.1	0.0	0.1	0.2	1.8E-01		4.7	7.6	0.0	0.0	0.1	6.6E-02	
53-2	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.6	0.1	0.0	0.0	0.0	2.0E-04	
53-3N	0.0	0.0	0.0	0.0	0.0	0.0E+00		2.0	3.3	0.0	0.0	0.0	2.5E-02	
54-412	108.8	23.8	1.8	3.4	3.4	2.0E-02		112.0	24.5	1.9	3.5	3.5	2.5E-02	
55-5	11.3	18.3	0.0	0.0	0.1	1.4E-01		3.9	6.4	0.0	0.0	0.0	2.0E-02	
55-8	184.3	40.3	3.1	5.8	5.8	3.4E-02		169.0	37.0	2.9	5.3	5.3	4.9E-02	
55-364	740.0	161.9	12.5	23.1	23.1	1.3E-01		1320.0	288.8	22.3	41.3	41.3	3.1E-02	
55-28	9.9	2.1	0.7	0.7	0.7	3.2E-03		20.5	4.4	1.5	1.5	1.5	2.4E-01	
55-47	130.2	27.9	9.3	9.3	9.3	4.2E-02		281.4	60.3	20.1	20.1	20.1	6.6E-03	
55-142	164.6	35.3	11.8	11.8	11.8	5.3E-02		122.6	26.3	8.8	8.8	8.8	9.1E-02	
59-1	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	3.9E-02	
60-yard	32.0	7.0	0.5	1.0	1.0	5.8E-03		19.2	4.2	0.3	0.6	0.6	0.0E+00	
63-93	0.0	0.0	0.0	0.0	0.0	0.0E+00		0.0	0.0	0.0	0.0	0.0	3.5E-03	
64-1	51.5	11.0	3.7	3.7	3.7	1.7E-02		65.1	14.0	4.6	4.6	4.6	0.0E+00	
69-33	292.0	63.9	4.9	9.1	9.1	5.3E-02		256.0	56.0	4.3	8.0	8.0	2.1E-02	
lbs/6 months	4915.1	1119.4	166.5	214.6	214.9	1.6	5034.7	1116.1	164.1	215.4	215.5	1.3	6.5E-04	
Tons/6 months	2.46	0.56	0.08	0.11	0.11	8.0E-04	2.52	0.56	0.08	0.11	0.11	0.11	6.5E-04	

YEARLY TOTAL Tons/Year	NOX	CO	SOX	PM	VOC	HAPs
	4.97	1.12	0.17	0.21	0.22	0.001

2008 Generator Hours

Location	HAPS (lbs)											
	Benzene		Toluene		Xylenes		1,3-Butadiene		Formaldehyde		Acetaldehyde	
	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half
Natural Gas	5.40E-06		1.91E-06		6.66E-07		2.26E-06		7.00E-05		9.53E-06	
Diesel (small)	3.19E-06		1.40E-06		9.73E-07		1.34E-07		4.03E-06		2.62E-06	
Diesel (large)	2.65E-06		9.60E-07		6.59E-07				2.69E-07		8.61E-08	
3-40	2.49E-03	4.78E-04	1.09E-03	2.10E-04	7.59E-04	1.46E-04	1.04E-04	2.00E-05	3.14E-03	6.05E-04	2.04E-03	3.93E-04
3-223	7.28E-04	0.00E+00	2.57E-04	0.00E+00	8.99E-05	0.00E+00	0.00E+00	0.00E+00	9.45E-03	0.00E+00	1.29E-03	0.00E+00
3-440	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3-440	1.59E-02	8.08E-03	5.76E-03	2.93E-03	3.95E-03	2.01E-03	0.00E+00	0.00E+00	1.62E-03	8.22E-04	5.16E-04	2.63E-04
3-1076	1.28E-03	4.45E-03	5.62E-04	1.95E-03	3.92E-04	1.36E-03	5.37E-05	1.86E-04	1.62E-03	5.63E-03	1.05E-03	3.66E-03
3-1400	5.10E-03	8.92E-03	2.23E-03	3.91E-03	1.56E-03	2.73E-03	2.14E-04	3.74E-04	6.45E-03	1.13E-02	4.19E-03	7.33E-03
3-1404	1.06E-01	8.32E-02	3.83E-02	3.01E-02	2.63E-02	2.07E-02	0.00E+00	0.00E+00	1.07E-02	8.45E-03	3.43E-03	2.70E-03
3-1498	7.95E-03	9.54E-03	2.88E-03	3.45E-03	1.98E-03	2.37E-03	0.00E+00	0.00E+00	8.08E-04	9.70E-04	2.58E-04	3.10E-04
3-2322	3.11E-03	1.68E-03	1.36E-03	7.38E-04	9.50E-04	5.14E-04	1.30E-04	7.05E-05	3.93E-03	2.13E-03	2.56E-03	1.38E-03
16-980	3.44E-02	3.91E-02	1.25E-02	1.41E-02	8.56E-03	9.72E-03	0.00E+00	0.00E+00	3.50E-03	3.97E-03	1.12E-03	1.27E-03
16-1374	7.41E-03	2.98E-03	2.62E-03	1.05E-03	9.15E-04	3.68E-04	3.11E-03	1.25E-03	9.62E-02	3.86E-02	1.31E-02	5.26E-03
18-31	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
35-2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
35-402	3.75E-03	3.25E-03	1.64E-03	1.42E-03	1.14E-03	9.93E-04	1.57E-04	1.36E-04	4.74E-03	4.11E-03	3.08E-03	2.67E-03
43-1	6.05E-04	8.28E-04	2.65E-04	3.63E-04	1.85E-04	2.53E-04	2.54E-05	3.47E-05	7.68E-04	1.05E-03	4.98E-04	6.81E-04
43-1	1.17E-02	1.31E-02	5.11E-03	5.76E-03	3.56E-03	4.02E-03	4.89E-04	5.51E-04	1.48E-02	1.66E-02	9.59E-03	1.08E-02
46-335	3.43E-02	2.35E-02	1.50E-02	1.03E-02	1.05E-02	7.18E-03	1.44E-03	9.86E-04	4.34E-02	2.97E-02	2.82E-02	1.93E-02
48-45	1.53E-02	8.60E-03	6.70E-03	3.77E-03	4.67E-03	2.63E-03	6.41E-04	3.61E-04	1.93E-02	1.09E-02	1.26E-02	7.07E-03
50-37	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
50-184	1.24E-02	8.32E-03	5.43E-03	3.65E-03	3.78E-03	2.54E-03	5.19E-04	3.49E-04	1.57E-02	1.05E-02	1.02E-02	6.84E-03
50-188	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
53-1	8.77E-03	3.17E-03	3.10E-03	1.12E-03	1.08E-03	3.92E-04	3.68E-03	1.33E-03	1.14E-01	4.12E-02	1.55E-02	5.60E-03
53-2	0.00E+00	4.78E-05	0.00E+00	2.10E-05	0.00E+00	1.46E-05	0.00E+00	2.00E+00	0.00E+00	6.05E-05	0.00E+00	3.93E-05
53-3N	0.00E+00	1.38E-03	0.00E+00	4.86E-04	0.00E+00	1.70E-04	0.00E+00	5.77E-04	0.00E+00	1.79E-02	0.00E+00	2.43E-03
54-412	9.01E-03	1.38E-03	3.26E-03	4.86E-04	2.24E-03	1.70E-04	0.00E+00	5.77E-04	9.16E-04	1.79E-02	2.93E-04	2.43E-03
55-5	7.61E-03	9.28E-03	2.69E-03	3.36E-03	9.39E-04	2.31E-03	3.19E-03	0.00E+00	9.87E-02	9.43E-04	1.34E-02	3.01E-04
55-8	1.53E-02	2.64E-03	5.53E-03	9.34E-04	3.80E-03	3.26E-04	0.00E+00	1.11E-03	1.55E-03	3.43E-02	4.96E-04	4.67E-03
55-364	6.13E-02	1.40E-02	2.22E-02	5.07E-03	1.52E-02	3.48E-03	0.00E+00	0.00E+00	6.23E-03	1.42E-03	1.99E-03	4.54E-04
55-28	7.52E-04	1.09E-01	3.30E-04	3.96E-02	2.30E-04	2.72E-02	3.15E-05	0.00E+00	9.51E-04	1.11E-02	6.18E-04	3.55E-03
55-47	9.88E-03	1.56E-03	4.33E-03	6.82E-04	3.02E-03	4.75E-04	4.14E-04	6.52E-05	1.25E-02	1.97E-03	8.12E-03	1.28E-03
55-142	1.25E-02	2.13E-02	5.48E-03	9.36E-03	3.82E-03	6.52E-03	5.23E-04	8.95E-04	1.58E-02	2.70E-02	1.03E-02	1.76E-02
59-1	0.00E+00	9.30E-03	0.00E+00	4.08E-03	0.00E+00	2.84E-03	0.00E+00	3.90E-04	0.00E+00	1.18E-02	0.00E+00	7.65E-03
60-yard	2.65E-03	0.00E+00	9.60E-04	0.00E+00	6.59E-04	0.00E+00	0.00E+00	0.00E+00	2.69E-04	0.00E+00	8.61E-05	0.00E+00
63-93	0.00E+00	1.59E-03	0.00E+00	5.76E-04	3.95E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.62E-04	0.00E+00	5.16E-05
64-1	3.90E-03	0.00E+00	1.71E-03	0.00E+00	1.19E-03	0.00E+00	1.64E-04	0.00E+00	4.94E-03	0.00E+00	3.21E-03	0.00E+00
69-33	2.42E-02	4.94E-03	8.76E-03	2.17E-03	6.01E-03	1.51E-03	0.00E+00	2.07E-04	2.46E-03	6.25E-03	7.85E-04	4.06E-03
lbs	4.18E-01	3.96E-01	1.60E-01	1.52E-01	1.07E-01	1.03E-01	1.52E-02	9.47E-03	4.94E-01	3.17E-01	1.48E-01	1.20E-01
Tons/Half/HAP	2.09E-04	1.98E-04	8.00E-05	7.58E-05	5.37E-05	5.16E-05	7.60E-06	4.74E-06	2.47E-04	1.59E-04	7.42E-05	6.00E-05
Tons/year/HAP	4.07E-04		1.56E-04		1.05E-04		1.23E-05		4.06E-04		1.34E-04	

2008 Generator Hours

Tons/Year Total	1.45E-03
-----------------	----------

Emission Factors from AP-42, Volume 1, Fifth Edition (Small Diesel Engines Table 3.3-2, Large Diesel Engines Table 3.4-4, Natural Gas 4-Stroke Engines Table 3.2-3)

2008 Generator Hours

HAPS (lbs)															
Acrolein		Naphthalene		1,1,2,2-Tetrachloroethane		1,1,2-Trichloroethane		1,3-Dichloropropene		Carbon Tetrachloride		Chlorobenzene		Chloroform	
1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half
8.98E-06	3.32E-07	3.32E-07	2.90E-07	8.64E-08	5.23E-08	5.23E-08	4.34E-08	6.05E-08	4.41E-08	4.68E-08	4.41E-08	6.05E-08	4.41E-08	4.68E-08	4.68E-08
3.16E-07	2.69E-08	2.90E-07	4.44E-07												
2.46E-04	4.74E-05	2.26E-04	4.34E-05												
1.21E-03	0.00E+00	4.48E-05	0.00E+00												
0.00E+00	0.00E+00	0.00E+00	0.00E+00												
1.61E-04	8.21E-05	2.66E-03	1.35E-03												
1.27E-04	4.41E-04	1.17E-04	4.04E-04												
5.05E-04	8.85E-04	4.63E-04	8.11E-04												
1.07E-03	8.44E-04	1.77E-02	1.39E-02												
8.07E-05	9.69E-05	1.33E-03	1.60E-03												
3.08E-04	1.67E-04	2.83E-04	1.53E-04												
3.49E-04	3.97E-04	5.76E-03	6.54E-03												
1.23E-02	4.96E-03	4.56E-04	1.83E-04	1.19E-04	4.77E-05	7.18E-05	2.88E-05	5.96E-05	2.39E-05	8.31E-05	3.34E-05	6.05E-05	2.43E-05	6.43E-05	2.58E-05
0.00E+00	0.00E+00	0.00E+00	0.00E+00												
0.00E+00	0.00E+00	0.00E+00	0.00E+00												
3.72E-04	3.22E-04	3.41E-04	2.95E-04												
6.00E-05	8.21E-05	5.50E-05	7.53E-05												
1.16E-03	1.30E-03	1.06E-03	1.19E-03												
3.40E-03	2.33E-03	3.12E-03	2.14E-03												
1.52E-03	8.53E-04	1.39E-03	7.82E-04												
0.00E+00	0.00E+00	0.00E+00	0.00E+00												
1.23E-03	8.25E-04	1.13E-03	7.56E-04												
0.00E+00	0.00E+00	0.00E+00	0.00E+00												
1.46E-02	5.29E-03	5.39E-04	1.95E-04	1.40E-04	5.08E-05	8.50E-05	3.07E-05	7.05E-05	2.55E-05	9.83E-05	3.55E-05	7.16E-05	2.59E-05	7.61E-05	2.75E-05
0.00E+00	4.74E-06	0.00E+00	4.34E-06												
0.00E+00	2.29E-03	0.00E+00	8.46E-05												
9.15E-05	2.29E-03	1.51E-03	8.46E-05												
1.27E-02	9.42E-05	4.68E-04	1.55E-03												
1.55E-04	4.40E-03	2.56E-03	1.62E-04												
6.22E-04	1.42E-04	1.03E-02	2.34E-03												
7.46E-05	1.11E-03	6.83E-05	1.83E-02												
9.79E-04	1.54E-04	8.98E-04	1.41E-04												
1.24E-03	2.12E-03	1.14E-03	1.94E-03												
0.00E+00	9.22E-04	0.00E+00	8.46E-04												
2.69E-05	0.00E+00	4.44E-04	0.00E+00												
0.00E+00	1.61E-05	0.00E+00	2.66E-04												
3.87E-04	0.00E+00	3.55E-04	0.00E+00												
2.46E-04	4.90E-04	4.05E-03	4.49E-04												
5.52E-02	3.29E-02	5.84E-02	5.68E-02	2.59E-04	9.83E-05	1.57E-04	5.96E-05	1.30E-04	4.94E-05	1.81E-04	6.89E-05	1.32E-04	5.02E-05	1.40E-04	5.33E-05
2.78E-05	1.65E-05	2.82E-05	2.83E-05	1.30E-07	4.93E-08	7.84E-08	2.98E-08	6.51E-08	2.47E-08	9.07E-08	3.45E-08	6.61E-08	2.51E-08	7.02E-08	2.67E-08
4.41E-05		5.75E-05		1.79E-07		1.08E-07		8.98E-08		1.25E-07		9.12E-08		9.69E-08	

2008 Generator Hours

HAPS (lbs)				HAPS (lbs)										Individual Generator Emissions (lb/s)		
Ethylbenzene	Ethylene Dibromide		Methanol		Methylene Chloride		PAH		Styrene		Toluene		Vinyl Chloride		1st Half	2nd Half
	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half		
8.47E-08	7.27E-08	1.05E-05	1.41E-07	4.82E-07	5.74E-07	4.06E-08	1.91E-06	2.45E-08						1.05E-02	2.03E-03	
														1.34E-02	0.00E+00	
														0.00E+00	0.00E+00	
														3.49E-02	1.77E-02	
														5.44E-03	1.89E-02	
														2.16E-02	3.79E-02	
														2.32E-01	1.83E-01	
														1.75E-02	2.10E-02	
														1.32E-02	7.14E-03	
														7.56E-02	8.58E-02	
1.16E-04	4.68E-05	1.44E-02	5.77E-03	1.93E-04	7.77E-05	6.62E-04	2.66E-04	5.58E-05	2.24E-05	2.62E-03	1.05E-03	3.37E-05	1.35E-05	1.55E-01	6.22E-02	
						0.00E+00	0.00E+00							0.00E+00	0.00E+00	
						0.00E+00	0.00E+00							0.00E+00	0.00E+00	
						6.75E-04	5.85E-04							1.38E-02	1.38E-02	
						1.09E-04	1.49E-04							2.57E-03	3.51E-03	
						2.10E-03	2.37E-03							4.95E-02	5.58E-02	
						6.18E-03	4.23E-03							1.46E-01	9.98E-02	
						2.75E-03	1.55E-03							6.49E-02	3.65E-02	
						0.00E+00	0.00E+00							0.00E+00	0.00E+00	
						2.23E-03	1.50E-03							5.25E-02	3.53E-02	
						0.00E+00	0.00E+00							0.00E+00	0.00E+00	
1.38E-04	4.98E-05	1.70E-02	6.15E-03	2.29E-04	8.27E-05	7.83E-04	2.83E-04	6.61E-05	2.39E-05	3.10E-03	1.12E-03	3.99E-05	1.44E-05	1.83E-01	6.62E-02	
						0.00E+00	8.61E-06							0.00E+00	2.03E-04	
						0.00E+00	1.23E-04							0.00E+00	2.54E-02	
						2.46E-03	1.23E-04							1.98E-02	2.54E-02	
						6.79E-04	2.53E-03							1.40E-01	2.04E-02	
						4.17E-03	2.36E-04							3.35E-02	4.88E-02	
						1.67E-02	3.82E-03							1.35E-01	3.07E-02	
						1.35E-04	2.99E-02							3.19E-03	2.40E-01	
						1.76E-03	2.80E-04							4.19E-02	6.60E-03	
						2.25E-03	3.84E-03							5.30E-02	9.06E-02	
						0.00E+00	1.68E-03							0.00E+00	3.95E-02	
						7.24E-04	0.00E+00							5.82E-03	0.00E+00	
						0.00E+00	4.34E-04							0.00E+00	3.49E-03	
						7.03E-04	0.00E+00							1.66E-02	0.00E+00	
						6.61E-03	8.89E-04							5.31E-02	2.10E-02	
2.54E-04	9.66E-05	3.14E-02	1.19E-02	4.27E-04	1.60E-04	9.88E-02	9.88E-02	1.22E-04	4.63E-05	5.72E-03	2.17E-03	7.36E-05	2.80E-05	1.59E+00	1.30E+00	
1.27E-07	1.09E-07	1.57E-05	5.96E-06	2.11E-07	8.02E-08	4.94E-05	4.79E-05	6.10E-08	2.32E-08	2.86E-06	1.09E-06	3.68E-08	1.40E-08			
		2.16E-05		2.91E-07		9.73E-05		8.41E-08		3.94E-06		5.08E-08				

**TA-3 Power Plant Fuel Use Totals 2008 (Data Entry)**

Month	DATA ENTRY						Monthly Totals	
	TA-3-22 Power Plant <sup>b</sup> Boiler # 1 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant <sup>b</sup> Boiler # 2 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant <sup>b</sup> Boiler # 3 (Union Iron Works, 210 MMBTU/hr)		Natural Gas (MMCF) <sup>a</sup>	Fuel Oil (gallons) <sup>a</sup>
January	6,912	328	63,171	0	1,108	0	71,191	328
February	19,497	493	34,960	0	3,618	0	58,075	493
March	617	603	50,578	0	866	384	52,061	987
April	0	0	37,023	219	4,276	0	41,299	219
May	0	0	23,792	0	7,242	331	31,034	331
June	148	55	11,048	0	9,920	0	21,116	55
July	9,607	55	11,966	0	1,085	0	22,257	55
August	568	0	14,574	0	23	0	15,165	0
September	219	55	20,859	0	394	40	21,472	95
October	49	164	12,359	0	23,640	0	36,048	164
November	129	0	26,123	212	21,713	0	47,965	212
December	8,068	0	1,813	0	57,018	0	66,899	0
<b>Annual Totals:</b>	<b>45,814</b>	<b>1,753</b>	<b>307,865</b>	<b>431</b>	<b>130,903</b>	<b>755</b>	<b>484,582</b>	<b>2939</b>
Jan. - June	27,174	1,479	220,572	219	27,030	715	274,776	2413
July - Dec.	18,640	274	87,293	212	103,873	40	209,806	526

Month	12-Mo. Rolling Total Natural Gas (MMscf)	12-Mo. Rolling Total Fuel Oil (gallons)
January	447.5	83343
February	446.5	83489
March	446.9	83420
April	446.2	83036
May	442.6	4903
June	463.7	4958
July	485.9	5013
August	485.7	5013
September	481.4	4670
October	480.0	4012
November	482.2	3652
December	484.6	2939
Permit Limits:	2000 MMscf	500,000 gallons

For References, See "Emission Summary Sheet"

Data Reviewed By: \_\_\_\_\_

Emissions by Boiler 2008

Pollutant Criteria	Emission Factor		Unit Emissions						Unit Emissions					
	Natural Gas (lb/MMscf) <sup>a)</sup>	Fuel Oil <sup>(b)</sup> Pounds/1000 gal	Boiler #1, Stack 032			Boiler #2, Stack 033			Boiler #3, Stack 034					
			Annual Nat'l Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)	Annual Nat'l Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)	Annual Nat'l Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)
Nox <sup>(c)</sup>	58	8.64	1.329	0.008	0.794	0.542	8.928	0.002	6.398	2.532	3.796	0.003	0.787	3.012
Sox <sup>(d)</sup>	0.6	7.4	0.014	0.006	0.014	0.007	0.092	0.002	0.067	0.027	0.039	0.003	0.011	0.031
PM <sup>(d)</sup>	7.6	3.3	0.174	0.003	0.174	0.106	1.170	0.001	0.839	0.332	0.497	0.001	0.104	0.395
PM-10 <sup>(d)</sup>	7.6	2.3	0.174	0.002	0.105	0.071	1.170	0.000	0.838	0.332	0.497	0.001	0.104	0.395
PM-2.5 <sup>(d)</sup>	7.6	1.55	0.174	0.001	0.104	0.071	1.170	0.000	0.838	0.332	0.497	0.001	0.103	0.395
CO <sup>(e)</sup>	40	5.0	0.916	0.004	0.547	0.373	6.157	0.001	4.412	1.746	2.618	0.002	0.542	2.078
VOC	5.5	0.2	0.126	0.0002	0.075	0.051	0.847	0.0000	0.607	0.240	0.360	0.000	0.074	0.286
HAPs <sup>(f)</sup>														
Arsenic	0.0002	0.00055	4.58E-06	4.80E-07	3.12E-06	1.94E-06	3.08E-05	1.18E-07	2.21E-05	8.79E-06	1.31E-06	2.07E-07	2.90E-06	1.04E-05
Benzene	0.0021	-	4.81E-05	0	2.85E-05	1.96E-05	3.23E-04	0	2.32E-04	9.17E-05	1.37E-04	0	2.84E-05	1.09E-04
Beryllium	0.000012	0.00041	2.75E-07	3.60E-07	4.67E-07	1.68E-07	1.85E-06	8.86E-08	1.37E-06	5.67E-07	7.88E-07	1.55E-07	3.09E-07	6.31E-07
Cadmium	0.0011	0.00041	2.52E-05	3.60E-07	1.52E-05	1.03E-05	1.69E-04	8.86E-08	1.21E-04	4.81E-05	7.20E-05	1.56E-07	1.50E-05	5.71E-05
Chromium	0.0014	0.00041	3.21E-05	3.60E-07	1.93E-05	1.31E-05	2.16E-04	8.86E-08	1.54E-04	6.11E-05	9.16E-05	1.55E-07	1.91E-05	7.27E-05
Cobalt	0.000084	-	1.92E-06	0	1.14E-06	7.83E-07	1.29E-05	0	9.26E-06	3.67E-06	5.50E-06	0	1.14E-06	4.36E-06
Dichlorobenzene	0.0012	-	2.75E-05	0	1.63E-05	1.12E-05	1.85E-04	0	1.32E-04	5.24E-05	7.85E-05	0	1.62E-05	6.23E-05
Formaldehyde	0.075	0.048	1.72E-03	4.21E-05	1.05E-03	7.06E-04	1.15E-02	1.03E-05	8.28E-03	3.28E-03	4.91E-03	1.81E-05	1.03E-03	3.90E-03
Hexane	1.8	-	4.12E-02	0	2.45E-02	1.68E-02	2.77E-01	0	1.99E-01	7.86E-02	1.18E-01	0	2.43E-02	9.35E-02
Lead	0.0005	0.00123	1.15E-05	1.08E-06	7.71E-06	4.83E-06	7.70E-05	2.66E-07	5.53E-05	2.20E-05	3.27E-05	4.65E-07	7.20E-06	2.60E-05
Manganese	0.00038	0.00082	8.70E-06	7.20E-07	5.77E-06	3.65E-06	5.85E-05	1.77E-07	4.20E-05	1.67E-05	2.49E-05	3.10E-07	5.43E-06	1.98E-05
Mercury <sup>(g)</sup>	0.00026	0.00041	5.96E-06	3.60E-07	3.84E-06	2.48E-06	4.00E-05	8.86E-08	2.87E-05	1.14E-05	1.70E-05	1.56E-07	3.66E-06	1.35E-05
Naphthalene	0.0061	-	1.40E-05	0	8.29E-06	5.69E-06	9.39E-05	0	6.73E-05	2.66E-05	3.99E-05	0	8.24E-06	3.17E-05
Nickel	0.0021	0.00041	4.81E-05	3.60E-07	2.88E-05	1.96E-05	3.23E-04	8.86E-08	2.32E-04	9.17E-05	1.37E-04	1.55E-07	2.85E-05	1.09E-04
POM	0.000088	0.0033	2.02E-06	2.89E-06	3.64E-06	1.27E-06	1.35E-05	7.11E-07	1.01E-05	4.19E-06	5.76E-06	1.25E-06	2.37E-06	4.64E-06
Selenium	0.000024	0.00206	5.50E-07	1.80E-06	1.85E-06	5.05E-07	3.69E-06	4.43E-07	2.87E-06	1.27E-06	1.57E-06	7.76E-07	1.06E-06	1.29E-06
Toluene	0.0034	-	7.79E-06	0	4.62E-06	3.17E-05	5.23E-04	0	3.75E-04	1.48E-04	2.23E-04	0	4.60E-05	1.77E-04
TOTAL HAPS			4.33E-02	5.08E-05	2.57E-02	1.76E-02	2.91E-01	1.25E-05	2.08E-01	8.24E-02	1.24E-01	2.19E-06	2.65E-02	9.81E-02

For References, see Emission Summary.

Data Reviewed By:

12 Month Rolling Emissions 2008 (Tons)

Pollutant	TSP	PM10	NOx	CO	VOC	SO <sub>2</sub>
Permit Limit (tons/yr) 12-Month Rolling Average	8.4	8.2	60.2	41.3	5.6	7.9
January	1.838	1.796	13.339	9.159	1.239	0.442
February	1.834	1.793	13.308	9.138	1.236	0.442
March	1.836	1.794	13.322	9.148	1.237	0.442
April	1.832	1.791	13.298	9.131	1.235	0.440
May	1.690	1.687	12.856	8.864	1.218	0.151
June	1.770	1.768	13.469	9.286	1.276	0.157
July	1.855	1.852	14.114	9.731	1.337	0.164
August	1.854	1.852	14.108	9.727	1.336	0.164
September	1.837	1.835	13.981	9.640	1.324	0.162
October	1.831	1.829	13.938	9.610	1.320	0.159
November	1.838	1.837	13.999	9.653	1.326	0.158
December	1.846	1.845	14.066	9.699	1.333	0.156

Monthly Emission Totals (Tons)

Pollutant	TSP	PM10	NOx	CO	VOC	SO <sub>2</sub>
January	0.271	0.271	2.066	1.425	0.196	0.023
February	0.221	0.221	1.686	1.163	0.160	0.019
March	0.199	0.199	1.514	1.044	0.143	0.019
April	0.157	0.157	1.199	0.827	0.114	0.013
May	0.118	0.118	0.901	0.622	0.085	0.011
June	0.080	0.080	0.613	0.422	0.058	0.007
July	0.085	0.085	0.646	0.445	0.061	0.007
August	0.058	0.058	0.440	0.303	0.042	0.005
September	0.082	0.082	0.623	0.430	0.059	0.007
October	0.137	0.137	1.046	0.721	0.099	0.011
November	0.183	0.183	1.392	0.960	0.132	0.015
December	0.254	0.254	1.940	1.338	0.184	0.020
Annual Totals	1.846	1.845	14.066	9.699	1.333	0.156

Data Reviewed By: \_\_\_\_\_



Emission Summary TA-3 Power Plant 2008

Pollutant Criteria	Emission Factor		Annual Emissions (Natural Gas + Fuel Oil) (tons)	Jan-June Emissions (Natural Gas + Fuel Oil) (tons)	July-Dec Emissions (Natural Gas + Fuel Oil) (tons)	Reference	
	Natural Gas (lb/MMscf) <sup>a</sup>	Fuel Oil <sup>b</sup> (lb/1000 gal.)				Gas	Oil
NOx	58	8.64	14,066	7,979	6,087	(c)	(a) AP-42, 788, Section 1.4, Natural Gas Combustion Tables 1.4-1, 1.4-2
SOx	0.6	7.4	0.156	0.091	0.065	(a)(j)	(b) Fuel usage obtained from Jerry Gonzales (FWOU). Values are provided in a monthly data deliverable from KSL.
PM	7.6	3.3	1,846	1,048	0.798	(d)	(c) Average of source tests conducted on all 3 boilers September 2002 burning natural gas after FGR installed. Assumed FGR resulted in similar NOx reduction for oil.
PM-10	7.6	2.3	1,845	1,047	0.798	(d)	(d) All PM from natural gas is assumed <1µ, so PM-10, PM-2.5 and total PM have equal EFs, AP-42, Natural Gas Combustion, Table 1.4-2. The PM emission factor for fuel oil is the sum of filterable and condensable PM.
PM-2.5	7.6	1.55	1,844	1,046	0.798	(d)	(e) AP-42, 185, Section 1.4, Natural Gas Combustion, Table 1.4-2. Consistent with previous stack tests.
CO	40	5.0	9,699	5,502	4,197	(b)	(f) AP-42, 988, Section 1.3, Fuel Oil Combustion, Table 1.3-1 with Errata, Table 1.3-3, and Table 1.3-6.
VOC	5.5	0.2	1,333	0.756	0.577	(b)	(g) Boilers-100 MMbtu/hr: SOx Emission Factor (SO <sub>2</sub> {142S} + SO <sub>3</sub> {5.7S}) = 147.7 * S (from AP-42, Table 1.3-1 w/Errata) (S = weight % sulfur in oil)/Sulfur content per analysis on oil in tanks in August 01, no new oil delivered in 02/03)
<b>HAPs<sup>c</sup></b>							
Arsenic	0.0002	0.00055	4.93E-06	2.81E-05	2.11E-05	(a)	(h) HAP emission factors for natural gas from AP-42, Tables 1.4-3 and 1.4-4, for fuel oil from AP-42 Tables 1.3-9 and 1.3-10.
Benzene	0.0021	-	5.09E-04	2.89E-04	2.20E-04	(c)	(i) AP-42, Table 1.4-2, 1.4-3, and 1.4-4, July 1998
Beryllium	0.000012	0.00041	3.51E-06	2.14E-06	1.37E-06	(c)	(j) Assume all SO <sub>3</sub> is converted to sulfuric acid.
Cadmium	0.0011	0.00041	2.67E-04	1.52E-04	1.16E-04	(c)	(k) AP-42, tables 1.3-9 and 1.3-10, September 1998.
Chromium	0.0014	0.00041	3.40E-04	1.93E-04	1.47E-04	(c)	(l) EPCRA PAC Guidance Document, Table 2-3.
Cobalt	0.000084	-	2.04E-05	1.15E-05	8.81E-06	(c)	Reviewed By/Date:
Dichlorobenzene	0.0012	-	2.91E-04	1.66E-04	1.26E-04	(c)	
Formaldehyde	0.075	0.048	1.82E-02	1.04E-02	7.88E-03	(c)	
Hexane	1.8	-	4.36E-01	2.47E-01	1.89E-01	(c)	
Lead	0.0005	0.001233	1.23E-04	7.02E-05	5.28E-05	(c)	
Manganese	0.00038	0.000822	9.33E-05	5.32E-05	4.01E-05	(c)	
Mercury	0.00026	0.000411	6.36E-05	3.62E-05	2.74E-05	(i)(c)	
Naphthalene	0.00061	-	1.48E-04	8.39E-05	6.40E-05	(c)	
Nickel	0.0021	0.000411	5.09E-04	2.89E-04	2.20E-04	(c)	
POM	0.000088	0.0033	2.62E-05	1.61E-05	1.01E-05	(c)	
Selenium	0.00024	0.002055	8.83E-06	5.78E-06	3.06E-06	(c)	
Toluene	0.0034	-	8.24E-04	4.67E-04	3.57E-04	(c)	
<b>TOTAL HAPS</b>			<b>4.58E-01</b>	<b>2.60E-01</b>	<b>1.98E-01</b>		
<b>EPCRA 313</b>				<b>lbs./year</b>			
Lead	0.0005	0.00123	1.23E-04	0.246		(c)	
Sulfuric Acid	0.60	0.285	1.46E-01	29.159		(e)(j)	
Mercury	0.00026	0.00041	6.36E-05	0.127		(c)	
PACs	8.69E-07	1.65E-05	2.35E-07	4.70E-04		(f)(i)	
Benze(g,h,i) perylene	1.20E-06	2.26E-06	2.94E-07	5.88E-04		(i)(k)(c)	
Zinc	-	0.00055	8.05E-07	1.61E-03		(k)	



# **Attachment B**

*2008 Annual Emissions Inventory Submittal to NMED*





*Environmental Protection Division*  
P.O. Box 1663, MS J978  
Los Alamos, New Mexico 87545  
(505) 667-2211/FAX: (505) 665-8858

Date: April 28, 2009  
Refer to: ENV-DO:09-007

Ms. Rhonda Payne  
New Mexico Environment Department  
Air Quality Bureau  
1301 Siler Rd. Bld. B  
Santa Fe, NM 87507

**SUBJECT: IDEA ID NO. 856 – LOS ALAMOS NATIONAL LABORATORY  
2008 EMISSIONS INVENTORY REPORT REQUIRED UNDER  
20.2.73 NMAC**

Dear Ms. Payne:

Enclosed is the 2008 Emissions Inventory Update for Los Alamos National Laboratory (LANL or Laboratory), required by Title 20, Chapter 2, Part 73 of the New Mexico Administrative Code (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements and has been submitted before New Mexico Environmental Department's revised deadline of May 1<sup>st</sup>. Additionally, this report satisfies LANL's reporting requirement under 20.2.87 NMAC, Greenhouse Gas Emissions Reporting.

We have updated the Excel worksheets that you provided, using the guidance in your instructions for the *2008 New Mexico Emissions Inventory Update*. All changes made to the worksheets are highlighted in yellow (additions).

In general, criteria pollutant emissions from LANL sources in 2008 are similar to emissions reported last year. Additionally, please note the following for our inventory for 2008:

- Three emission units were added this year: two 20 KW Kohler 20EORZ generators (EQPT 119, EQPT 120) at TA-33 and a 225 KW Caterpillar 3306 generator (EQPT 122) also at TA-33.
- Per NMED request, we have included direct CO<sub>2</sub> emissions from stationary combustion sources in tons per year. Additionally, we included a separate Excel workbook as an attachment that includes example calculations for all unique subject item types.

Ms. Rhonda Payne  
ENV-DO:09-007  
LA-UR: 09-02567

-2-

April 28, 2009

- Two Equipment IDs were added to account for the boilers and generators not required on the Emissions Inventory report, but required for the Greenhouse Gas Emissions report. These Equipment IDs do not include criteria pollutant emissions. EQPT 139 represents approximately 40 generators and EQPT 140 represents approximately 160 boilers.
- Emissions of radionuclides, other than radon, from Laboratory operations, as reported to EPA under 40 CFR 61 Subpart H, resulted in a maximum offsite dose of 0.52 mrem during 2007. For 2008, this offsite dose is estimated to be <1 mrem. A final dose for 2008 will be reported to EPA in June 2009.

This submittal includes a diskette (Attachment 1) containing electronic copies of the updated spreadsheets and a signed certification statement (Attachment 2).

If you have any questions regarding this report, please contact Steve Story (665-2169) or Walt Whetham (665-8885), in the Laboratory's Ecology and Air Quality Group.

Sincerely,



Victoria A. George  
Division Leader  
Environmental Protection Division

VAG:tav

Enc: a/s

Cy:

M. Mallory, PADOPS, w/o enc., A102  
C. Cantwell, ADESH&Q, w/o enc., K491  
S. Fong, DOE-LA-SO, w/o enc., A316  
P. Wardwell, LC-ESH, w/o enc., A187  
D. Wilburn, ENV-EAQ, w/o enc., J978  
D. Janecky, ENV-EAQ, w/o enc., J978  
S. Story, ENV-EAQ, w/o enc., J978  
M. Stockton, ENV-EAQ, w/o enc., J978  
D. Fuehne, ENV-EAQ, w/o enc., J978  
W. Whetham, ENV-EAQ, w/o enc., J978  
IRM-RM550, w/o enc., A150  
ENV-DO File  
ENV-EAQ Emissions Inventory File  
ENV-EAQ File

LA-UR-09-02567

Approved for public release;  
distribution is unlimited.

*Title:* 2008 Emissions Inventory Report

*Author(s):* Walter Whetham

*Intended for:* Rhonda Payne, New Mexico Environmental Department




Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

Form 836 (7/06)

**2008 Emissions Inventory Certification**

I, Victoria A. George, hereby certify on behalf of Los Alamos National Security, LLC (LANS), that the information and data submitted in the 2007 Emissions Inventory for Los Alamos National Laboratory with Permit Number P100M2 (IDEA/Tempo ID No. 856) are as complete, true and accurate as possible, to the best of my personal knowledge and professional expertise and experience.


Signed this twenty-eighth day of April, 2009, upon my oath of affirmation, before a notary of the State of New Mexico.

  
SIGNATURE (Responsible Company Official)      4/28/09 DATE      505-667-2211 PHONE

Victoria A. George      Division Leader      LANS  
PRINTED NAME      TITLE      COMPANY

Subscribed and sworn to before me on this 28<sup>th</sup> day of April, 2009.

My authorization as a Notary of the State of New Mexico expires on the 10<sup>th</sup> day of April, ~~20~~ 2010.

  
NOTARY'S SIGNATURE      4-28-09 DATE

Taylor Valdez  
NOTARY'S PRINTED NAME      NOTARY SEAL



856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	AQB-State/Local ID	006	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Operating Time in Hours Per Day	5	h/d
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Operating Time in Days Per Week	5	dw/week
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Operating Time in Weeks Per Year	52	h/y
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Operating Time in Hours Per Year	1300	h/y
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Input Materials Processed	516	Metal
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Standard Classification (S.C.C) Code	30903004	Industrial Processes, Fabricated Metal Products, Machining Operations, Specify Material**
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Beryllium in tons per year	1.98E-08	tons/y
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Beryllium calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Beryllium Actual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1-250F	99.95	percent
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Particulate Matter (total suspended) in tons per year	1.98E-08	tons/y
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Actual Particulate Matter (total suspended) calculation method	2	Engineer Calculation
856	Los Alamos National Laboratory	350280001	TA-35-213	Be Machining Ta35 Bldg213	Particulate Matter (total suspended) Actual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1-250F	99.95	percent

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	AQB-S later/Local ID	007	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Percent of Operation During Fall	24	h/d
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Operating Time in Weeks Per Year	52	weekly
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Operating Time in Hours Per Year	8760	h/y
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Input Materials Processed	516	Metal
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Standard Classification (SCC) Code	30903004	Industrial Processes, Fabricated Metal Products, Machining Operations, Specify Material**
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Beryllium in tons per year	7.71E-09	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Beryllium calculation method	1	Continuous Emissions Monitoring
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Beryllium actual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1-250F	99.95	percent
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Particulate Matter (total suspended) in tons per year	7.71E-09	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Particulate Matter (total suspended) calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	TA-3-141	Be Machining Ta3 Bldg 141	Actual Particulate Matter (total suspended) actual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1-250F	99.95	percent

856	Los Alamos National Laboratory	350280001	TA-55-PF4 (e)	Machining Operations: Beryllium machining, weld dressing and metallography	010	Not Applicable	3
					Actual Percent of Operation During Winter	percent of time	1G
					Actual Percent of Operation During Spring	percent of time	1G
					Actual Percent of Operation During Summer	percent of time	1G
					Actual Percent of Operation During Fall	percent of time	1G
					Actual Operating Time in Hours Per Day	hr/d	8
					Actual Operating Time in Days Per Week	days/week	7
					Actual Operating Time in Weeks Per Year	weeks/yr	52
					Actual Operating Time in Hours Per Year	hr/yr	2912
					Actual Input Materials Processed	Metal	17
					Standard Classification (SCC) Code	Industrial Processes, Fabricated Metal Products, Machining Operations, Specify Material**	20
					Actual Aluminum in tons per year	tons/yr	21
					Actual Aluminum calculation method	EPA emission factors (e.g., AP-42)	22
					Aluminum/Actual total efficiency controlled by		
					Fabric Filter/Medium Temp ie 180F-1250F	percent	23
					Actual Beryllium in tons per year	tons/yr	24
					Actual Beryllium calculation method	EPA emission factors (e.g., AP-42)	25
					Beryllium/Actual total efficiency controlled by		
					Fabric Filter/Medium Temp ie 180F-1250F	percent	26



Facility	Activity	Unit	CO2	CH4	N2O	HFC	PFC	SF6	Other	Total
05	05	05	0	0	0	0	0	0	0	0
06	06	06	0	0	0	0	0	0	0	0
07	07	07	0	0	0	0	0	0	0	0
08	08	08	0	0	0	0	0	0	0	0
09	09	09	0	0	0	0	0	0	0	0
10	10	10	0	0	0	0	0	0	0	0
11	11	11	0	0	0	0	0	0	0	0
12	12	12	0	0	0	0	0	0	0	0
13	13	13	0	0	0	0	0	0	0	0
14	14	14	0	0	0	0	0	0	0	0
15	15	15	0	0	0	0	0	0	0	0
16	16	16	0	0	0	0	0	0	0	0
17	17	17	0	0	0	0	0	0	0	0
18	18	18	0	0	0	0	0	0	0	0
19	19	19	0	0	0	0	0	0	0	0
20	20	20	0	0	0	0	0	0	0	0
21	21	21	0	0	0	0	0	0	0	0
22	22	22	0	0	0	0	0	0	0	0
23	23	23	0	0	0	0	0	0	0	0
24	24	24	0	0	0	0	0	0	0	0
25	25	25	0	0	0	0	0	0	0	0
26	26	26	0	0	0	0	0	0	0	0
27	27	27	0	0	0	0	0	0	0	0
28	28	28	0	0	0	0	0	0	0	0
29	29	29	0	0	0	0	0	0	0	0
30	30	30	0	0	0	0	0	0	0	0
31	31	31	0	0	0	0	0	0	0	0
32	32	32	0	0	0	0	0	0	0	0
33	33	33	0	0	0	0	0	0	0	0
34	34	34	0	0	0	0	0	0	0	0
35	35	35	0	0	0	0	0	0	0	0
36	36	36	0	0	0	0	0	0	0	0
37	37	37	0	0	0	0	0	0	0	0
38	38	38	0	0	0	0	0	0	0	0
39	39	39	0	0	0	0	0	0	0	0
40	40	40	0	0	0	0	0	0	0	0
41	41	41	0	0	0	0	0	0	0	0
42	42	42	0	0	0	0	0	0	0	0
43	43	43	0	0	0	0	0	0	0	0
44	44	44	0	0	0	0	0	0	0	0
45	45	45	0	0	0	0	0	0	0	0
46	46	46	0	0	0	0	0	0	0	0
47	47	47	0	0	0	0	0	0	0	0
48	48	48	0	0	0	0	0	0	0	0
49	49	49	0	0	0	0	0	0	0	0
50	50	50	0	0	0	0	0	0	0	0
51	51	51	0	0	0	0	0	0	0	0
52	52	52	0	0	0	0	0	0	0	0
53	53	53	0	0	0	0	0	0	0	0
54	54	54	0	0	0	0	0	0	0	0
55	55	55	0	0	0	0	0	0	0	0
56	56	56	0	0	0	0	0	0	0	0
57	57	57	0	0	0	0	0	0	0	0
58	58	58	0	0	0	0	0	0	0	0
59	59	59	0	0	0	0	0	0	0	0
60	60	60	0	0	0	0	0	0	0	0
61	61	61	0	0	0	0	0	0	0	0
62	62	62	0	0	0	0	0	0	0	0
63	63	63	0	0	0	0	0	0	0	0
64	64	64	0	0	0	0	0	0	0	0
65	65	65	0	0	0	0	0	0	0	0
66	66	66	0	0	0	0	0	0	0	0
67	67	67	0	0	0	0	0	0	0	0
68	68	68	0	0	0	0	0	0	0	0
69	69	69	0	0	0	0	0	0	0	0
70	70	70	0	0	0	0	0	0	0	0
71	71	71	0	0	0	0	0	0	0	0
72	72	72	0	0	0	0	0	0	0	0
73	73	73	0	0	0	0	0	0	0	0
74	74	74	0	0	0	0	0	0	0	0
75	75	75	0	0	0	0	0	0	0	0
76	76	76	0	0	0	0	0	0	0	0
77	77	77	0	0	0	0	0	0	0	0
78	78	78	0	0	0	0	0	0	0	0
79	79	79	0	0	0	0	0	0	0	0
80	80	80	0	0	0	0	0	0	0	0
81	81	81	0	0	0	0	0	0	0	0
82	82	82	0	0	0	0	0	0	0	0
83	83	83	0	0	0	0	0	0	0	0
84	84	84	0	0	0	0	0	0	0	0
85	85	85	0	0	0	0	0	0	0	0
86	86	86	0	0	0	0	0	0	0	0
87	87	87	0	0	0	0	0	0	0	0
88	88	88	0	0	0	0	0	0	0	0
89	89	89	0	0	0	0	0	0	0	0
90	90	90	0	0	0	0	0	0	0	0
91	91	91	0	0	0	0	0	0	0	0
92	92	92	0	0	0	0	0	0	0	0
93	93	93	0	0	0	0	0	0	0	0
94	94	94	0	0	0	0	0	0	0	0
95	95	95	0	0	0	0	0	0	0	0
96	96	96	0	0	0	0	0	0	0	0
97	97	97	0	0	0	0	0	0	0	0
98	98	98	0	0	0	0	0	0	0	0
99	99	99	0	0	0	0	0	0	0	0
100	100	100	0	0	0	0	0	0	0	0

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	AOB-State/Local ID	007	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Operating Time in Hours Per Day	0	hr/d
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Operating Time in Weeks Per Year	0	weeks/yr
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Operating Time in Hours Per Year	0	hr/yr
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Input Materials Processed		percent
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	TA-3-29	Removed-Chemistry & Metallurgy Research Facility	Standard Classification (S,CC) Code	30903004	Industrial Processes, Fabricated Metal Products, Machining Operations, Specify Material**

856	Los Alamos National Laboratory	350280001	Agency Interest	TA-33 Tech Rev to modify recordkeeping requirement	Standard Industrial Classification (SIC) Code	9711	National security
856	Los Alamos National Laboratory	350280001	Agency Interest	TA-33 Tech Rev to modify recordkeeping requirement	North American Industry Classification (NAIC) Code	92811	National Security

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent of Operation During Winter	20	percent of time	1G	4
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent of Operation During Spring	30	percent of time	1G	5
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent of Operation During Summer	30	percent of time	1G	6
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent of Operation During Fall	20	percent of time	1G	7
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Operating Time in Hours Per Day	12	hr/d	23	8
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Operating Time in Days Per Week	7	dw/week	X6	9
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Operating Time in Weeks Per Year	52	weekly	ZD	10
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Operating Time in Hours Per Year	4368	hr/y	HR	11
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Fuel Consumption				12
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Fuel Heating Value				13
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Fuel Type				14
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent Sulfur of Fuel				15
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent Ash of Fuel				16
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Input Materials Processed	15	Wood		17
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Percent Carbon				19
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Standard Classification (SCC) Code	30703096	Industrial Processes, Pulp and Paper and Wood Products, Miscellaneous Wood Working Operations,		20
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (10 microns or less) in tons per year	0.016	tons/y	TY	21
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (10 microns or less) calculation method controlled by Single Cyclone	ap	EP A emission factors (eg., AP-42)		22
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (2.5 microns or less) in tons per year	65	percent	1G	23
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (2.5 microns or less) calculation method controlled by Single Cyclone	ap	EP A emission factors (eg., AP-42)		25
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (total suspended) in tons per year	45	percent	1G	26
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (total suspended) calculation method controlled by Single Cyclone	ap	EP A emission factors (eg., AP-42)		27
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Particulate Matter (total suspended) calculation method controlled by Single Cyclone	ap	EP A emission factors (eg., AP-42)		28
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Volatile Organic Compounds (VOC) in tons per year	95	percent	1G	29
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Volatile Organic Compounds (VOC) calculation method	0	tons/y	TY	30
856	Los Alamos National Laboratory	350280001	TA-3-38	Carpenter Shop - General Construction	Actual Volatile Organic Compounds (VOC) calculation method	2	Engineer Calculation		31



856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent of Operation During Winter	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent of Operation During Spring	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent of Operation During Summer	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent of Operation During Fall	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Operating Time in Hours Per Day	12	hr/d
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Operating Time in Days Per Week	7	dw/week
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Operating Time in Weeks Per Year	52	weeks/y
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Operating Time in Hours Per Year	4368	hr/y
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Fuel Consumption		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Fuel Heating Value		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Fuel Type		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent Sulfur of Fuel		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent Ash of Fuel		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Input Materials Processed		
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Percent Carbon	15	wood
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Standard Classification (SCC) Code	30703066	Industrial Processes, Pulp and Paper and Wood Products, Miscellaneous Wood Working Operations, Sanding/Planning Operations: Specify
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Particulate Matter (10 microns or less) calculation method	0.027	tons/y
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Particulate Matter (2.5 microns or less) calculation method	0.013	tons/y
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Particulate Matter (total suspended) calculation method	0.03	tons/y
856	Los Alamos National Laboratory	350280001	TA-15-563	Carpenter Shop - Test Stands	Actual Particulate Matter (total suspended) calculation method		Design calculation

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	AOB-State/Local ID	011	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Percent of Operation During Winter		percent of time
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Percent of Operation During Spring		percent of time
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Percent of Operation During Summer		percent of time
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Percent of Operation During Fall		percent of time
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Operating Time in Hours Per Day		hd
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Operating Time in Days Per Week		dweek
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Operating Time in Weeks Per Year		weeks/yr
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Operating Time in Hours Per Year		hr
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Standard Classification (SCC) Code	30900303	Industrial Processes, Fabricated Metal Products, Abrasive Cleaning of Metal Parts, Polishing
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Aluminum in tons per year		tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Aluminum calculation method		Estimate
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	AluminumActual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1<-250F		percent
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Beryllium in tons per year		tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	Actual Beryllium calculation method		Estimate
856	Los Alamos National Laboratory	350280001	TA-3-66	Sigma Facility-electroplating/metallography	BerylliumActual total efficiency controlled by Fabric Filter-Medium Temp ie 180F-1<-250F		percent

856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Carbon Dioxide Vented in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Carbon Monoxide Vented in tons per year	0.36	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Hexane in tons per year	0.008	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Nitrogen Dioxide in tons per year	0.43	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (10 microns or less) in tons per year	0.033	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (2.5 microns or less) in tons per year	0.033	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (total suspended) in tons per year	0.033	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Sulfur Dioxide in tons per year	0.003	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Volatile Organic Compounds (VOC) in tons per year	0.024	tons/yr
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-1	Boiler (TA-48-1) BS-1	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A OB- State/Local ID	016	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Operating Time in Hours Per Week	24	h/d
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Operating Time in Weeks Per Year	7	d/week
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Operating Time in Hours Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Fuel Consumption	5544	h/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Fuel Heating Value	8.6	MMSCF/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Fuel Type	1049	MMBTU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	Standard Classification (SCC) Code	10300602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers <100 Million Btu/yr except Tangential
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide in tons per year	479	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide Combusted in tons per year	479	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Monoxide in tons per year	0.36	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Hexane in tons per year	0.008	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Nitrogen Dioxide in tons per year	0.43	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (10 microns or less) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (2.5 microns or less) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (total suspended) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Sulfur Dioxide in tons per year	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Volatile Organic Compounds (VOC) in tons per year	0.024	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, B S2	Boiler (Ta-48-1) B s-2	A actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	AQB-State/Local ID	017	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Operating Time in Hours Per Year	5544	h/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Fuel Consumption	11.5	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Fuel Heating Value	1049	MM BTU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent Sulfur of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Standard Classification (SCC) Code	10300602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide in tons per year	641	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide Combusted in tons per year	641	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Dioxide Vented calculation method	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Monoxide in tons per year	0.48	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Formaldehyde in tons per year	0.0004	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Formaldehyde calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Hexane in tons per year	0.01	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Nitrogen Dioxide in tons per year	0.58	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (10 microns or less) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (2.5 microns or less) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (total suspended) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Sulfur Dioxide in tons per year	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Volatile Organic Compounds (VOC) in tons per year	0.032	tons/y
856	Los Alamos National Laboratory	350280001	TA-48-1, BS-6	Boiler (Ta-48-1) Bs-6	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	AQB-Statel/Local ID	018	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Operating Time in Weeks Per Year	33	weekly
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Operating Time in Hours Per Year	5544	h/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Fuel Consumption	11.48	MMSCF/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Fuel Heating Value	1049	MMBTU/MMSCF
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Standard Classification (SCC) Code	10300602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers <100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide in tons per year	638.8	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide Combusted in tons per year	638.8	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Monoxide in tons per year	0.48	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Formaldehyde in tons per year	0.0004	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Formaldehyde calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Hexane in tons per year	0.01	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Nitrogen Dioxide in tons per year	0.57	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (10 microns or less) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (2.5 microns or less) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (total suspended) in tons per year	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Sulfur Dioxide in tons per year	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Volatile Organic Compounds (VOC) in tons per year	0.032	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, BHW-1	Boiler (Ta-53-365) Bhw-1	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	AQB-Statel/Local ID	019	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Operating Time in Hours Per Year	5544	h/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Fuel Consumption	11.5	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Fuel Heating Value	1049	MMBTU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Standard Classification (SCC) Code	10300602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Dioxide in tons per year	638.8	<100 Million Btu/hr except Tangential tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Dioxide Combusted in tons per year	638.8	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Dioxide Vented calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Monoxide calculation method	0.48	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Monoxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Carbon Monoxide calculation method	0.0004	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Formaldehyde in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Formaldehyde calculation method	0.01	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Hexane in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Hexane calculation method	0.57	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Nitrogen Dioxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Nitrogen Dioxide calculation method	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (10 microns or less) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (10 microns or less) calculation method	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (2.5 microns or less) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (2.5 microns or less) calculation method	0.044	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (total suspended) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Particulate Matter (total suspended) calculation method	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Sulfur Dioxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Sulfur Dioxide calculation method	0.032	tons/y
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Volatile Organic Compounds (VOC) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-53-365, B HW2	Boiler (Ta-53-365) B hw-2	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	AQB-State/Local ID	020	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Operating Time in Hours Per Day	24	hr/d
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Operating Time in Hours Per Year	5544	hr/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Fuel Consumption	8.6	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Fuel Heating Value	1049	MMBTU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Fuel Type		Natural Gas
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-1	Boiler (Ta-59-1) Bhw-1	Actual Percent Carbon	68	percent
					External Combustion Boilers, Electric Generation, Natural Gas, Boilers <100 Million Btu/hr except Tangential	10300602	Million Btu/hr except Tangential
						479	tons/y
					Standard Classification (SCC) Code	pr	Other Publication Reference
					Actual Carbon Dioxide in tons per year	479	tons/y
					Actual Carbon Dioxide Combusted in tons per year	pr	Other Publication Reference
					Actual Carbon Dioxide Combusted calculation method	0	tons/y
					Actual Carbon Dioxide Vented in tons per year		
					Actual Carbon Dioxide Vented calculation method		
					Actual Carbon Monoxide in tons per year	0.36	tons/y
					Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Hexane in tons per year	0.008	tons/y
					Actual Hexane calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Nitrogen Dioxide in tons per year	0.43	tons/y
					Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Particulate Matter (10 microns or less) in tons per year	0.033	tons/y
					Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Particulate Matter (2.5 microns or less) in tons per year	0.033	tons/y
					Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Particulate Matter (total suspended) in tons per year	0.033	tons/y
					Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Sulfur Dioxide in tons per year	0.003	tons/y
					Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g. AP-42)
					Actual Volatile Organic Compounds (VOC) in tons per year	0.024	tons/y
					Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g. AP-42)



856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	AQB-Statel/Local ID	021	Ndt, Applicable
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Operating Time in Hours Per Year	5544	hy
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Fuel Heating Value	8.6	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Fuel Type	1049	MM BTU/MMSCF
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Standard Classification (SCC) Code	10100602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide in tons per year	479	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide Combusted in tons per year	479	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Monoxide in tons per year	0.36	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Hexane in tons per year	0.008	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Nitrogen Dioxide in tons per year	0.43	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (10 microns or less) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (2.5 microns or less) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (total suspended) in tons per year	0.033	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Sulfur Dioxide in tons per year	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Volatile Organic Compounds (VOC) in tons per year	0.024	tons/y
856	Los Alamos National Laboratory	350280001	TA-59-1,BHW-2	Boiler (Ta-59-1) Bhw-2	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	AQB-State/Local ID	026	Not Applicable
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Operating Time in Hours Per Day	0	h/d
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Operating Time in Hours Per Year	0	h/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Fuel Consumption		MM SCF/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Input Materials Processed		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Standard Classification (SCC) Code	30502501	Mineral Products, Construction Sand and Gravel, Total Plant: General
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide Combusted in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide Combusted calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide Ventd in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Dioxide Ventd calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Monoxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Carbon Monoxide calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Carbon Monoxide/Actual total efficiency controlled by Water Sprays		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Nitrogen Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Nitrogen Dioxide calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Nitrogen Dioxide/Actual total efficiency controlled by Water Sprays		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Particulate Matter (10 microns or less) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Particulate Matter (10 microns or less) calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Particulate Matter (10 microns or less)/Actual total efficiency controlled by Water Sprays		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Particulate Matter (total suspended) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Particulate Matter (total suspended) calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Particulate Matter (total suspended)/Actual total efficiency controlled by Water Sprays		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Sulfur Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Sulfur Dioxide calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Sulfur Dioxide/Actual total efficiency controlled by Water Sprays		percent
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Actual Volatile Organic Compounds (VOC) calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	026	Removed-Rock Crusher	Volatile Organic Compounds (VOC)/Actual total efficiency controlled by Water Sprays		percent

856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	ACB, State/Local ID	027	Not Applicable
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Operating Time in Hours Per Day	0	hr/d
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Operating Time in Hours Per Year	0	hr/y
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Input Materials Processed		Paper
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Percent Caibon		percent
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Standard Classification (SCC) Code		Industrial Processes, Pulp and Paper and Wood Products, Miscellaneous
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (10 microns or less) in tons per year		Paper Products, Other Not Classified
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (10 microns or less) calculation method		tons/y
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Particulate Matter (10 microns or less) actual total efficiency controlled by Single Cyclone, Baghouse		Engineer Calculation
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (2.5 microns or less) in tons per year		percent
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (2.5 microns or less) calculation method		tons/y
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Particulate Matter (2.5 microns or less) actual total efficiency controlled by Single Cyclone, Baghouse		Engineer Calculation
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (total suspended) in tons per year		percent
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Actual Particulate Matter (total suspended) calculation method		tons/y
856	Los Alamos National Laboratory	350280001	027	Removed, Paper Shredder	Particulate Matter (total suspended) actual total efficiency controlled by Single Cyclone, Baghouse		Engineer Calculation

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	AOB- State/Local ID	028	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Operating Time in Hours Per Day	4	hr/d
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Operating Time in Days Per Week	1	d/week
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Operating Time in Weeks Per Year	52	weeks/y
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Operating Time in Hours Per Year	208	h/y
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Input Materials Processed	962	Solvents: All
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Standard Classification (SCC) Code		Petroleum and Solvent Evaporation, Organic
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual TCE (Trichloroethylene) in tons per year	40100255	Solvent Evaporation, Degreasing,
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Actual TCE (Trichloroethylene), (Trichloroethylene) calculation method	0.015	Trichloroethylene: General Degreasing Units
856	Los Alamos National Laboratory	350280001	TA-55-DG-1	Degreaser - Cold Ultrasonic Bath	Ta-55-4	Material balance	mb	tons/y

856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	AQB-Statelocal ID	028	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Percent of Operation During Fall	0	hd
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Operating Time in Hours Per Day	0	dweek
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Operating Time in Weeks Per Week	0	weeks/y
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Operating Time in Hours Per Year	0	hy
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Input Materials Processed		percent
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual Percent Carbon		Petroleum and Solvent Evaporation, Organic Solvent Evaporation, Degreasing, Trichloroethylene, General Degreasing Units
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Standard Classification (SCC) Code	40100255	0
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual TCE: (Trichloroethylene) in tons per year		tons/y
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	Actual TCE: (Trichloroethylene) calculation method		Estimate
856	Los Alamos National Laboratory	350280001	TA-55-D-G-2	Degreaser - Cold Ultrasonic Bath Ts-46-24	TCE: (Trichloroethylene), (Trichloroethylene) Actual total efficiency controlled by Uncontrolled		percent

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	AOB- State/Local ID	030	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Operating Time in Hours Per Day	0	h/d
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Operating Time in Weeks Per Year	0	weeks/yr
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Operating Time in Hours Per Year	0	h/yr
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Input Materials Processed	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual Percent Carbon	0	percent
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Standard Classification (SCC) Code	40100255	Petroleum and Solvent Evaporation, Organic Solvent Evaporation, Degreasing, Trichloroethylene, General Degreasing Units
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual TCE: (Trichloroethylene), (Trichloroethene) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	Actual TCE: (Trichloroethylene), (Trichloroethene) calculation method	es	Estimate
856	Los Alamos National Laboratory	350280001	TA-46-24	Degreaser - inhouse Cold Batch Ta-46-24	TCE: (Trichloroethylene), (Trichloroethene)Actual total efficiency controlled by Uncontrolled		percent

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	AQB:State/Local ID	032	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Winter	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Summer	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Fall	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Days Per Week	7	diweek
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Weeks Per Year	52	weekly
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Hours Per Year	8760	hy
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Consumption	45.8	MMSCF/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Heating Value	1049	MMBTU/MMSCF
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Standard Classification (SCC) Code	10100601	External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide in tons per year	2550	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Combusted in tons per year	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Ventilated in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Ventilated calculation method	0.92	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide calculation method	0.002	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Formaldehyde in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Hexane in tons per year	0.04	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide in tons per year	1.33	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Nitrogen Dioxide/Actual total efficiency controlled by Flue Gas Recirculation	64	percent
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) in tons per year	0.174	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) in tons per year	0.174	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide in tons per year	0.014	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Toluene (Methyl benzene) in tons per year	0.00008	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Toluene (Methyl benzene) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) in tons per year	0.13	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-224	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Standard Classification (SCC) Code	10100601	External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide in tons per year	17135.7	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Combusted in tons per year	17135.7	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Vented in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide in tons per year	6.16	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Formaldehyde in tons per year	0.01	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Formaldehyde calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Hexane in tons per year	0.28	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide in tons per year	8.93	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Nitrogen Dioxide Actual total efficiency controlled by Flue Gas Recirculation	64	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) in tons per year	1.17	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) in tons per year	1.17	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) in tons per year	1.17	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide in tons per year	0.09	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) in tons per year	0.85	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)



856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	AQB-State/Local ID	034	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Winter	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Summer	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent of Operation During Fall	24	h/d
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Hours Per Day	7	d/week
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Weeks Per Year	52	weeks/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Operating Time in Hours Per Year	8760	h/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Consumption	130.9	MMSCFY
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Heating Value	1049	MMBTU/MMSCF
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Fuel Type	0.006	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent Sulfur of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent Ash of Fuel	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Input Materials Processed	68	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Percent Carbon		External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Standard Classification (SCC) Code	10100601	
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide in tons per year	7286.1	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Combusted in tons per year	pr	7286.1 tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Vented calculation method	0	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Vented in tons per year		tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Dioxide Vented calculation method		tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide in tons per year	2.62	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Formaldehyde in tons per year	0.005	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Formaldehyde calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Hexane in tons per year	0.12	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Hexane calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide in tons per year	3.8	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Nitrogen Dioxide calculation method	64	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Nitrogen Dioxide/Actual total efficiency controlled by Flue Gas Recirculation		
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) in tons per year	0.5	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) in tons per year	0.5	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) in tons per year	0.5	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide in tons per year	0.039	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) in tons per year	0.36	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	AQB-State/Local ID	035	Not Applicable
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Operating Time in Weeks Per Year	52	weeks/y
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Operating Time in Hours Per Year	8760	h/y
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Fuel Consumption	2939	gal/y
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Input Materials Processed	58	Distillate Oil (No. 2)
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Standard Classification (SCC) Code	39090004	Industrial Processes, In-process Fuel Use, Fuel Storage - Fixed Roof Tanks,
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0.007	Distillate Oil (No. 2): Working Loss tons/y
856	Los Alamos National Laboratory	350280001	T-3-026	Tank (No. 2 Fuel Oil)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	AQB-State/Local ID	036	Not Applicable
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Winter	30	percent of time
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Summer	20	percent of time
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Percent of Operation During Fall	30	percent of time
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Operating Time in Weeks Per Year	52	weeks/y
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Operating Time in Hours Per Year	8760	h/y
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Fuel Consumption	2939	gally
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Input Materials Processed	58	Distillate Oil (No. 2)
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Standard Classification (SCC) Code	39090004	Industrial Processes, In-process Fuel Use, Fuel Storage - Fixed Roof Tanks,
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0.033	Distillate Oil (No. 2): Working Loss tons/y
856	Los Alamos National Laboratory	350280001	T-3-779	Tank (No. 2 Fuel Oil)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A QB - State/Local ID	037	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Operating Time in Hours Per Day	24	h/d
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Operating Time in Hours Per Year	5544	h/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Fuel Consumption	15.0	MMSCF/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Fuel Heating Value	1049	MMB T U M M S C F
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent Sulfur of Fuel	0.006	P percent
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent Ash of Fuel	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Input Materials Processed	68	percent
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Percent Carbon	10100602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100 Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	Standard Classification (SCC) Code	835.5	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide in tons per year	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide Combusted in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide Combusted calculation method	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide Vented in tons per year	11	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Dioxide Vented calculation method	0.29	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Monoxide in tons per year	0.014	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Hexane in tons per year	1.04	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Hexane calculation method	st	A actual stack test
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Nitrogen Dioxide in tons per year	0.11	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Nitrogen Dioxide calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (10 microns or less) in tons per year	0.11	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (10 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (2.5 microns or less) in tons per year	0.11	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (2.5 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (total suspended) in tons per year	0.005	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Sulfur Dioxide in tons per year	0.045	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Sulfur Dioxide calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Volatile Organic Compounds (VOC) in tons per year	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler B h w - 1 b (TA 55-6, B l d g, P F6)	A actual Volatile Organic Compounds (VOC) calculation method		

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	AQB-State/Local ID	038	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent of Operation During Winter	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent of Operation During Fall	40	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Operating Time in Hours Per Day	7	hd
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Operating Time in Weeks Per Year	33	weeks/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Operating Time in Hours Per Year	5544	hy
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Fuel Consumption	7.2	MMSCF/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Fuel Heating Value	1049	MMB TU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Fuel Type	0.006	Natural Gas Percent
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent Sulfur of Fuel	209	Natural Gas percent
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent Ash of Fuel		percent
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Input Materials Processed		Ex-ternal Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Percent Carbon	10100602	Million Btu/hr except Tangential
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Standard Classification (SCC) Code	401.6	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide in tons per year	401.6	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide calculation method		Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide Combusted in tons per year	401.6	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide Combusted calculation method		Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Dioxide Vented calculation method		tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Monoxide in tons per year	0.14	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Monoxide calculation method		Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Carbon Monoxide calculation method	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Formaldehyde in tons per year	0.006	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Hexane in tons per year	0.006	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Hexane calculation method		EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Lead in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Lead calculation method		Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Nitrogen Dioxide in tons per year	0.50	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Nitrogen Dioxide calculation method		Actual stack test
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (10 microns or less) in tons per year	0.051	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (10 microns or less) calculation method		Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (2.5 microns or less) in tons per year	0.051	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (2.5 microns or less) calculation method		Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (total suspended) in tons per year	0.051	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Particulate Matter (total suspended) calculation method		Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Sulfur Dioxide in tons per year	0.002	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Sulfur Dioxide calculation method		EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Volatile Organic Compounds (VOC) in tons per year	0.022	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF6	Sellers Boiler Bhw-2x(TA 55-6, Bldg. PF6)	Actual Volatile Organic Compounds (VOC) calculation method		Manufacturer Specification

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	AOB-State/Local ID	024	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Operating Time in Hours Per Day	0	h/d
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Operating Time in Hours Per Year	0	h/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Fuel Consumption		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Fuel Heating Value		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Fuel Type		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent Sulfur of Fuel		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent Ash of Fuel		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Input Materials Processed		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Percent Carbon		
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Standard Classification (SCC) Code	10300603	External Combustion Boilers, Commercial/Institutional, Natural Gas, < 10 Million Btu/hr
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide Combusted in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide Combusted calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Dioxide Vented calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Monoxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Carbon Monoxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Lead in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Lead calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Nitrogen Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Nitrogen Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (10 microns or less) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (10 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (2.5 microns or less) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (2.5 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (total suspended) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Particulate Matter (total suspended) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Sulfur Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Sulfur Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-B-S-2	Low NOx Boiler TA-16-1484-B-S-2	Actual Volatile Organic Compounds (VOC) calculation method	dc	Design calculation

856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent of Operation During Spring	50	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Operating Time in Hours Per Day	4	h/d
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Operating Time in Days Per Week	1	d/week
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Operating Time in Weeks Per Year	12	weeks/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Operating Time in Hours Per Year	25	h/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Fuel Consumption	37	M gally
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Fuel Heating Value	139	MM BTU/M gal
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Fuel Type	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent Sulfur of Fuel	0.0015	percent
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent Ash of Fuel	0.01	percent
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Input Materials Processed	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Percent Carbon	83	percent
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Standard Classification (SCC) Code	20100102	Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel), Reciprocating
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide in tons per year	37.6	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide Combusted in tons per year	37.6	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Monoxide in tons per year	0.44	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Carbon Monoxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Lead in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Lead calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Nitrogen Dioxide in tons per year	0.54	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Nitrogen Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter (10 microns or less) in tons per year	0.018	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter (2.5 microns or less) in tons per year	0.018	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter (total suspended) in tons per year	0.018	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Sulfur Dioxide in tons per year	0.08	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Volatile Organic Compounds (VOC) in tons per year	0.01	tons/y
856	Los Alamos National Laboratory	350280001	TA-33-G-1	Diesel Fred Generator	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	AQB, State/Local ID	035	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Operating Time in Hours Per Day	24	hr/d
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Operating Time in Days Per Week	7	d/week
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Operating Time in Weeks Per Year	52	weekly
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Operating Time in Hours Per Year	8760	hr/yr
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Fuel Consumption	23,767	gal/yr
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Input Materials Processed	647	Asphalt
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Standard Classification (S CC) Code	A.2501965000	Storage and Transport, Petroleum and Petroleum Product
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Volatile Organic Compounds (VOC) in tons per year	0.003	tons/yr
856	Los Alamos National Laboratory	350280001	TA-60	insignificant, Tank (Asphalt Emulsion)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)



856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Percent of Operation During Fall	7	hd
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Operating Time in Hours Per Day	5	dwk
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Operating Time in Days Per Week	52	weeks/y
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Operating Time in Weeks Per Year	1820	hw
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Operating Time in Hours Per Year	226	Paper
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Input Materials Processed		
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Output Materials Processed		
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Standard Classification (SCC) Code	A.28500000	Waste Disposal, Treatment, and Recovery, Scrap and Waste Materials, Shredding
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (10 microns or less) in tons per year	0.28	tons/y
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (10 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Particulate Matter (10 microns or less) Actual total efficiency controlled by Single Cyclone, Fabric Filter	95	percent
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (2.5 microns or less) in tons per year	0.19	tons/y
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (2.5 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Particulate Matter (2.5 microns or less) Actual total efficiency controlled by Single Cyclone, Fabric Filter	95	percent
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (total suspended) in tons per year	0.31	tons/y
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Actual Particulate Matter (total suspended) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	Ta-52-11	Data Disintegrator/Industrial Shredder	Particulate Matter (total suspended) Actual total efficiency controlled by Single Cyclone, Fabric Filter	95	percent

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Percent of Operation During Fall	24	h/d
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Operating Time in Hours Per Day	7	d/week
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Operating Time in Days Per Week	52	weeks/y
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Operating Time in Weeks Per Year	8760	h/y
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Fuel Consumption	5	Mgally
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Input Materials Processed	823	Distillate Oil (No. 1 & 2) Industrial Processes, In-process Fuel Use, Fuel Storage - Fixed Roof Tanks,
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Standard Classification (SCC) Code	39090004	Distillate Oil (No. 2); Working Loss
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Volatile Organic Compounds (VOC) in tons per year	0.007	tons/y
856	Los Alamos National Laboratory	350280001	043	Insignificant, Composite Mineral Oil Tank	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., A P-42)

856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent of Operation During Spring	20	percent of time
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent of Operation During Summer	50	percent of time
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent of Operation During Fall	30	percent of time
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Operating Time in Hours Per Day	6	hr/d
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Operating Time in Days Per Week	7	days/week
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Operating Time in Weeks Per Year	15	weeks/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Fuel Consumption	100	MM SCFY
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Fuel Heating Value	16.9	MM B TU/MM SCF
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent Sulfur of Fuel	0.006	percent
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent Ash of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Input Materials Processed	209	Natural Gas
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Percent Carbon	68	percent
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Standard Classification (SCC) Code	20100201	Internal Combustion Engines, Electric Generation, Natural Gas, Turbine
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide in tons per year	942.5	tons/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide Combusted in tons per year	942.5	tons/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide Vented in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Dioxide Vented calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Monoxide in tons per year	0.089	tons/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Carbon Monoxide calculation method	0	Actual stack test
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Lead in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Nitrogen Dioxide in tons per year	0.43	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Nitrogen Dioxide calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Particulate Matter (10 microns or less) in tons per year	0.058	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Particulate Matter (2.5 microns or less) in tons per year	0.058	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Sulfur Dioxide in tons per year	0.03	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Volatile Organic Compounds (VOC) in tons per year	0.019	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	C1-1	Turbine Generation Set (TA-3, P over plant)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)



856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Winter	004	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Operating Time in Hours Per Day	0	hr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Operating Time in Weeks Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Operating Time in Weeks Per Year	0	weekly
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Fuel Consumption	0	hy
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Fuel Heating Value		
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Fuel Type		
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent Sulfur of Fuel		
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent Ash of Fuel		
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Input Materials Processed		
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Standard Classification (SCC) Code	10300501	External Combustion Boilers, Commercial/Institutional, Distillate Oil, Grades 1 and 2 Oil
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide Combusted in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide Combusted calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Monoxide in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Carbon Monoxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Lead in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Nitrogen Dioxide in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Nitrogen Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (total suspended) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Particulate Matter (total suspended) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Sulfur Dioxide in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Sulfur Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-21-357-2b	Steam Plant Boiler Ta21 Bldg357(Alt Op Scenario No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) calculation method	dc	Design calculation

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	AOB-State/Local ID	004	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Operating Time in Hours Per Day	0	hrd
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Operating Time in Days Per Week	0	dweek
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Operating Time in Hours Per Year	0	hr/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Fuel Consumption		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Fuel Heating Value		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Fuel Type		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent Sulfur of Fuel		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent Ash of Fuel		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Input Materials Processed		
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Percent Carbon		percent
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Standard Classification (SCC) Code	10300501	External Combustion Boilers, Commercial/Institutional, Distillate Oil, Grades 1 and 2
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide Combusted in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Dioxide Combusted calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Monoxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Carbon Monoxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Lead in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Lead calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Nitrogen Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Nitrogen Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (total suspended) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Particulate Matter (total suspended) calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Sulfur Dioxide in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Sulfur Dioxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-21-357-3b	Steam Plant Boiler Ta21 Bldg357(AI Op Scenario No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) calculation method	dc	Design calculation

856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent of Operation During Winter	10	percent of time
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent of Operation During Spring	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent of Operation During Summer	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent of Operation During Fall	8	h/d
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Operating Time in Hours Per Day	5	d/week
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Operating Time in Days Per Week	26	weeks/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Operating Time in Weeks Per Year	185	hy
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Fuel Consumption	25312	gal/yr
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Fuel Heating Value	2516	MMB TU/MM S CF
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Fuel Type	255	Propane
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent Sulfur of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent Ash of Fuel	647	Asphalt
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Input Materials Processed		Products, Asphalt Concrete, Drum
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Percent Carbon		Mix Plant: Rotary Drum Dryer / Mixer, Natural Gas - Fired
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Standard Classification (SCC) Code	30500255	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide in tons per year	146.2	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide Combusted in tons per year	146.2	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Monoxide in tons per year	0.4	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Lead in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Lead calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Nitrogen Dioxide in tons per year	0.027	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (10 microns or less) in tons per year	0.006	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (10 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (2.5 microns or less) in tons per year	0.006	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (2.5 microns or less) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (total suspended) in tons per year	0.01	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Particulate Matter (total suspended) calculation method	11	Manufacturer Specification
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Sulfur Dioxide in tons per year	0.005	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Volatile Organic Compounds (VOC) in tons per year	0.009	tons/y
856	Los Alamos National Laboratory	350280001	TA-60-BDMb	Asphalt Plant Dryer Propane	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Operating Time in Hours Per Day	0	h/d
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Operating Time in Hours Per Year	0	h/y
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Fuel Consumption	0	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Standard Classification (SCC) Code	30903004	Industrial Processes, Fabricated Metal Products, Machining Operations, Specify Material**
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Aluminum in tons per year	ap	tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Aluminum calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	AluminumActual total efficiency controlled by		percent
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Beryllium in tons per year		tons/y
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	Actual Beryllium calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-55-PF 4 (b)	Foundry Operations: Beryllium Furnace	BerylliumActual total efficiency controlled by		percent



856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Fall	2	hd
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Hours Per Day	3	h/week
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Days Per Week	10	weekly
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Weeks Per Year	21	ty
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Fuel Consumption	35.2	gal/yr
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Fuel Heating Value	139	MMBtu/MMgal
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Fuel Type	0.0015	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent Sulfur of Fuel	0.01	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent Ash of Fuel	83	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Percent Carbon	202020202	Internal Combustion Engines, Industrial, Natural Gas, Reciprocating
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Standard Classification (SCC) Code	0.36	tons/yr
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide in tons per year	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide calculation method	0.36	tons/yr
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Combusted in tons per year	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Combusted calculation method	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Vented in tons per year	0.002	tons/yr
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Vented calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Monoxide in tons per year	0.008	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Carbon Monoxide calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Carbon Monoxide/Actual total efficiency controlled by Uncontrolled	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Nitrogen Dioxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Nitrogen Dioxide calculation method	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Nitrogen Dioxide/Actual total efficiency controlled by Uncontrolled	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (10 microns or less) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (10 microns or less) calculation method	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Particulate Matter (10 microns or less/Actual total efficiency controlled by Uncontrolled	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (total suspended)/in tons per year	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (total suspended)/Actual total efficiency controlled by Uncontrolled	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Particulate Matter (total suspended)/Actual total efficiency controlled by Uncontrolled	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Sulfur Dioxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Sulfur Dioxide calculation method	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Sulfur Dioxide/Actual total efficiency controlled by Uncontrolled	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Volatile Organic Compounds (VOC) in tons per year	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Actual Volatile Organic Compounds (VOC) calculation method		
856	Los Alamos National Laboratory	350280001	TA-33-g-3	Kohler Diesel Generator 20E ORZ	Volatile Organic Compounds (VOC)/Actual total efficiency controlled by Uncontrolled		

Emissions Inventory Report Summary for LANL for Calendar Year 2008

2008	856	Los Alamos National Laboratory	350280001	TA-3349-2	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Winter	25	percent of time
2008	856	Los Alamos National Laboratory	350280001	TA-3349-2	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Spring	25	percent of time
2008	856	Los Alamos National Laboratory	350280001	TA-3349-2	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Summer	25	percent of time
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Percent of Operation During Fall	1	hr/d
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Hours Per Day	1	hr/d
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Days Per Week	1	days/week
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Operating Time in Weeks Per Year	1	weeks/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Fuel Consumption	0.6	hr/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Fuel Heating Value	138	MMBTU/M gal
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Fuel Type	0.0015	Diesel
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Percent Sulfur of Fuel	0.01	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Percent Ash of Fuel	44	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Percent Carbon	83	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Standard Classification (SCC) Code	20200202	Internal Combustion Engines, Industrial, Natural Gas, 4-cycle Rich Burn
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide in tons per year	0.01	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Combusted in tons per year	0.01	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Vent calculation method	pr	Other Publication Reference
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Dioxide Vented in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Monoxide in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Carbon Monoxide calculation method	dc	Design calculation
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Carbon Monoxide Actual total efficiency controlled by Uncontrolled	0	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Nitrogen Dioxide in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Nitrogen Dioxide calculation method	dc	Design calculation
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Nitrogen Dioxide actual total efficiency controlled by Uncontrolled	0	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (10 microns or less) in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Particulate Matter (10 microns or less) Actual total efficiency controlled by Uncontrolled	0	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (total suspended) in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Particulate Matter (total suspended) Actual total efficiency controlled by Uncontrolled	0	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Sulfur Dioxide in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Sulfur Dioxide actual total efficiency controlled by Uncontrolled	0	percent
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/yr
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Actual Volatile Organic Compounds (VOC) calculation method	dc	Design calculation
2008	856	Los Alamos National Laboratory	350280001	TA-334-2	Kohler Diesel Generator 20E ORZ	Volatile Organic Compounds (VOC) actual total efficiency controlled by Uncontrolled	0	percent

856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent of Operation During Winter	25	percent of time	1G	5
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent of Operation During Spring	25	percent of time	1G	6
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent of Operation During Summer	25	percent of time	1G	7
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent of Operation During Fall	4	hrd	23	8
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Operating Time in Hours Per Day	2	dwkweek	X6	9
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Operating Time in Weeks Per Week	10	weekly	ZD	10
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Operating Time in Days Per Year	54	hrd	ZD	11
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Operating Time in Hours Per Year	853	galy	HR	12
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Fuel Consumption	139	MWBTU/Mgal	1F	13
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Fuel Type		Diesel	PR	14
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent Sulfur of Fuel	0.0015	percent	PR	15
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent Ash of Fuel	0.01	percent	PR	16
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Input Materials Processed	44			17
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Percent Carbon	44	Diesel		17
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Standard Classification (SCC) Code	20200202	83 percent	PR	19
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide in tons per year		Internal Combustion Engines, Industrial, Natural Gas, 4-cycle Rich Burn		20
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide calculation method		8.66 tons/y	TY	21
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide calculation method		Other Publication Reference		22
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide Combusted in tons per year		8.66 tons/y	TY	24
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide Combusted calculation method		Other Publication Reference		25
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide Vented in tons per year		0 tons/y	TY	27
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Dioxide Vented calculation method		0.06 tons/y	TY	28
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Monoxide in tons per year		Design calculation		31
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Carbon Monoxide calculation method		0.26 tons/y	1G	32
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Carbon Monoxide/Actual total efficiency controlled by Uncontrolled		Design calculation		33
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Nitrogen Dioxide in tons per year		Design calculation		34
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Nitrogen Dioxide calculation method		0.02 tons/y	1G	35
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Nitrogen Dioxide/Actual total efficiency controlled by Uncontrolled		EPA emission factors (e.g., AP-42)		37
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Particulate Matter (10 microns or less) in tons per year		0 percent	1G	38
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Particulate Matter (10 microns or less) calculation method		0.02 tons/y	TY	39
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Particulate Matter (total suspended) in tons per year		EPA emission factors (e.g., AP-42)		40
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Particulate Matter (total suspended) calculation method		0 percent	1G	41
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Particulate Matter (total suspended)/Actual total efficiency controlled by Uncontrolled		0.02 tons/y	TY	42
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Sulfur Dioxide in tons per year		EPA emission factors (e.g., AP-42)		43
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Sulfur Dioxide calculation method		0.02 tons/y	1G	44
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Sulfur Dioxide/Actual total efficiency controlled by Uncontrolled		0.02 tons/y	TY	45
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Volatile Organic Compounds (VOC) in tons per year		Design calculation		46
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Actual Volatile Organic Compounds (VOC) calculation method		0 percent	1G	47
856	Los Alamos National Laboratory	350280001	TA-33-9-4	Caterpillar 3306 225Kw	Volatile Organic Compounds (VOC)/Actual total efficiency controlled by Uncontrolled		0 percent		

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent of Operation During Fall	24	hd
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Operating Time in Hours Per Day	4	dwkweek
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Operating Time in Weeks Per Year	12	dwkweek
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Operating Time in Hours Per Year	576	hry
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Fuel Consumption	1.8	MMBtu
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Fuel Heating Value	1049	MMBtu/MM SCF
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent Sulfur of Fuel	0.006	Percent
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent Ash of Fuel	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Input Materials Processed	68	percent
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Percent Carbon	10100604	External Combustion Boilers, Electric Generation, Natural Gas, Tangentially Fired Units
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Standard Classification (SCC) Code	98.5	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide in tons per year	98.5	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide Combusted in tons per year	98.5	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide Calculated in tons per year	98.5	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide Ventilated in tons per year	0	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide Vented in tons per year	0	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Dioxide Vented calculation method	0.07	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Monoxide in tons per year	0.08	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Monoxide calculation method	0.07	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Carbon Monoxide calculation method	0.007	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Nitrogen Dioxide in tons per year	0.007	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Nitrogen Dioxide calculation method	0.007	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Particulate Matter (10 microns or less) in tons per year	0.001	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Particulate Matter (2.5 microns or less) calculation method	0.005	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Sulfur Dioxide in tons per year	0.005	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Sulfur Dioxide calculation method	0.005	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Volatile Organic Compounds (VOC) in tons per year	0.005	tonsy
856	Los Alamos National Laboratory	350280001	TA-502-B-S-1	Superior Model M65-5-1500-S-260	Actual Volatile Organic Compounds (VOC) calculation method	0.005	tonsy

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	AQB-State/Local ID	024	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent of Operation During Winter	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent of Operation During Spring	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent of Operation During Summer	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent of Operation During Fall	25	percent of time
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Operating Time in Hours Per Day	7	h/d
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Operating Time in Weeks Per Year	52	d/week
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Operating Time in Hours Per Year	8736	h/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Fuel Consumption	20.5	MM SCF/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Fuel Heating Value	1049	MM BTU/MM SCF
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Fuel Type	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent Sulfur of Fuel	0	percent
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent Ash of Fuel	209	Natural Gas
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Input Materials P processed	68	percent
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P percent Carbon		External Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100 Million Btu/hr except, Tangential
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Standard Classification (SCC) Code	10100602	Million Btu/hr except, Tangential
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide in tons per year	1140.2	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide Combusted in tons per year	1140.2	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Dioxide Vented calculation method		
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Monoxide in tons per year	0.38	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Lead in tons per year	5.12E-06	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Lead calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Nitrogen Dioxide in tons per year	0.38	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Nitrogen Dioxide (10 microns or less) in tons per year	0.078	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P particulate Matter (2.5 microns or less) in tons per year	0.078	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P particulate Matter (total suspended) in tons per year	0.078	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual P particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Sulfur Dioxide in tons per year	0.006	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Volatile Organic Compounds (VOC) in tons per year	0.056	tons/y
856	Los Alamos National Laboratory	350280001	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	AQB-State/Local ID	002	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Winter	50	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Spring	30	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Summer	10	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Fall	10	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Day	24	hrs
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Days Per Week	2	days/week
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Weeks Per Year	12	weeks/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Year	576	hrs
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Consumption	1753	gally
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Heating Value	139	MMBTU/M gal
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Type	Diesel	Diesel
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Sulfur of Fuel	0.05	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Ash of Fuel	-0.01	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Input Materials Processed	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Output Materials Processed	83	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Standard Classification (SCC) Code	10100501	External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide in tons per year	1778	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted in tons per year	1778	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Ventilated in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Ventilated calculation method	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide in tons per year	0.004	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide in tons per year	0.008	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) in tons per year	0.002	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (total suspended) in tons per year	0.003	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide in tons per year	0.006	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0.0002	tons/yr
856	Los Alamos National Laboratory	350280001	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)

856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	AQB-S State/Local ID	002	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent of Operation During Spring	50	percent of time
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent of Operation During Fall	50	percent of time
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Day	24	hr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Weeks Per Week	2	week
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Weeks Per Year	12	weekly
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Year	576	hr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Consumption	431	gal/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Heating Value	138	MMBTU/M gal Diesel
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Type	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent Sulfur of Fuel	0.05	Percent
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P percent Ash of Fuel	<0.01	Percent
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Input Materials Processed	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Carbon	83	percent
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Standard Classification (SCC) Code	10100501	External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide in tons per year	4.4	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted in tons per year	4.4	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Vented in tons per year		tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Vented calculation method		tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide in tons per year	0.001	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Formaldehyde in tons per year	1.05E-05	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Formaldehyde calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Hexane in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Hexane calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide in tons per year	0.002	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide calculation method	st	Actual stack test
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Nitrogen Dioxide Actual total efficiency controlled by Flue Gas Recirculation	64	percent
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (10 microns or less) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (10 microns or less) calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (2.5 microns or less) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (2.5 microns or less) calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (total suspended) in tons per year	0.001	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual P particulate Matter (total suspended) calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide in tons per year	0.002	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide calculation method	ap	EPA emission factors (e.g. AP-42)
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/yr
856	Los Alamos National Laboratory	350280001	TA-322-2	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g. AP-42)

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	AOB- State/Local ID	002	Not Applicable
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Spring	95	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent of Operation During Fall	5	percent of time
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Day	24	hrs
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Days Per Week	2	days/week
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Weeks Per Year	12	weeks/year
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Operating Time in Hours Per Year	576	hrs
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Heating Value	755	gal/hy
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Fuel Type	139	MMBtu/MM gal
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Sulfur of Fuel	0.05	Percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Ash of Fuel	-0.01	Percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Input Materials Processed	44	Diesel
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Percent Carbon	83	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Standard Classification (SCC) Code	10100501	External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide in tons per year	7.7	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted in tons per year	7.7	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Vented in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Dioxide Vented calculation method	0.002	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Carbon Monoxide calculation method	1.80E-05	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Formaldehyde in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Formaldehyde calculation method	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Hexane in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Hexane calculation method	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide in tons per year	st	Actual stack test
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Nitrogen Dioxide calculation method	64	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Nitrogen Dioxide/Actual total efficiency controlled by Flue Gas Recirculation	0.001	percent
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (10 microns or less) calculation method	0.001	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (2.5 microns or less) calculation method	0.001	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (total suspended) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Particulate Matter (total suspended) calculation method	0.003	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Sulfur Dioxide calculation method	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) in tons per year	ap	EPA emission factors (e.g., AP-42)
856	Los Alamos National Laboratory	350280001	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	Actual Volatile Organic Compounds (VOC) calculation method	ap	EPA emission factors (e.g., AP-42)



856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Fuel Consumption	20607.4 gal	12
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Fuel Heating Value	139 MMB TU/Mgal	13
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Fuel Type	Diesel	14
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual P percent Sulfur of Fuel	0.0015 percent	15
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual P percent Ash of Fuel	0.01 percent	16
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Output Materials Processed		18
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual P percent Carbon	83 percent	19
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Standard Classification (SCC) Code	Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel),	
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Carbon Dioxide Combusted in tons per year	20100102 Reciprocating	20
856	Los Alamos National Laboratory	350280001	GENERATORS	Generators - GHG only	Actual Carbon Dioxide Combusted calculation method	213.1 tons/yr	21
					Other Publication Reference		22

Emissions Inventory Report Summary for LANL for Calendar Year 2008

856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Fuel Consumption	403.3	MM SCF/y	12
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Fuel Heating Value	1049	MM BTU/MM SCF	13
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Fuel Type	209	Natural Gas	14
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Percent Sulfur of Fuel	0.006	percent	15
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Percent Ash of Fuel	0	percent	16
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Output Materials Processed	68	percent	18
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Percent Carbon	68	percent	19
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Standard Classification (SCC) Code	10100602	External Combustion Boilers, Electric Generation, Natural Gas, Boilers < 100 Million Btu/hr except Tangential	20
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Carbon Dioxide Combusted in tons per year	22,445.10	Million Btu/hr except Tangential	21
856	Los Alamos National Laboratory	350280001	BOILERS	Boilers - GHG only	Actual Carbon Dioxide Combusted calculation method	pr	Other Publication Reference	22

856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Percent of Operation During Winter	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Percent of Operation During Spring	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Percent of Operation During Summer	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Percent of Operation During Fall	0	percent of time
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Operating Time in Hours Per Day	0	h/d
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Operating Time in Days Per Week	0	d/week
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Operating Time in Weeks Per Year	0	weeks/y
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Operating Time in Hours Per Year	0	h/y
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Standard Classification (SCC) Code	30622201	Industrial Processes, Petroleum Industry, , Underground Storage and Other Remediation: Vapor Extract
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Total HAP in tons per year	dc	tons/y
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Total HAP calculation method	dc	Design calculation
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Total HAP Actual total efficiency controlled by Catalytic Oxidation	0	percent
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Volatile Organic Compounds (VOC) in tons per year	0	tons/y
856	Los Alamos National Laboratory	350280001	TA-54-SVE	Soil Vapor Extraction	Actual Volatile Organic Compounds (VOC) calculation method	dc	Design calculation



# **Attachment C**

*2008 Semi-Annual Emissions Reports Submitted  
Under Title V Operating Permit Requirements*





*Environmental, Safety, Health & Quality*

PO Box 1663, MS K491  
Los Alamos, New Mexico 87545  
505-667-4218/Fax 505-665-3811



Date: September 12, 2008  
Refer To: ESH&Q-08-050

Ms. Debra McElroy  
Compliance & Enforcement Section  
New Mexico Environment Department  
Air Quality Bureau  
1301 Siler Road, Building B  
Santa Fe, New Mexico 87507

**SUBJECT: SEMI-ANNUAL EMISSIONS REPORT - JANUARY 1, 2008 – JUNE 30, 2008  
AIR QUALITY TITLE V OPERATING PERMIT P100M2  
IDEA ID No. 856 – LOS ALAMOS NATIONAL LABORATORY (LANL)**

Dear Ms. McElroy:

Enclosed is Los Alamos National Laboratory's (LANL) semi-annual emissions report for the period January 1, 2008 through June 30, 2008 (Enclosure-1). This report is required by permit condition 4.1 and is submitted within 90 days from the end of the reporting period as required by permit condition 4.3.

The semi-annual emissions report includes actual emissions from permitted sources included in section 2.0 of LANL's Operating Permit. Emissions are also reported from insignificant boiler and generator sources. These sources are included to demonstrate that LANL has not exceeded Prevention of Significant Deterioration (PSD) applicability thresholds. In this report, actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

A Construction Permit (NSR Permit 2195-P) was issued on August 8, 2007 to construct and operate three electrical generator engines at Technical Area 33. These three units are not listed in the current Operating Permit, but have been included in the LANL Operating Permit application submitted in April of 2008. The three units are included in this emissions report.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169.

Sincerely,

Richard S. Watkins  
Associate Director, ESH&Q

*Ms. Debra McElroy*  
ESH&Q-08-050  
LA-UR: 08-05553

WWW

Enc: a/s

Cy: M. Mallory, w/o enc.,ADPADOPS, A102  
S. Fong, w/o enc., DOE-LA-AO, A316  
P. Wardwell, w/o enc., LC-ESH, A187  
D. Wilburn, w/o enc., ENV-EAQ, J978  
S. Story, ENV-EAQ, J978  
M. Stockton, ENV-EAQ, J978  
W. Whetham, ENV-EAQ, J978  
J. Stanton, SSS-AF-V02, A199  
IRM-RM550, A150  
ENV-EAQ Title V Emissions Report File  
ENV-EAQ Reading File  
ENV-DO Reading File



LA-UR-08-05553

Approved for public release;  
distribution is unlimited.

*Title:* Semi-Annual Emissions Report - Operating Permit Number  
P100M2 January - June 2008

*Author(s):* Walt Whetham  
Evelyn Rainey

*Intended for:* New Mexico Environmental Department




Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

Form 836 (7/06)

# **Enclosure - 1**

Los Alamos National Laboratory's  
Title V Operating Permit  
Emissions Report for the period  
**January 1 – June 30, 2008**

## Title V Report Certification Form

<b>I. Report Type</b>		
<input type="checkbox"/> <b>Annual Compliance Certification</b> <input type="checkbox"/> <b>Semi-Annual Monitoring Report</b> <input checked="" type="checkbox"/> <b>Other Specify: Title V Semi-Annual Emissions Report January-June 2008</b>		
<b>II. Identifying Information</b>		
Facility Name: Los Alamos National Laboratory		
Facility Address: P.O. Box 1663, MS J978, Los Alamos	State: NM	Zip: 87545
Responsible Official (RO): Richard S. Watkins	Phone: 505-667-4218	Fax: 505-665-3811
RO Title: Assoc. Director Environmental, Safety, Health, and Quality	RO e-mail: rswatkin@lanl.gov	
Permit No.: P100M2	Date Permit Issued: July 16, 2007	
Report Due Date (as required by the permit): 09/28/2008	Permit AI number: 856	
Time period covered by this Report: From: January 1, 2008	To: June 30, 2008	
<b>III. Certification of Truth, Accuracy, and Completeness</b>		
<p>I am the Responsible Official indicated above. I, (Richard S. Watkins) certify that I meet the requirements of 20.2.70.7.AD NMAC. I certify that, based on information and belief formed after reasonable inquiry, the statements and information contained in the attached Title V report are true, accurate, and complete.</p>		
Signature		Date: 9/12/08

**Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008**

This report is being provided to meet the requirement set forth in permit condition 4.1 of the Los Alamos National Laboratory (LANL) Operating Permit Number P100M2. The emissions were calculated using operating data recorded during the first six months of 2008.

**Facility Emissions**

The following table displays the actual facility-wide emissions compared with the Facility Wide Emission Limits specified in permit condition 2.10.1 of the Operating Permit. These emissions include insignificant sources, which are included to demonstrate that facility-wide emissions are below all PSD applicability threshold limits. Hazardous Air Pollutant (HAP) and Volatile Organic Compound (VOC) emissions from chemical use include point source and fugitive emissions (see permit condition 4.1).

Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	2008 Annual Emissions (tons)	Facility Wide Emission Limits (Permit Condition 2.10.1) (tons per year)
Nitrogen Oxides (NOx)	25.4			245
Sulfur Dioxide (SO <sub>2</sub> )	0.3			150
Particulate Matter (PM)	2.5			120
Carbon Monoxide (CO)	18.4			225
Volatile Organic Compounds (VOCs)	6.4			200
Hazardous Air Pollutants (HAPs)	3.2			24 combined
Jan-June Highest Individual HAP (Hydrochloric Acid)	0.5			8 individual

**Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008**

**Source Emissions**

The following are the actual emissions from permitted sources listed in permit condition 2.0 of the operating permit for the six month reporting period. Included with these emissions are the source specific emission limits if applicable.

**Permit Condition/Source**

**2.1 Asphalt Production**

Asphalt Plant TA-60-SDM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.1.2) (tons per year)
NOx	0.013			1.0
SO <sub>2</sub>	0.002			1.0
Pb/P	0.005			35.4 lb/hr
CO	0.210			2.6
VOC	0.004			1.0
HAPs	0.004			No Source Permit Limit

**Note:** The Asphalt Plant does not have an annual limit for PM. The hourly emissions were demonstrated during the initial source compliance test conducted on August 25th & 26th, 2005 and submitted to NMED.

Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008

2.2 Beryllium Activities

Source	Pollutant	January - June Emissions	July - December Emissions	Annual Emissions	Permit Limits (Condition 2.2.2)
Beryllium Test Facility TA-3-14 <sup>(1)</sup>	Beryllium (grams)	< 0.0033			3.5 gm/yr
Target Fabrication Facility TA-35-21 <sup>(2)</sup>	Beryllium (grams)	< 0.00944			0.36 gm/yr
Plutonium Facility TA-55-PF4 <sup>(3)</sup>	Beryllium (grams)	< 1.495			2.99 gm/yr
Machining Operation	Aluminum (grams)	< 1.495			2.99 gm/yr
Plutonium Facility TA-55-PF4	Beryllium (grams)	0			$8.73 \times 10^{-4}$ gm/yr
Foundry Operation <sup>(4)</sup>	Aluminum (grams)	0			$8.73 \times 10^{-4}$ gm/yr
<b>Beryllium Total<sup>(5)</sup></b>	<b>(tons) =</b>	<b>&lt; 1.66E-06</b>			
<b>Aluminum Total (tons) =</b>	<b>=</b>	<b>&lt; 1.65E-06</b>			

Notes: <sup>(1)</sup> Emission values shown for the Beryllium Test Facility are from actual stack emission measurements which are submitted to NMED quarterly. <sup>(2)</sup> Emissions for the Target Fabrication Facility are from initial compliance testing of that source and calculated based on a conservative assumption of 8 hour work days. Log books were created to verify that work days were much less than 8 hours. <sup>(3)</sup> Emissions for the Plutonium Facility are calculated based on permitted throughputs. Log books were checked to verify that throughputs were much less than permitted values. <sup>(4)</sup> The Plutonium Facility foundry operations did not operate during the first six months of 2008. <sup>(5)</sup> Other Beryllium activities listed in section 2.2 of the permit do not require reporting in the Semi-Annual Emissions Report.

**Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008**

**2.3 Boilers and Heaters**

Boilers and Heaters	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.3.2) (tons per year)
NOx	14.50			80
SO <sub>2</sub>	0.09			50
PM	1.16			50
PM-10	1.16			50
CO	11.83			80
VOCs	0.81			50
HAPs	0.28			No Source Limit

Note: The emissions shown in this table include significant and insignificant sources. This section does not include the TA-3-22 Power Plant boilers. These can be found under Section 2.9 of this report.

**2.4 Carpenter Shops**

Shop	Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.4.2) (tons per year)
TA-3-38	PM <sub>10</sub>	0.006			3.07
TA-15-563	PM <sub>10</sub>	0.013			2.81

**Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008**

2.5 Chemical Usage

Chemical Usage LANL-FW-CHEM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.5.3.1)
VOCs	4.7			Source limits refer to facility-wide limits. (See Facility Emissions Table on Page 1)
HAPs	2.6			
Highest Individual HAP for the first six months (Hydrochloric Acid)	0.5			

2.6 Degreasers

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.6.2.1) (tons per year)
VOCs	0.010			Source limits refer to facility-wide limits. (See Facility Emissions Table on Page 1)
HAPs	0.010			

Note: Degreasers TA-55-DG-2 and TA-55-DG-3 were not used from January 1 to June 30, 2008. The units have been removed from LANL and will not be used in the future. The Title V application submitted to NMED in April 2009 reflects this change.



Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008

2.7 Internal Combustion Sources

Generator TA-33-G-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2,7.2) (tons per year)
NOx	0.359			18.7
SOx	0.053			2.5
TSP	0.072			0.6
PM <sub>10</sub>	0.072			0.6
CO	0.252			15.2
VOC	0.007			0.3
HAPs	7.73E-05			No Source Limit

Generator TA-33-G-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NOx	0.000			0.21
SOx	0.000			Not Required
TSP	0.000			Not Required
PM <sub>10</sub>	0.000			Not Required
CO	0.000			0.1
VOC	0.000			Not Required
HAPs	0.00E+00			No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. This generator did not run during the first six months of 2008.

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NOx	0.008			0.21
SOx	0.001			Not Required
TSP	0.001			Not Required
PM <sub>10</sub>	0.001			Not Required
CO	0.002			0.1
VOC	0.001			Not Required
HAPs	2.68E-06			No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. The emissions from this unit are included in this facility wide total.

**Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008**

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NOx	0.000			2.33
SOx	0.000			0.16
TSP	0.000			Not Required
Pm10	0.000			Not Required
CO	0.000			1.4
VOC	0.000			0.2
HAPs	0.00E+00			No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. This generator did not run during the first six months of 2008.

Stationary Standby Generators	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	2.46			No Source Specific Emission Limits for Standby Generators
SOx	0.08			
TSP	0.11			
Pm10	0.11			
CO	0.56			
VOC	0.11			
HAPs	0.001			

Note: Standby Generators are insignificant sources.

Los Alamos National Laboratory  
Semi-Annual Emissions Report  
January 1, 2008 through June 30, 2008

2.8 Data Disintegrator

Data Disintegrator TA-52-11	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.8.2) (tons per year)
TSP	0.19			9.9
PM10	0.17			9.9

2.9 Power Plant at Technical Area 3 (TA-3-22)

Boilers TA_3-22-1, TA-3-22-2 TA-3-22-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition 2.9.2) (tons per year)
NOx	8.0			60.2
SO <sub>2</sub>	0.1			7.9
TSP	1.0			8.4
PM <sub>10</sub>	1.0			8.2
CO	5.5			41.3
VOC	0.8			5.6
HAPs	0.3			No Source Limit

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition 2.9.2) (tons per year)
NOx	0.014			33.2
SO <sub>2</sub>	0.001			1.9
TSP	0.002			2.3
PM <sub>10</sub>	0.002			2.3
CO	0.003			19.8
VOC	0.001			No TPY Limit
HAPs	3.90E-04			No Source Limit



Associate Directorate for ESH&Q  
P.O. Box 1663, MS K491  
Los Alamos, New Mexico 87545  
505-667-4218/Fax 505-665-3811



Date: March 20, 2009  
Refer To: ESH&Q-09-014

Compliance Reporting Manager  
Compliance & Enforcement Section  
New Mexico Environment Department  
Air Quality Bureau  
1301 Siler Road, Building B  
Santa Fe, NM 87507

**IDEA ID NO. 856 – LOS ALAMOS NATIONAL LABORATORY (LANL)  
OPERATING PERMIT NO: P100M2  
SEMI-ANNUAL EMISSIONS REPORT – JULY 1, 2008 TO DECEMBER 31, 2008**

Dear Compliance Reporting Manager:

Enclosed is Los Alamos National Laboratory's (LANL) Semi-Annual Emissions report for the period July 1, 2008 through December 31, 2008. This report is required by permit condition 4.1 and is submitted within 90 days from the end of the reporting period as required by permit condition 4.3.

The semi-annual emissions report includes actual emissions from permitted sources included in section 2.0 of LANL's Operating Permit. Emissions are also reported from insignificant boiler and generator sources. These sources are included to demonstrate that LANL has not exceeded Prevention of Significant Deterioration (PSD) applicability thresholds. In this report, actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169.

Sincerely,

A handwritten signature in black ink that reads "J. Chris Cantwell".

J. Chris Cantwell  
Associate Director, ESH&Q

WWW

The World's Greatest Science Protecting America  
An Equal Opportunity Employer / Operated by the University of California for DOE/NNSA

ESH&Q-09-014  
LA-UR:09-01479

March 20, 2009

-2-

Cy:

M. Mallory, PADOPS, A102  
S. Fong, DOE-LA-AO, A316  
P. Wardwell, LC-ESH, A187  
D. Wilburn, ENV-EAQ, J978  
D. Janecky, ENV-EAQ, J978  
S. Story, ENV-EAQ, J978  
M. Stockton, ENV-EAQ, J978  
W. Whetham, ENV-EAQ, J978

---

IRM-RM550, A150  
ENV-EAQ Title V Emissions Report File  
ENV-EAQ Admin File  
ESH&Q File

# Enclosure

---

Los Alamos National Laboratory's  
Title V Operating Permit  
Emissions Report for the period  
**July 1 – December 31, 2008**

## Title V Operating Permit Semi-Annual Emission Report

July 1, 2008 – December 31, 2008

Identifying Information	
Source Name: <u>Los Alamos National Laboratory</u>	County: <u>Los Alamos</u>
Source Address:	
City: <u>Los Alamos</u>	State: <u>NM</u> Zip Code: <u>87545</u>
Responsible Official: <u>J. Chris Cantwell</u>	Ph No. <u>(505) 606-2354</u> Fax No. <u>(505) 665-3811</u>
Technical Contact: <u>Steven L. Story</u>	Ph No. <u>(505) 665-2169</u> Fax No. <u>(505) 665-8858</u>
Principal Company Product or Business: <u>National Security and Nuclear Weapons Research</u> Primary SIC Code: <u>9711</u>	
Permit No. <u>P100M2 (IDEA/Tempo ID No. 856)</u>	Permit Issued Date: <u>July 16, 2007</u>
Certification of Truth, Accuracy, and Completeness	
I, <u>J. Chris Cantwell</u> certify that, based on information and belief formed after reasonable inquiry, the statements and information in the attached semi-annual emission report are true, accurate, and complete.	
Signature <u>J. C. Cantwell</u>	Date: <u>3/16/08</u>
Title: <u>Associate Director Environmental, Safety, Health, and Quality</u>	

## Title V Semi-Annual Emission Report for Permit P100M2

### Emission Reporting Requirements

#### 4.0 Reporting

Conditions of 4.0 are pursuant to 20.2.70.302.E NMAC.

- 4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NOx, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.
- 4.3 The report required by Condition 4.1 shall be submitted within 90 days from the end of the reporting period. The semiannual report required by Condition 4.2 shall be submitted within 45 days from the end of the reporting period. The reporting periods are January 1<sup>st</sup> to June 30<sup>th</sup> and July 1<sup>st</sup> to December 31<sup>st</sup>. This condition is pursuant to 20.2.70.302.E.1 NMAC.



**Specific Emissions Reports:**

**2.1 Asphalt Production**

2.1.2 Emission Limits

Emission Unit	Allowable Emission Limits				
	NO <sub>x</sub>	SO <sub>2</sub>	PM	CO	VOC
TA-60-BDM	1.0 tpy	1.0 tpy	0.04 g/dscf 35.4 lbs/hr	2.6 tpy	1.0 tpy

**Reporting Requirement**

2.1.6.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

<sup>(1)</sup> Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal?  
Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

**Comments:**

Asphalt Plant TA-60-BDM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.1.2) (tons per year)
NO <sub>x</sub>	0.013	0.014	0.027	1.0
SO <sub>2</sub>	0.002	0.003	0.005	1.0
PM	0.005	0.005	0.010	*35.4 lb/hr
CO	0.210	0.220	0.430	2.6
VOC	0.004	0.005	0.009	1.0
HAPs	0.004	0.004	0.008	No Source Permit Limit

Note: \* The Asphalt Plant does not have an annual limit for PM. The hourly emissions were demonstrated during the initial source compliance test conducted on August 25th & 26th, 2005.

**2.2 Beryllium Activities**

2.2.2 Emission Limits

Source	Allowable Emission Limits	
	Beryllium	Aluminum
Chemistry and Metallurgy Research Facility TA-3-29	10 gm/24 hr	Not Applicable
Sigma Facility TA-3-66	10 gm/24 hr	Not Applicable
Beryllium Test Facility TA-3-141	0.35 gm/24 hr 3.5 gm/yr	Not Applicable
TA-16-207	10 gm/24 hr	Not Applicable
TA-35-87	10 gm/24 hr	Not Applicable
Target Fabrication Facility TA-35-213	$1.8 \times 10^{-01}$ gm/hr 0.36 gm/yr	Not Applicable

Source	Allowable Emission Limits	
	Beryllium	Aluminum
Plutonium Facility TA-55-PF4		
Machining Operation	0.12 gm/24 hr 2.99 gm/yr	0.12 gm/24 hr 2.99 gm/yr
Foundry Operation	$3.49 \times 10^{-5}$ gm/24 hr $8.73 \times 10^{-3}$ gm/yr	$3.49 \times 10^{-5}$ gm/24 hr $8.73 \times 10^{-4}$ gm/yr

**Reporting Requirement**

2.2.6 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

<sup>(1)</sup> Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

Comments:      Continued on the next page

## 2.2 Beryllium Activities - continued

## Comments:

Source	Pollutant	January - June Emissions	July - December Emissions	Annual Emissions	Permit Limits (Condition 2.2.2)
Beryllium Test Facility TA-3-141 <sup>(1)</sup>	Beryllium (grams)	< 0.0033	< 0.0033	< 0.007	3.5 gm/yr
Target Fabrication Facility TA-35-213 <sup>(2)</sup>	Beryllium (grams)	< 0.00944	< 0.009	< 0.018	0.36 gm/yr
Plutonium Facility TA-55-PF4 Machining Operation <sup>(3)</sup>	Beryllium (grams)	< 1.495	< 1.41	< 2.91	2.99 gm/yr
	Aluminum (grams)	< 1.495	< 1.41	< 2.91	2.99 gm/yr
Plutonium Facility TA-55-PF4 Foundry Operation <sup>(4)</sup>	Beryllium (grams)	0	0	0.00	$8.73 \times 10^{-4}$ gm/yr
	Aluminum (grams)	0	0	0.00	$8.73 \times 10^{-4}$ gm/yr
<b>Beryllium Total<sup>(5)</sup> (tons) =</b>		<b>&lt; 1.66E-06</b>	<b>&lt; 1.57E-06</b>	<b>&lt; 3.23E-06</b>	
<b>Aluminum Total (tons) =</b>		<b>&lt; 1.65E-06</b>	<b>&lt; 1.55E-06</b>	<b>&lt; 3.30E-06</b>	

Notes: <sup>(1)</sup> Emission values shown for the Beryllium Test Facility are from actual stack emission measurements which are submitted to NMED quarterly. <sup>(2)</sup> Emissions for the Target Fabrication Facility are from initial compliance testing of that source and calculated based on a conservative assumption of 8 hour work days. Log books were checked to verify that work days were much less than 8 hours. <sup>(3)</sup> Emissions for the Plutonium Facility are calculated based on permitted throughputs. Log books were checked to verify that throughputs were much less than permitted values. <sup>(4)</sup> The Plutonium Facility foundry operations did not operate in 2008. <sup>(5)</sup> Other Beryllium activities listed in section 2.2 of the permit do not require reporting in the Semi-Annual Emissions Report.

**2.3 Boilers and Heaters**

**2.3.2 Emission Limits**

Source	Allowable Emission Limits				
	NO <sub>x</sub> (tpy)	CO (tpy)	PM or PM <sub>10</sub> (tpy)	SO <sub>2</sub> (tpy)	VOC (tpy)
All Boilers and Heaters <sup>1</sup>	80	80	50	50	50

<sup>1</sup> Excludes TA-3-22 Power Plant addressed in Condition 2.9

**Reporting Requirement**

2.3.6.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

**Comments:**

Boilers and Heaters	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.3.2) (tons per year)
NO <sub>x</sub>	14.60	10.98	25.58	80
SO <sub>2</sub>	0.09	0.07	0.16	50
PM	1.16	0.87	2.03	50
PM-10	1.16	0.87	2.03	50
CO	11.83	8.86	20.69	80
VOCs	0.81	0.61	1.42	50
HAPs	0.28	0.21	0.49	No Source Limit

Note: The emissions shown in this table include significant and insignificant sources. This section does not include the TA-3-22 Power Plant boilers. These can be found under Section 2.9 of this report.



**2.5 Chemical Usage**  
**2.5.2 Emission Limits**

2.5.3.1 The contribution of VOC and/or HAPs emissions from chemical usage shall not cause the exceedence of the corresponding facility-wide limit listed below:

200 tons per year of facility-wide VOCs  
 8 tons per year of individual facility-wide HAP  
 24 tons per year of total facility-wide HAPs

**Reporting Requirement**  
 2.5.5.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NOx, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal?  
 Answer Yes or No below.

Yes      Date report submitted: \_\_\_\_\_      Tracking Number: \_\_\_\_\_

No      Provide comments and identify any supporting documentation as an attachment.

Comments:

Chemical Usage LANL-FW-CHEM	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.5.3.1)
VOCs	4.7	4.3	9.0	Source limits refer to facility-wide limits.
HAPs	2.6	1.9	4.5	
Highest individual HAP for both the first and the second six months (Hydrochloric Acid)	0.5	0.5	1.0	

**2.6 Degreasers**

2.6.2 Emission Limits

2.6.2.1 The contribution of VOC and/or HAP emissions from chemical usage shall not cause the exceedence of the corresponding facility-wide limit listed below:

200 tons per year of facility-wide VOCs  
 8 tons per year of an individual facility-wide HAP  
 24 tons per year of total facility-wide HAPs

**Reporting Requirement**

2.6.6.3 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal?  
 Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

Comments:

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.6.2.1) (tons per year)
VOCs	0.010	0.005	0.015	Source limits refer to facility-wide limits. (See Facility Emissions Table on Page 1)
HAPs	0.010	0.005	0.015	

Note: Degreasers TA-55-DG-2 and TA-55-DG-3 were not used in 2008. The units have been removed from LANL and will not be used in the future. The Title V application submitted to NMED in April 2008 reflects this change.

**2.7 Internal Combustion Sources**

**2.7.2 Emission Limits**

Source	Allowable Emission Limits											
	TSP		PM10		NO <sub>x</sub>		CO		VOC		SO <sub>x</sub>	
	pph	tpy	pph	tpy	pph	tpy	pph	tpy	pph	tpy	pph	tpy
TA-33-G-1	1.4	0.6	1.4	0.6	40.3	18.1	33.7	15.2	0.7	0.3	5.5	2.5

**Reporting Requirement**

2.7.6.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal?  
Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

**Comments:**

Generator TA-33-G-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.7.2) (tons per year)
NO <sub>x</sub>	0.359	0.181	0.540	18.1
SO <sub>x</sub>	0.053	0.027	0.080	2.5
TSP	0.012	0.006	0.018	0.6
PM <sub>10</sub>	0.012	0.006	0.018	0.6
CO	0.292	0.148	0.440	15.2
VOC	0.007	0.003	0.010	0.3
HAPs	7.73E-05	3.91E-05	1.16E-04	No Source Limit

Continued on the next page.



**2.7 Internal Combustion Sources - continued****Comments:**

Generator TA-33-G-2	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NO <sub>x</sub>	0.000	0.000	0.000	0.21
SO <sub>x</sub>	0.000	0.000	0.000	Not Required
TSP	0.000	0.000	0.000	Not Required
PM <sub>10</sub>	0.000	0.000	0.000	Not Required
CO	0.000	0.000	0.000	0.1
VOC	0.000	0.000	0.000	Not Required
HAPs	0.00E+00	0.00E+00	0.00E+00	No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. This generator did not run during the first six months of 2008 and ran for less than an hour during the second six months of 2008.

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NO <sub>x</sub>	0.008	0.000	0.008	0.21
SO <sub>x</sub>	0.001	0.000	0.001	Not Required
TSP	0.001	0.000	0.001	Not Required
PM <sub>10</sub>	0.001	0.000	0.001	Not Required
CO	0.002	0.000	0.002	0.1
VOC	0.001	0.000	0.001	Not Required
HAPs	2.68E-06	0.00E+00	2.68E-06	No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. The unit ran less than an hour during the second six months of 2008. The emissions from this unit are included in the facility wide total.

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (NSR Permit 2195-P Condition 2) (tons per year)
NO <sub>x</sub>	0.000	0.255	0.255	2.33
SO <sub>x</sub>	0.000	0.018	0.018	0.16
TSP	0.000	0.018	0.018	Not Required
PM <sub>10</sub>	0.000	0.018	0.018	Not Required
CO	0.000	0.055	0.055	1.4
VOC	0.000	0.018	0.018	0.2
HAPs	0.00E+00	8.21E-05	8.21E-05	No Source Limit

Note: This generator is not listed in the latest Title V permit, P100M2. However, it is listed in NSR Permit No. 2195-P which was issued on August 8, 2007 and has been included in the Title V application submitted to NMED in April 2008. This generator did not run during the first six months of 2008. The emissions from this unit are included in the facility wide total.

Continued on the next page.

**2.7 Internal Combustion Sources - continued**

**Comments:**

Stationary Standby Generators	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	2.46	2.52	4.97	No Source Specific Emission Limits for Standby Generators.
SOx	0.08	0.08	0.17	
TSP	0.11	0.11	0.21	
PM <sub>10</sub>	0.11	0.11	0.21	
CO	0.56	0.56	1.12	
VOC	0.11	0.11	0.22	
HAPs	7.97E-04	6.49E-04	1.45E-03	

Note: Standby Generators are insignificant sources.

**2.8 Data Disintegrator**

**2.8.2 Emission Limits**

Source	Allowable Emission Limits			
	TSP (pph)	TSP (tpy)	PM10 (pph)	PM10 (tpy)
TA-52-11	2.3	9.9	2.3	9.9

PM10 and TSP emissions limits shown in above Table are after controls.

**Reporting Requirement**

2.8.6.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NOx, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal?  
Answer Yes or No below.

Yes      Date report submitted: \_\_\_\_\_      Tracking Number: \_\_\_\_\_

No      Provide comments and identify any supporting documentation as an attachment.

**Comments:**

Data Disintegrator	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition 2.8.2) (tons per year)
TA-52-11				
TSP	0.19	0.12	0.31	9.9
PM10	0.17	0.11	0.28	9.9

**2.9 Power Plant at Technical Area 3 (TA-3-22)**

**2.9.2 Emission Limits**

Source	Allowable Emission Limits											
	NO <sub>x</sub> (lb/hr)		CO (lb/hr)		SO <sub>x</sub> (lb/hr)		TSP (lb/hr)		PM <sub>10</sub> (lb/hr)		VOC (lb/hr)	
	Gas	Oil	Gas	Oil	Gas	Oil	Gas	Oil	Gas	Oil	Gas	Oil
TA-3-22-1	10.2	11.3	7.0	6.5	1.1	9.6	1.3	4.3	1.3	3.0	1.0	0.3
TA-3-22-2	10.2	11.3	7.0	6.5	1.1	9.6	1.3	4.3	1.3	3.0	1.0	0.3
TA-3-22-3	10.2	11.3	7.0	6.5	1.1	9.6	1.3	4.3	1.3	3.0	1.0	0.3
Boilers Combined <sup>1</sup>	60.2 tpy		41.3 tpy		7.9 tpy		8.4 tpy		8.2 tpy		5.6 tpy	
TA-3-22 CT-1 (lb/hr)	23.8		170.9		1.4		1.6		1.6		1.0	
TA-3-22 CT-1 (tpy) <sup>1,2</sup>	33.2		19.8		1.9		2.3		2.3		-	

<sup>1</sup>Annual emission limits are 12-month rolling totals. This is pursuant to NSR Permit No. 2195BM1, Table 2.2, Note 1.

<sup>2</sup>"-" notation implies emission rates less than or equal to 0.5 tpy.

**Reporting Requirement**

2.9.6.1 Reports shall be submitted in accordance with conditions 4.1 and 4.2.<sup>(1)</sup>

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO<sub>x</sub>, CO, SO<sub>2</sub>, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

(1) Condition 4.2 refers to submitting a Semi-Annual Monitoring report which LANL submitted on February 5, 2009, Tracking Number SBR20090001.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes      Date report submitted:      Tracking Number:

No      Provide comments and identify any supporting documentation as an attachment.

Comments:      Continued on the next page

2.9 Power Plant at Technical Area 3 (TA-3-22) - Continued

Comments:

Boilers TA-3-22-1, TA-3-22 2 TA-3-22-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition 2.9.2) (tons per year)
NO <sub>x</sub>	7.98	6.09	14.07	60.2
SO <sub>2</sub>	0.09	0.06	0.15	7.9
TSP	1.05	0.80	1.85	8.4
PM <sub>10</sub>	1.05	0.80	1.85	8.2
CO	5.50	4.20	9.70	41.3
VOC	0.76	0.58	1.34	5.6
HAPs	0.26	0.20	0.46	No Source Limit

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition 2.9.2) (tons per year)
NO <sub>x</sub>	0.014	0.413	0.427	33.2
SO <sub>2</sub>	0.001	0.029	0.030	1.9
TSP	0.002	0.056	0.058	2.3
PM <sub>10</sub>	0.002	0.056	0.058	2.3
CO	0.003	0.086	0.089	19.8
VOC	0.001	0.018	0.019	No TPY Limit
HAPs	3.93E-04	1.12E-02	1.16E-02	No Source Limit



This report has been reproduced directly from the best available copy. It is available electronically on the Web (<http://www.doe.gov/bridge>).

Copies are available for sale to U.S. Department of Energy employees and contractors from:  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831  
(865) 576-8401

Copies are available for sale to the public from:  
National Technical Information Service  
U.S. Department of Commerce  
5285 Port Royal Road  
Springfield, VA 22161  
(800) 553-6847

