

LA-UR-09-00464

Approved for public release;
distribution is unlimited.

Title: Title V Semi - Annual Monitoring Report
for Permit P100M2
July 2008 through December 2008

Author(s): David Paulson, ENV-EAQ

Intended for: Compliance Reporting Manager
New Mexico Environment Department - Air Quality Bureau
1301 Siler Road, Building B
Santa Fe, New Mexico 87507



Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

Title V Semi - Annual Monitoring Report for Permit P100M2

Part 1 – Monitoring Activity Reporting Requirements

4.0 REPORTING

Conditions of 4.0 are pursuant to 20.2.70.302.E NMAC.

- 4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.
- 4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.
- 4.3 The report required by Condition 4.1 shall be submitted within 90 days from the end of the reporting period. The semiannual report required by Condition 4.2 shall be submitted within 45 days from the end of the reporting period. The reporting periods are January 1st to June 30th and July 1st to December 31st. This condition is pursuant to 20.2.70.302.E.1 NMAC.
- 4.4 The permittee shall submit reports of all deviations (including emergencies) from permit requirements to the Department when they occur. The permittee shall communicate initial notice of the deviation to the Department within twenty-four (24) hours of the start of the first business day following the start of the occurrence via telephone or facsimile. Within ten (10) calendar days of the start of the first business day following the start of the occurrence, written notice using the Excess Emissions Form (attached to this permit) shall be submitted to the Department. This condition is pursuant to 20.2.70.302.E.2. NMAC.

Attachment 1
Asphalt Plant Opacity Reports

Summary Table, Reports Attached

Month	Read Location	Date	Time	Average Opacity	EPA Method
July	Top of Shaker	07/28/08	9:54 am	0	9 ^(a)
August	Top of Shaker	08/11/08	3:30 pm	0	9 ^(a)
September	Top of Shaker	09/26/08	9:02 am	0	9 ^(a)
October	Top of Shaker	10/07/08	11:04 am	0	9 ^(a)
November	Top of Shaker	11/07/08	9:15 am	0	9 ^(a)
December	Top of Shaker	12/05/08	9:09 am	0	9 ^(a)

(a) EPA Method 9 was used. Average opacity for the Asphalt Plant is the sum of the highest consecutive 24 readings divided by 24 (6 minutes of readings). The method is in accordance with 20.2.61 NMAC and conditions 2.1.4.1 and 2.1.4.3 of the Los Alamos National Laboratory (LANL) Operating Permit P100M2.



LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: <i>LANL Asphalt Plant</i>		Observation Date: <i>7-28-08</i>	Start Time: <i>0954</i>	End Time: <i>1000</i>
Source Location: <i>TA-60 (Sigma Mesa)</i>		Min	Sec	Comments
Type of Source: <i>Asphalt Plant Baghouse</i>	Type of Control Equipment:	0	15	30
Describe Emission Point (Top of stack, etc.): <i>Top of shaker stack</i>		45	45	
Height Above Ground Level: <i>45 Feet</i>	Height Relative to Observer: <i>45 Feet</i>	1	0	0
Distance From Observer: <i>60 Feet</i>	Direction of Source From Observer: <i>NW</i>	2	0	0
Description of Plume (stack exit only): <input type="checkbox"/> Lifting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coasting <input checked="" type="checkbox"/> No Plume Present		3	0	0
Emission Color: <i>N/A</i>	Plume Type: <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent	4	0	0
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES If YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached		5	0	0
At what point in the plume was opacity determined? <i>2 ft above top of stack</i>		6	0	0
Describe Background (i.e. blue sky/trees, etc.): <i>Blue sky</i>		7		
Background Color: <i>Blue</i>	Sky Conditions: <i>clear</i>	8		
Wind Speed: <i>3-5 mph</i>	Wind Direction (provide from/to, i.e. from North to South): <i>From ESE</i>	9		
Ambient Temperature: <i>68 °F</i>	Relative Humidity: <i>62 %</i>	10		
Additional Comments/Information: <i>All emission points clear</i>		11		
Stack with Plume:		12		
SUN		13		
Wind		14		
SOURCE LAYOUT SKETCH		15		
Emission Point		16		
Draw Arrow in North Direction		17		
OBSERVER'S POSITION		18		
SUN LOCATION LINE		19		
140°		20		
Average 6-Minute Opacity: <i>0%</i>		Range of Opacity Readings Min. <i>0%</i> Max. <i>0%</i>		
OBSERVER (please print)				
Name: <i>Don Stone</i>		Title: <i>Engineer</i>		
Signature: <i>Don Stone</i>		Date: <i>7-28-08</i>		
Observer Organization: <i>KSL</i>				
Certified by: <i>ETA</i>		Certification Date: <i>2-27-08</i>		

THIS FORM IS FROM E/AQ-307, R4







LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: LANL ASPHALT PLANT		Observation Date: 8-11-08	Start Time: 1530	End Time: 1536				
Source Location: TA-60 (Sigma Mesa)		Min \ Sec	0	15	30	45	Comments	
Type of Source: Asphalt Plant	Type of Control Equipment: Baghouse							
Describe Emission Point (Top of stack, etc.): Top of shaker stack		1	0	0	0	0		
Height Above Ground Level: 45 Feet	Height Relative to Observer: 45 Feet	2	0	0	0	0		
Distance From Observer: 60 Feet	Direction of Source From Observer: NNW	3	0	0	0	0		
Description of Plume (stack exit only): <input type="checkbox"/> Lofting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present		4	0	0	0	0		
Emission Color: N/A	Plume Type: <input checked="" type="checkbox"/> No Plume Present <input type="checkbox"/> Continuous <input type="checkbox"/> Fugitive <input type="checkbox"/> Intermittent	5	0	0	0	0		
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES IF YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached		6	0	0	0	0		
At what point in the plume was opacity determined? 5ft. above top of stack		7						
Describe Background (i.e. blue sky, trees, etc.): Blue sky		8						
Background Color: Blue	Sky Conditions: Clear	9						
Wind Speed: 5-10 mph	Wind Direction (provide from/to, i.e. from North to South): From SE	10						
Ambient Temperature: 82 °F	Relative Humidity: 31 %	11						
Additional Comments/Information: All emission points clear		12						
<p>SOURCE LAYOUT SKETCH</p> <p>The sketch shows an 'Emission Point' (marked with an X) and an 'OBSERVER'S POSITION' (marked with a dot) connected by a vertical line. A 'SUN LOCATION LINE' is drawn from the observer's position at a 140-degree angle. A legend indicates 'Stack with Plume' (circle with X), 'Sun' (circle with crosshair), and 'Wind' (arrow). A note says 'Draw Arrow in North Direction' with an arrow pointing up.</p>		13						
		14						
		15						
		16						
		17						
		18						
		19						
		20						
Average 6-Minute Opacity: 0%		Range of Opacity Readings Min. 0% Max. 0%						
OBSERVER (please print) Name: Don Stone Title: Engineer								
Signature: Don Stone		Date: 8-11-08						
Observer Organization: KSL								
Certified by: ETA		Certification Date: 2-27-08						


THIS FORM IS FROM EAQ-307, R4

Los Alamos

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: <i>LANL Asphalt Plant</i>		Observation Date: <i>9-26-08</i>	Start Time: <i>0902</i>	End Time: <i>1:00</i>		
Source Location: <i>TA-LW (Sigma Mesa)</i>		Sec	Comments			
Type of Source: <i>Asphalt Plant</i>	Type of Control Equipment: <i>Boothhouse</i>	Min	0	15		
Describe Emission Point (top of stack, etc.): <i>Top of shaker stack</i>		1	0	0		
Height Above Ground Level: <i>45 Feet</i>	Height Relative to Observer: <i>45 Feet</i>	2	0	0		
Distance From Observer: <i>68 Feet</i>	Direction of Source From Observer: <i>NW</i>	3	0	0		
Description of Plume (stack exit only): <input type="checkbox"/> Lifting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Fanning <input type="checkbox"/> Coasting <input checked="" type="checkbox"/> No Plume Present		4	0	0		
Emission Color: <i>N/A</i>	Plume Type: <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Pulsative <input type="checkbox"/> Intermittent	5	0	0		
Water Droplets Present: <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES (droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached)		6	0	0		
At what point in the plume was opacity determined? <i>10 ft above top of stack</i>		7				
Describe Background (i.e. blue sky, trees, etc.): <i>Blue Sky</i>		8				
Background Color: <i>Blue</i>	Sky Conditions: <i>Clear</i>	9				
Wind Speed: <i>2-4 mph</i>	Wind Direction (provide from to, i.e. from North to South): <i>From E</i>	10				
Ambient Temperature: <i>59 °F</i>	Relative Humidity: <i>48%</i>	11				
Additional Comments/Information: <i>All emission points clear</i>		12				
<p>Stack with Plume: </p> <p>Sun: </p> <p>Wind: </p> <p>SOURCE LAYOUT SKETCH</p> <p>Draw Arrow in North Direction</p>  <p>Observer's Position</p> <p>SUN LOCATION LINE</p>		13				
		Average 6-Minute Opacity: <i>0%</i>	Range of Opacity Readings Min: <i>0%</i> Max: <i>0%</i>			
		OBSERVER (please print): Name: <i>Don Stone</i> Title: <i>Engineer</i>				
		Signature: <i>Don Stone</i> Date: <i>9-26-08</i>				
		Observer Organization: <i>KSL</i>				
		Certified by: <i>ETA</i>				
		Certification Date: <i>8-27-08</i>				
				14		
				15		
				16		
		17				
		18				
		19				
		20				

THIS FORM IS FROM EAQ-307, R4



LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name LANL Asphalt Plant		Observation Date 10-7-08	Start Time 1104	End Time 1110
Source Location TA-60 (Sigma Mesa)		Sec	0	15
Type of Source Asphalt Plant, Warehouse		Min	0	45
Description of Emission Point (top of stack, etc.) Top of shaker stack		1	0	0
Height Above Ground Level 45 Feet		2	0	0
Height Relative to Observer 45 Feet		3	0	0
Distance From Observer 60 Feet		4	0	0
Direction of Source From Observer NW		5	0	0
Description of Plume (stack exit only) <input type="checkbox"/> Lifting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Flaring <input type="checkbox"/> Coasting <input checked="" type="checkbox"/> No Plume Present		6	0	0
Emission Color N/A		7		
Plume Type <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Pulsing <input type="checkbox"/> Intermittent		8		
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES IF YES, droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached		9		
At what point in the plume was opacity determined? 2 ft above top of stack		10		
Describe Background (i.e. blue sky, trees, etc.) Blue sky		11		
Background Color Blue		12		
Sky Condition clear		13		
Wind Speed 7-10 mph		14		
Wind Direction (specify from to, i.e. from North to South) From SSE		15		
Ambient Temperature 55 F		16		
Relative Humidity 49%		17		
Additional Comments/Information All emission points clear		18		
		19		
		20		
Stack with Plume		Average 5-Minute Opacity 0%		Range of Opacity Readings Min 0% Max 0%
Sun		OBSERVER (please print) Name: Don Stone Title: Engineer		
Wind		Signature: Don Stone Date: 10-7-08		
SOURCE LAYOUT SKETCH 		Observer Organization: KSL		
		Certified by: ETA Certification Date: 8-27-08		

THIS FORM IS FROM EAQ-307, R4

Los Alamos

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: LANL ASPHALT PLANT		Observation Date: 11-7-08	Start Time: 09:15	End Time: 09:21
Source Address: TA-60 (Sigma Mesa)		Min	Sec	Comment
Type of Source: Asphalt Plant Baghouse	Type of Control Equipment:	1	0000	
Describe Emission Point (top of stack, etc.): Top of Shaker Stack		2	0000	
Height Above Ground Level: 45 Feet	Height Relative to Observer: 45-60 Feet	3	0000	
Distance From Observer: 60 Feet	Direction of Source From Observer: NW	4	0000	
Description of Plume (stack exit only): <input type="checkbox"/> Lifting <input type="checkbox"/> Trapping <input type="checkbox"/> Looping <input type="checkbox"/> Flaring <input type="checkbox"/> Coning <input checked="" type="checkbox"/> No Plume Present		5	0000	
Emission Color: N/A	Plume Type: <input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Pulsative <input type="checkbox"/> Intermittent	6	0000	
Water Droplets Present? <input checked="" type="checkbox"/> NO <input type="checkbox"/> YES. droplet plume is <input type="checkbox"/> Attached <input type="checkbox"/> Detached		7		
At what point in the plume was opacity determined? 2 ft. above top of stack		8		
Describe Background (i.e. blue sky, trees, etc.): Blue sky		9		
Background Color: Blue	Sky Conditions: clear	10		
Wind Speed: 5-10 mph	Wind Direction: provide from to, i.e. from North to South from ENE	11		
Ambient Temperature: 34°F	Relative Humidity: 28%	12		
Additional Comments Information: All emission points clear		13		
Average 6-Minute Opacity: 0%		14		
Range of Opacity Reading: Min 0% Max 0%		15		
OBSERVER (please print): Name: Don Stone Title: Engineer		16		
Signature: Don Stone Date: 11-7-08		17		
Observer Organization: KSL		18		
Certified by: ETA		19		
Certification Date: 8-27-08		20		

SOURCE LAYOUT SKETCH

Stack with Plume:

Sun:

Wind:

Observer's Position: ●

Emission Point: ⊗

SUN LOCATION LINE

40°

Draw Arrow as North Direction


THIS FORM IS FROM EAQ-307, R4



LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (6 MINUTE)

Source Name: LANL Asphalt Plant
 Source Location: TA-60 (Sigma Mesa)
 Type of Source: Asphalt Plant Type of Control Equipment: Baghouse
 Describe Emission Point (top of stack, etc.): Top of Plant stack
 Height Above Ground Level: 45 Feet Height Relative to Observer: 45 Feet
 Distance From Observer: 60 Feet Direction of Source From Observer: NW
 Description of Plume (stack exit only):
 Lofting Trapping Looping Fanning Coiling
 No Plume Present
 Emission Color: N/A Plume Type: No Plume Present
 Continuous Fugitive Intermittent
 Water Droplets Present? NO YES If YES, droplet plume is Attached Detached
 At what point in the plume was opacity determined? 2 ft. above top of stack
 Describe Background (i.e. blue sky, trees, etc.): Blue sky
 Background Color: Blue Sky Conditions: Clear
 Wind Speed: 2-4 mph Wind Direction (provide from to, i.e. from North to South): From N
 Ambient Temperature: 21 °F Relative Humidity: 80 %
 Additional Comments/Information: All emission points clear

Observation Date	Start Time	End Time				
<u>12-5-08</u>	<u>0909</u>	<u>0915</u>				
Sec	0	15	30	45	Comments	
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 6-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%
 OBSERVER (please print):
 Name: Don Stone Title: Engineer
 Signature: Don Stone Date: 12-5-08
 Observer Organization: UEI
 Certified by: ETA Certification Date: 8-27-08

THIS FORM IS FROM EAQ-307, R4

2.2 Beryllium Activities

Source	Monitoring Required
Chemistry and Metallurgy Research Facility TA-3-29	A log shall be maintained during operations which indicates the number of Be samples processed.
Sigma Facility TA-3-66	A log shall be maintained during operations which shows the number of metallographic specimens used in the polishing operation and the weight of Be samples processed in the electroplating/chemical milling, machining, and arc melting/casting operations.
Beryllium Test Facility TA-3-141	Facility exhaust stack will be equipped with a continuous emission monitor used to measure beryllium emissions. Cartridge and HEPA filters will be equipped with differential pressure gauges that measure the differential pressure across the cartridge and HEPA filters while the exhaust fans are in operation.
TA-16-207	Project files shall be maintained of components prepared for testing.
TA-35-87	A log shall be maintained during operations which shows the number of beryllium filters cut.
Target Fabrication Facility TA-35-213	Records of the stack emission test results (see Condition 2 of NSR Permit No. 632) and other data needed to determine total emissions shall be retained at the source and made available for inspection by the Department.
Plutonium Facility TA-55-PF4	The HEPA filtration systems shall be equipped with a differential pressure gauge that measures the differential pressure (inches of water) across the HEPA filters while the exhaust fans are in operation. Control efficiency shall be verified by daily HEPA filter pressure drop tests and annual HEPA filter challenge tests of accessible filters.

Reporting Requirement

Source	Reporting Required
Chemistry and Metallurgy Research Facility TA-3-29	See condition 4.2.
Sigma Facility TA-3-66	See condition 4.2.
Beryllium Test Facility TA-3-141	Anticipated date of initial startup of each new or modified source not less than thirty (30) days prior to the date. Actual date of initial startup of each new or modified source within fifteen (15) days after the startup date. Provide the date when each new or modified emission source reaches the maximum production rate at which it will operate within fifteen (15) days after that date. Notify the Department within 60 days after each calendar quarter of the facility's compliance status with the

	permitted emission rate from the continuous monitoring system. Provide any data generated by activities described in the Quality Assurance Plan (QAP) that will assist the Air Quality Bureau's Enforcement Section in determining the reliability of the methodology used for demonstrating compliance with the permitted emission rate within 45 days of such a request.
TA-16-207	See condition 4.2.
TA-35-87	See condition 4.2.
Target Fabrication Facility TA-35-213	See conditions 4.1 and 4.2.
Plutonium Facility TA-55-PF4	Stack emission test results and facility operating parameters will be made available to Department personnel upon request. Reports may be required to be submitted to the Department if inspections of the source indicate noncompliance with this permit or as a means of determining compliance.

- 4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.
- 4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.

Has this reporting requirement been met during this reporting period with a separate report submittal? Answer Yes or No below.

Yes **Date report submitted:** July 28, 2008 & October 23, 2008 **Tracking Number:** SBR20080007

No **Provide comments and identify any supporting documentation as an attachment.**

Comments:

Chemistry and Metallurgy Research Facility (TA-3-29) – This beryllium source was removed from Operating Permit P100M1 as requested by LANL. A letter from NMED-AQB amending the permit was dated July 16, 2007. This amendment resulted in the assignment of Operating Permit No. P100M2.

Sigma Facility (TA-3-66) - A log is maintained showing the number of metallographic specimens used in the polishing operation. Logs are maintained showing the weight of Be samples processed in the electroplating/chemical milling, machining, and arc melting/casting operations. Logs are available on-site for NMED inspection.

Beryllium Test Facility (TA-3-141) - The BTF is equipped with a continuous emissions monitor to measure beryllium emissions. The monitoring system is operated in accordance with LANL Quality Assurance Project Plans and emission results are provided to NMED quarterly. Submissions for this period were

provided to NMED in reports dated July 28, 2008 and October 23, 2008. Cartridge and HEPA filters are equipped with differential pressure gauges that measure the differential pressure across the cartridge and HEPA filters while the exhaust fans are in operation. No new or modified emission sources were added during this reporting period.

TA-16-207 - Project files are maintained of components prepared for testing. Files are available on-site for NMED inspection.

TA-35-87 - A log is maintained showing the number of beryllium filters cut. The log is available on-site for NMED inspection.

Target Fabrication Facility (TA-35-213) - Records of stack emission test results are maintained on-site and are available for NMED inspection. Stack emission test results are used to determine total emissions from this facility.

Plutonium Facility (TA-55-PF4) - The HEPA filtration systems are equipped with differential pressure gauges that measure the differential pressure across the HEPA filters while the exhaust fans are in operation. Control efficiency is verified by daily HEPA filter pressure drop readings. Readings are recorded in the TA-55 Operations Center. Annual HEPA filter challenge tests of accessible filters are performed. Test results are summarized in **Attachment 2**.

Attachment 2
Beryllium HEPA Filter Tests Results

Summary Table, Reports Attached

Unit	Date	Pass/Fail
TA-55 (H-5-1450) (FF-854)	07/22/2008	Pass
TA-55 (H-5-1460) (FF-855)	07/22/2008	Pass
TA-55 (H-5-5870) (FF-858)	07/22/2008	Pass
TA-55 (H-5-5880) (FF-859)	07/22/2008	Pass

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

12. ATTACHMENT A
300 Area Glovebox Exhaust FF-854 Data Sheet

Date: 07/23/08 (8.4.1) LAS Calibration Expiration Date: 07/23/08 (8.4.3) Diluter Calibration Expiration Date: 09/03/08 (8.4.4) Dilution Ratio: 2091 (8.4.2)

Step No.	Item	FF-854
9.1.12.2	Background concentration (part./cc)	7.062×10^{-3} part concentration
9.1.12.3	Upstream concentration (part./cc)	2.672×10^4 part concentration
9.1.12.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	1.7×10^6 part concentration
9.1.12.5	1 st stage downstream concentration (part./cc)	2.495×10^2 part concentration
9.1.12.6	2 nd /3 rd stage downstream concentration (part./cc)	1.412×10^2 part concentration
9.1.12.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	9.301×10^{-5}
9.1.12.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	2.643×10^{-4}
9.1.13.2 9.1.13.3	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<u>hmt</u> initials <u>PT</u> independent verification

Valve	Required Position	Initials	Independent Verification
HV-854-J	Closed and Locked	<u>hmt</u>	<u>PT</u>
HV-854-G	Closed	<u>hmt</u>	<u>PT</u>
HV-854-H	Closed	<u>hmt</u>	<u>PT</u>
HV-854-D	Closed	<u>hmt</u>	<u>PT</u>
HV-854-C	Closed	<u>hmt</u>	<u>PT</u>
HV-854-B	Closed	<u>hmt</u>	<u>PT</u>
HV-854-A	Closed	<u>hmt</u>	<u>PT</u>
HV-854-AA	Closed	<u>hmt</u>	<u>PT</u>

Comments:

FOR INFORMATION

Surveillance Personnel [Signature] 7/23/08 Date OC On-duty Supervisor [Signature] 7/23/08 Date

Notify CSE that complete and accepted surveillance is available for review.

System Engineer [Signature] 7/25/08 Date
Signature Date

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

14. ATTACHMENT C
300 Area Glovebox Exhaust FF-855 Data Sheet

Date: 07/22/08 (8.4.1) LAS Calibration Expiration Date: 05/21/09 (8.4.3) Diluter Calibration Expiration Date: 09/03/08 (8.4.4) Dilution Ratio: 2.91 (8.4.2)

Step No.	Item	FF-855
9.3.12.2	Background concentration (part./cc)	1.412×10^{-2} part concentration
9.3.12.3	Upstream concentration (part./cc)	2.079×10^6 part concentration
9.3.12.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	<i>mmf</i> Initials
9.3.12.5	1 st stage downstream concentration (part./cc)	5.905×10^1 part concentration
9.3.12.6	2 nd /3 rd stage downstream concentration (part./cc)	1.766×10^2 part concentration
9.3.12.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	2.839×10^{-5}
9.3.12.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	1.649×10^{-9}
9.3.13.2 9.3.13.3	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<i>mmf</i> Initials Independent Verification <i>PT</i>

Valve	Required Position	Initials	Independent Verification
HV-855-J	Closed and Locked	<i>PT</i>	<i>mmf</i>
HV-855-G	Closed	<i>PT</i>	<i>mmf</i>
HV-855-H	Closed	<i>PT</i>	<i>mmf</i>
HV-855-D	Closed	<i>PT</i>	<i>mmf</i>
HV-855-C	Closed	<i>PT</i>	<i>mmf</i>
HV-855-B	Closed	<i>PT</i>	<i>mmf</i>
HV-855-A	Closed	<i>PT</i>	<i>mmf</i>
HV-854-AA	Closed	<i>PT</i>	<i>mmf</i>

Comments:

FOR INFORMATION ONLY

Surveillance Personnel *[Signature]* 7/22/08
Signature Date

OC On-duty Supervisor *[Signature]* 7/23/08
Signature Date

Notify CSE that complete and accepted surveillance is available for review.

System Engineer *[Signature]* 7/25/08
Signature Date

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

13. ATTACHMENT B
300 Area SRL Glovebox Exhaust FF-858 Data Sheet

Date: 7/22/08 (8.4.1) LAS Calibration Expiration Date: 5/31/09 (8.4.3) Diluter Calibration Expiration Date: 9/03/08 (8.4.4) Dilution Ratio: 291 (8.4.2)

Step No.	Item	FF-858
9.2.9.2	Background concentration (part./cc)	2.531×10^{-3} part concentration
9.2.9.3	Upstream concentration (part./cc)	4.832×10^{-2} part concentration
9.2.9.4	Challenge aerosol concentration between 2.00×10^6 and 2.71×10^6 part./cc	<i>hmg</i> part./cc
9.2.9.5	1 st stage downstream concentration (part./cc)	2.811×10^{-1} part concentration
9.2.9.6	2 nd /3 rd stage downstream concentration (part./cc)	1.059×10^{-2} part concentration
9.2.9.7	1 st stage Penetration $\leq 5.0 \times 10^{-4}$ (efficiency $\geq 99.95\%$)	9.923×10^{-4}
9.2.9.8	2 nd /3 rd stage Penetration $\leq 2.5 \times 10^{-7}$ (efficiency $\geq 99.999975\%$)	2.493×10^{-7}
9.2.10.3 9.2.10.4	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<i>hmg</i> initials Independent Verification <i>PT</i>

Valve	Required Position	Initials	Independent Verification
HV-858-8	Closed	<i>PT</i>	<i>hmg</i>
HV-858-7	Closed	<i>PT</i>	<i>hmg</i>
HV-858-5	Closed	<i>PT</i>	<i>hmg</i>
HV-858-3	Closed	<i>PT</i>	<i>hmg</i>
HV-858-2	Closed	<i>PT</i>	<i>hmg</i>
HV-858-1	Closed	<i>PT</i>	<i>hmg</i>
HV-854-AA	Closed	<i>PT</i>	<i>hmg</i>

Comments:

FOR INFORMATION ONLY

Surveillance Personnel: *[Signature]* Signature 7/23/08 Date OC On-duty Supervisor: *[Signature]* Signature 7/23/08 Date

Notify CSE that complete and accepted surveillance is available for review.

System Engineer: *[Signature]* Signature 7/25/08 Date

300 AREA GLOVEBOX EXHAUST IN-PLACE HEPA FILTER TESTING

15. ATTACHMENT D
300 Area SRL Glovebox Exhaust FF-859 Data Sheet

Date: 07/23/08 (8.4.1) LAS Calibration Expiration Date: 5/21/09 (8.4.3) Diluter Calibration Expiration Date: 9/3/08 (8.4.4) Dilution Ratio: 20/1 (8.4.2)

Step No.	Item	FF-859
9.4.9.2	Background concentration (part./cc)	7.062 x 10 ⁻⁵ <small>part. concentration</small>
9.4.9.3	Upstream concentration (part./cc)	2.500 x 10 ⁶ <small>part. concentration</small>
9.4.9.4	Challenge aerosol concentration between 2.00 x 10 ⁶ and 2.71 x 10 ⁶ part./cc	<i>mmf</i> <small>initials</small>
9.4.9.5	1 st stage downstream concentration (part./cc)	4.901 x 10 ¹ <small>part. concentration</small>
9.4.9.6	2 nd /3 rd stage downstream concentration (part./cc)	1.412 x 10 ⁻² <small>part. concentration</small>
9.4.9.7	1 st stage Penetration ≤ 5.0 x 10 ⁻⁴ (efficiency ≥ 99.95%)	1.920 x 10 ⁻⁵
9.4.9.8	2 nd /3 rd stage Penetration ≤ 2.5 x 10 ⁻⁷ (efficiency ≥ 99.999975%)	2.825 x 10 ⁻⁹
9.4.10.3 9.4.10.4	Ensure all test port ball valves are closed; (FF-858-FH1, FF-859-FH1, TP-858-2, TP-855-2, TP-854-2, TP-859-2, TP-854-3, TP-855-3, TP-855-1, TP-854-1)	<i>mmf</i> Initials Independent Verification <i>PT</i>

Valve	Required Position	Initials	Independent Verification
HV-859-8	Closed	<i>PT</i>	<i>mmf</i>
HV-859-7	Closed	<i>PT</i>	<i>mmf</i>
HV-859-5	Closed	<i>PT</i>	<i>mmf</i>
HV-859-3	Closed	<i>PT</i>	<i>mmf</i>
HV-859-2	Closed	<i>PT</i>	<i>mmf</i>
HV-859-1	Closed	<i>PT</i>	<i>mmf</i>
HV-854-AA	Closed	<i>PT</i>	<i>mmf</i>

Comments:

FOR INFORMATION ONLY

Surveillance Personnel: *[Signature]* 7/23/08 Date
OC On-duty Supervisor: *[Signature]* 7/23/08 Date

Notify CSE that complete and accepted surveillance is available for review.

System Engineer: *[Signature]* 7/23/08 Date

2.3 Boilers and Heaters

2.3.4 Emissions Monitoring Requirements

2.3.4.1 Emission units TA-21-357-1, TA-21-357-2, and TA-21-357-3: A volumetric flow meter shall be utilized to measure the total amount of natural gas being used on a monthly basis.

2.3.4.2 Emission units TA-55-6-BHW-1 and TA-55-6-BHW-2: A volumetric flow meter shall be utilized to measure the total amount of natural gas being used on a monthly basis.

2.3.4.3 40 CFR Part 60, Appendix A, Method 9 shall be used to determine compliance with the opacity limitation.

Reporting Requirement

2.3.6 Reports shall be submitted in accordance with conditions 4.1 and 4.2.

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.

Has this reporting requirement been met during this reporting period with a separate report submittal? Answer Yes or No below.

Yes **Date report submitted:** **Tracking Number:**

No **Provide comments and identify any supporting documentation as an attachment.**

Comments:

2.3.4.1 The TA-21 Steam Plant was officially and permanently shut-down as of September 28, 2007. This information was communicated to NMED in a letter dated October 16, 2007.

2.3.4.2 Volumetric flow meters are utilized to measure the total amount of natural gas being used by units TA-55-6-BHW-1 and TA-55-6-BHW-2 on a monthly basis. Natural gas usage is summarized in **Attachment 3**.

2.3.4.3 LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine compliance with the opacity limitation.

Attachment 3 Boilers and Heaters Natural Gas Usage

2008 Small Boilers Data Entry / Gas Use

Month	Metered Boilers			Total Gas Use ^(a)		Non-Metered Gas Use	12-Month Rolling Total for all Small Boilers (MMSCF) ^(e)
	TA-55 Boiler Gas Use (MSCF) ^(c)		TA-50-2 ^(d) (MSCF)	(MSCF)	(MMSCF)	(MMSCF)	
	BHW-1B (B-602)	BHW-2B (B-603)	BS-1				
January	3441	2		84,295	84.30	80.65	504.57
February	2075	8		65,798	65.80	63.52	504.27
March	1786	2		58,027	58.03	56.04	507.94
April	1175	951		40,942	40.94	38.62	504.67
May	528	989		28,334	28.33	26.62	503.54
June	0	1210	1192.4	17,402	17.40	15.99	507.41
July	1	1312		14,028	14.03	12.62	507.75
August	35	912		15,039	15.04	14.00	514.00
September	644	763		21,266	21.27	19.76	515.57
October	552	1055		37,850	37.85	36.15	516.91
November	1633	10		58,166	58.17	56.43	520.86
December	3140	2	578.1	74,982	74.98	71.74	516.13
TOTAL	15010	7216	1770.5	516,129	516.13	492.13	Permit Limit = 870

2008 Non Metered Boiler Pool Capacity: **305.1** MMBTU/hr^(f)

Estimated Gas-Use per MMBtu rating Jan-June: 0.92 MMscf/MMBtu/hr
 Estimated Gas-Use per MMBtu rating July-Dec: 0.69 MMscf/MMBtu/hr
 Estimated Gas-Use per MMBtu - Annual: 1.61 MMscf/MMBtu/hr

Definitions: MMSCF= Million Standard Cubic Feet
 MSCF = Thousand Standard Cubic Feet
 Metered/Non-metered: Metered boilers are those units that have unit specific volumetric flow meters for the boiler(s) only.

Gas Use Non-Metered ^(g) (MMSCF)									
AIRS Stack #	015	016	017	018	019	020	021	024	Units ^(h)
Location:	TA-48-1	TA-48-1	TA-48-1	TA-53-365	TA-53-365	TA-59-1	TA-59-1	TA-16-1484	Lab Wide
ID:	BS-1	BS-2	BS-6	BHW-1	BHW-2	BHW-1	BHW-2	Plant 5	Various
Design Rate ⁽ⁱ⁾ (MMBTU/hr)	5.336	5.335	7.140	7.115	7.115	5.335	5.335	12.700	250
Calculated Gas Use-Jan-June	4.922	4.922	6.586	6.563	6.563	4.922	4.922	11.715	230.324
Calculated Gas Use-July-Dec	3.685	3.685	4.931	4.913	4.913	3.685	3.685	8.770	172.428
Calculated Gas Use-Annual	8.608	8.606	11.517	11.476	11.476	8.606	8.606	20.485	402.752

2.4 Carpenter Shops

2.4.4 Emissions Monitoring

2.4.4.1 The permittee shall maintain logs of the hours the carpenter shops are in operation.

Reporting Requirement

2.4.6 Reports shall be submitted in accordance with conditions 4.1 and 4.2.

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.

Has this reporting requirement been met during this reporting period with a separate report submittal? Answer Yes or No below.

Yes

Date report submitted:

Tracking Number:

No

Provide comments and identify any supporting documentation as an attachment.

Comments:

2.4.4.1 A log is maintained of the hours of operation for each of the permitted carpenter shops. Hour readings are collected and recorded monthly from hour meters installed on each of the cyclone separators. Hours of operation are provided in **Attachment 4**.

**Attachment 4
Carpenter Shop Hours of Operation**

2008 TA-3 & TA-15 Carpenter Shops

TA-3	Data Entry	TA-3	Data Entry
Month	Hours of Operation ¹	Month	Hours of Operation ¹
	TA-3		TA-3
January	1.7	July	1.9
February	1.0	August	1.1
March	1.1	September	17.4
April	3.3	October	4.8
May	6.0	November	6.4
June	3.7	December	1.7
6 mo. Total	16.8	6 mo. Total:	33.3

TA-15	Data Entry	TA-15	Data Entry
Month	Hours of Operation ¹	Month	Hours of Operation ¹
	TA-15		TA-15
January	7.6	July	12.4
February	9.8	August	14.5
March	8.3	September	9.4
April	14.4	October	8.6
May	5.2	November	7.1
June	6.4	December	6.4
6 mo. Total	51.7	6 mo. Total:	58.4

Saws, drills, shaping and sanding equipment shall each not operate in excess of 4368 hours per year.

Reference
1. Based on information provided monthly by the shop foreman from each shop.

Attachment 5
Degreaser Solvent Usage

General Degreaser Information

Degreaser	Type	TA	Solvent		
TA-55-DG-1	Cold Batch	55	Trichloroethylene		

Date Measured	Initial Solvent Level (inches)	Volume Added (liters)	Level Added (inches)	Volume Removed (liters)	Level Removed (inches)
Jul-31-2008	7.50	0.00	0.00	14.74	7.50
Aug-05-2008	0.00	14.74	7.50	0.00	0.00
Aug-28-2008	7.25	1.00	0.50	0.00	0.00
Sep-24-2008	7.50	0.00	0.00	0.00	0.00
Oct-21-2008	7.25	1.00	0.50	14.50	7.37
Oct-27-2008	0.00	15.38	7.83	0.00	0.00
Nov-03-2008	7.83	0.00	0.00	0.63	0.33
Nov-24-2008	7.50	0.00	0.00	0.00	0.00
Dec-22-2008	7.00	0.00	0.00	0.00	0.00

2.7 Internal Combustion Sources

2.7.4 Emissions Monitoring Requirements

Source	Monitoring Required
Stationary Standby Generators	Track and record hours of operation for stationary standby generators on a semi-annual basis.
TA-33-G-1	Track hourly and 12-month rolling total kWh. Record hours of operation and the time operation begins and ends each day.

2.7.4.1 40 CFR Part 60, Appendix A, Method 9 shall be used to determine compliance with the opacity limitation.

Reporting Requirement

2.7.6 Reports shall be submitted in accordance with conditions 4.1 and 4.2.

4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.

4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.

Has this reporting requirement been met during this reporting period with a separate report submittal? Answer Yes or No below.

Yes **Date report submitted:** _____ **Tracking Number:** _____

No **Provide comments and identify any supporting documentation as an attachment.**

Comments:

2.7.4 (Stationary Standby Generators) - LANL tracks and records generator hours of operation on a semi-annual basis. Stationary generator hours of operation for this reporting period are provided in **Attachment 6**.

2.7.4 (TA-33-G-1) - NSR Air Quality Permit 2195-F-R3 was issued on May 28, 2008. This revision included a change to the kilowatt-hour (kWh) monitoring for the generator. The new condition, 4.a., reads: "The permittee shall record the kilowatt-hours produced by Unit TA-33-G-1 on a daily basis and on a monthly rolling 12-month total basis." A kWh tracking form is used for tracking generator start and stop times as well as daily kWh. These daily readings are used in tracking the 12-month rolling kWh total. This change has also been requested as part of our Operating Permit Renewal Application submitted in April 2008. The hours of operation for all permitted units are also included in **Attachment 6**.

2.7.4.1 LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine opacity compliance.

Attachment 6 Internal Combustion Generator Hours of Operation

2008 Generator Hours

TA	Bldg	Manufacturer	MODEL	KW	Fuel Type	Previous Reading Date	Previous Reading	First 6 Month Readings			Second 6 Month Readings		
								6 Month Reading Date	Reading	Hours Run	12 Month Reading Date	Reading	Hours Run
3	40	Onan Sons	1500DVE15R31374B	150	Diesel	Dec-08	6.6	Jun-08	11.8	5.2	Dec-08	12.8	1
3	223	Onan Sons	45.OEM-15R/10742D	45	Propane	Dec-08	489.5	Jun-08	492.5	3.0	Dec-08	492.5	0
3	440	Cummins	500FDR5051	260	Diesel	Dec-08	121.8	Jun-08	121.8	0.0	Dec-08	121.8	0
3	440	Cummins	DFGA-5005210	500	Diesel	Dec-08	81.8	Jun-08	93.8	12.0	Dec-08	99.9	6.1
3	1076	Cummins	DGDB-5601289	35	Diesel	Dec-08	129.7	Jun-08	141.2	11.5	Dec-08	181.1	39.9
3	1400	Cummins	DFEH-5699616	400	Diesel	Dec-08	33.0	Jun-08	37	4.0	Dec-08	44	7
3	1404	Cummins	DFLC-5554001	1250	Diesel	Dec-08	336.5	Jun-08	368.4	31.9	Dec-08	393.5	25.1
3	1498	Caterpillar	SR-4	600	Diesel	Dec-08	326.0	Jun-08	331.0	5.0	Dec-08	337	6
3	2322	Onan Sons	DGDA-5005757	80	Diesel	Dec-08	339.8	Jun-08	352	12.2	Dec-08	358.6	6.6
16	980	Cummins	KTA50-G2	1100	Diesel	Dec-08	293.4	Jun-08	305.2	11.8	Dec-08	318.6	13.4
16	1374	Onan Sons	60ENA	60	Nat. Gas	Dec-08	1092.9	Jun-08	1115.8	22.9	Dec-08	1125	9.2
18	31	Onan Sons	275DFML29807N	275	Diesel	Dec-08	180.8	Jun-08	180.8	0.0	Dec-08	180.8	0
35	2	Onan Sons	100DGDB	100	Diesel	Dec-08	115.5	Jun-08	115.5	0.0	Dec-08	115.5	0
35	402	Cummins	DGCB-5674244	60	Diesel	Dec-08	138.4	Jun-08	158.0	19.6	Dec-08	175	17
43	1	Cummins	4BT3.9-GC	50	Diesel	Dec-08	383.9	Jun-08	387.7	3.8	Dec-08	392.9	5.2
43	1	Onan Sons	DVE	150	Diesel	Dec-08	620.0	Jun-08	644.4	24.4	Dec-08	671.9	27.5
46	335	Onan Sons	300DFCB	300	Diesel	Dec-08	959.5	Jun-08	995.4	35.9	Dec-08	1020	24.6
48	45	Onan Sons	DFCB-5740130	300	Diesel	Dec-08	53.5	Jun-08	69.5	16.0	Dec-08	78.5	9
50	37	Cummins	680FDR5059FF	500	Diesel	Dec-08	502.9	Jun-08	502.9	0.0	Dec-08	502.9	0
50	184	Onan Sons	DGFA-568741	150	Diesel	Dec-08	212.7	Jun-08	238.6	25.9	Dec-08	256	17.4
50	188	Onan Sons	L940563879	1250	Diesel	Dec-08	149.0	Jun-08	149.0	0.0	Dec-08	149	0
53	1	Onan Sons	60ENA	60	Nat. Gas	Dec-08	1234.1	Jun-08	1261.2	27.1	Dec-08	1271	9.8
53	2	Kato Eng.	Kamag-14	50	Diesel	Dec-08	194.3	Jun-08	194.3	0.0	Dec-08	194.6	0.3
53	3N	Onan	15.0JC-18R	15	Propane	Jun-08	345.3	Jun-08	345.3	0.0	Dec-08	362.3	17
54	412	Olympian	95M-07874-F	500	Diesel	Dec-08	317.9	Jun-08	324.7	6.8	Dec-08	331.7	7
55	5	Kohler	100RZ71	100	Propane	Dec-08	79.3	Jun-08	93.4	14.1	Dec-08	98.3	4.9
55	8	Delco/Detroit	E7014DD	600	Diesel	Dec-08	822.2	Jun-08	831.8	9.6	Dec-08	840.6	8.8
55	364	Onan Sons	1250DFLC-4987	1250	Diesel	Dec-08	82.8	Jun-08	101.3	18.5	Dec-08	134.3	33
55	28	Onan Sons	40DL6T	40	Diesel	Dec-08	66.5	Jul-08	72.4	5.9	Dec-08	84.6	12.2
55	47	Onan Sons	1465	200	Diesel	Dec-08	540.0	Jul-08	555.5	15.5	Dec-08	589	33.5
55	142	Cummins	DFEB-4963414	400	Diesel	Dec-08	105.0	Jul-08	114.8	9.8	Dec-08	122.1	7.3
59	1	Allis Chalmers	2884-0703	90	Diesel	Dec-08	750.0	Jul-08	750.0	0.0	Dec-08	750	0
60	yard	Cummins	DFHD-4964979	1000	Diesel	Dec-08	648.4	Jun-08	649.4	1.0	Dec-08	650	0.6
63	93	Murphy	3166-0084	30	Diesel	Dec-08	716.0	Jul-08	716.0	0.0	Dec-08	716	0
64	1	Onan Sons	250DVG	250	Diesel	Dec-08	166.9	Jul-08	171.8	4.9	Dec-08	178	6.2
69	33	Cummins	DFLC-5568730	1250	Diesel	Dec-08	71.3	Jul-08	78.6	7.3	Dec-08	85	6.4
36 Generators in use								TOTAL			TOTAL		
								365.6			362.0		

N/R = Not Read

First half average hours per unit	10.2	Second half average hours per unit	10.1
-----------------------------------	------	------------------------------------	------

Annual Average of hours per unit	10.1
----------------------------------	------

Permitted Generators							First Half 2008			Second Half 2008			* Total Run Hours		
TA	Bldg	Manufacturer	Serial #	MODEL	KW	Fuel Type	Reading 2nd half of previous year	6 Month Reading Date	Reading	Hours Run	12 Month Reading Date	Reading		Hours Run	
33	290	Kohler	375801	1600ROZD	1600	Diesel	Dec. 07	9.3	Jun-08	25.9	16.6	Dec-08	34.3	8.4	25.0
33	151	Caterpillar	6PK01065	XQ225	225	Diesel	Jan. 08	3253.0	Jun-08	3253.0	0.0	Dec-08	3307.0	54	54.0
33	209	Kohler	2025460	20EORZ	20	Diesel	Dec. 07	383.5	Jul-08	383.5	0.0	Dec-08	384.1	0.6	0.6
33	114	Kohler	2025461	20EORZ	20	Diesel	Dec. 07	155.2	Jun-08	175.0	19.8	Dec-08	175.9	0.9	20.7

* The 225 kW and the two 20 kW generators have a limit of 500 hours of operation per year. The 1600 kW unit is limited to 900 hours per year.

**Attachment 7
Data Disintegrator Box Throughput**

2008 TA-52 Data Disintegrator

Data Entry		Data Entry	
Month	Boxes ^(c) Shredded	Month	Boxes ^(c) Shredded
January	876	July	810
February	761	August	1329
March	840	September	132
April	657	October	382
May	837	November	131
June	567	December	60
6 mo. Total:	4,538	6 mo. Total:	2,844
Annual Boxes:		7,382	

2.9 Power Plant at Technical Area 3 (TA-3-22)

- 2.9.4.1 Total fuel oil consumption shall be monitored so that combined fuel oil usage of Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 can be calculated on a rolling 365-day total. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.a.
- 2.9.4.2 Natural gas consumption shall be monitored so that combined natural gas usage of Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 can be calculated on a rolling 365-day total. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.b.
- 2.9.4.3 Natural gas consumption shall be monitored so that natural gas usage for Unit TA-3-22 CT-1 can be calculated on a rolling 365-day total. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.f.
- 2.9.4.4 A certification of total sulfur content of the No. 2 fuel oil used by Units TA-3-22-1, TA-3-22-2 and TA-3-22-3 shall be obtained from the supplier whenever No. 2 fuel oil is delivered to the facility. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.c.
- 2.9.4.5 If the certification as specified by Condition 2.9.4.4 is not available at delivery, the permittee shall analyze the No. 2 fuel oil to determine the total sulfur content. The analysis shall be conducted using Department approved methods and standards for determining total sulfur content of No. 2 fuel oil. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.d.
- 2.9.4.6 The operating load of Unit TA-3-22 CT-1 specified by Condition 2.9.3.7 shall be monitored and recorded hourly during normal operations of that unit. Periods of startup and shutdown shall not be included in the hourly monitoring but shall be recorded separately. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.e.
- 2.9.4.7 Compliance with NO_x pound per hour emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the daily total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.1029 pounds NO_x per thousand SCF of gas burned (applicable for worst-case conditions of negative 18 degrees Fahrenheit) and divided by the number of hours of operation of the unit during that day as recorded pursuant to Condition 2.9.3.8. Compliance with NO_x annual emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the 365 day total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.1029 pounds NO_x per thousand SCF of gas burned (applicable for annual average conditions of 47.9 degrees Fahrenheit). This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.g.
- 2.9.4.8 Compliance with CO pound per hour emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the daily total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.731 pounds CO per thousand SCF of gas burned (applicable for worst-case conditions of negative 18 degrees Fahrenheit), and divided by the number of hours of operation of the unit during that day as recorded pursuant to Condition 2.9.3.8). Compliance with CO annual emission limits for Unit TA-3-22 CT-1 shall be determined by multiplying the 365 day total natural gas firing rate for the unit (expressed in thousands of SCF), as recorded pursuant to Condition 2.9.5.3, by the manufacturer's guaranteed emission rate of 0.0613 pounds CO per thousand SCF of gas burned (applicable for annual average conditions of 47.9 degrees Fahrenheit). This condition was brought forward from NSR Permit No.

2195BM1, Condition 3.h.

- 2.9.4.9 At least once each calendar quarter the permittee shall use the method specified in Conditions 2.9.4.7 and 2.9.4.8 to determine compliance of Unit TA-3-22 CT-1 with the hourly and annual emission limits specified in this permit. This condition was brought forward from NSR Permit No. 2195BM1, Condition 3.i.
- 2.9.4.10 Visible emissions from stationary combustion equipment shall not equal or exceed an opacity of 20%. Use of pipeline quality natural gas fuel as defined in Conditions 2.9.3.1 and 2.9.3.4 constitutes compliance with 20.2.61 NMAC unless opacity exceeds 20%. At such time as No. 2 fuel oil as defined in Condition 2.9.3.1 is used, opacity shall be measured in accordance with the procedures at 40 CFR 60, Appendix A, Method 9. Opacity measurements shall continue on a quarterly basis per calendar year for each effected unit until such time as pipeline quality natural gas is used. This condition is pursuant to 20.2.61 NMAC and NSR Permit No. 2195BM1, Condition 2.c.
- 2.9.4.11 Initial compliance tests are required on Unit TA-3-22 CT-1 for NO_x and CO. These tests shall be conducted within sixty (60) days after the unit achieves the maximum normal production. If the maximum normal production rate does not occur within one hundred twenty (120) days of source startup, then the tests must be conducted no later than one hundred eighty (180) days after initial startup of the source. The tests shall be conducted in accordance with EPA Reference Methods 1 through 4, Method 7E for NO_x, and Method 10 for CO contained in CFR Title 40, Part 60, Appendix A, and with the requirements of Subpart A, General Provisions, 60.8(f). Alternative test method(s) may be used if the Department approves the change. The permittee shall submit a testing protocol to the Department at least thirty (30) days prior to the test date, and provide notification to the Department at least thirty (30) days prior to the test date. This condition was brought forward from NSR Permit No. 2195BM1, Condition 6.b and General Condition 13.
- 2.9.4.12 The permittee shall comply with fuel sulfur monitoring requirements at 40 CFR 60.334(h) applicable to Unit TA-3-22 CT-1 by making the required demonstration which shows the fuel combusted in the turbine meets the definition of natural gas at 40 CFR 60.331(u).

The conditions of Section 2.9.4 are pursuant to 20.2.70.302.C NMAC.

Reporting Requirement

- 2.9.6 Reports shall be submitted in accordance with conditions 4.1 and 4.2.

This condition is pursuant to 20.2.60.302.E NMAC.

- 4.1 Reports of actual emissions from permitted sources in Section 2.0 shall be submitted on a 6 month basis. Reports shall not include emissions from insignificant activities. Emission estimates of criteria pollutants NO_x, CO, SO₂, PM and VOCs shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits specified in Section 2.10 of this permit.
- 4.2 Reports of all required monitoring activities shall be submitted on a semiannual basis. All instances of deviation from permit requirements, including emergencies, shall be clearly identified in these reports. The conditions of 4.1 and 4.2 are pursuant to 20.2.70.302.E.1 NMAC.

Has this reporting requirement been met during this reporting period with a separate report submittal? Answer Yes or No below.

Date report submitted:

Tracking Number:

Provide comments and identify any supporting documentation as an attachment.

Comments:

- 2.9.4.1 Total fuel oil consumption is monitored on a daily basis. These daily readings are used to calculate a 365-day rolling total. **Attachment 8** contains a summary of monthly fuel oil consumption. Records of daily fuel oil use are available on-site for NMED inspection.
- 2.9.4.2 A volumetric flow meter is used to measure the total amount of natural gas used on a daily basis. These daily readings are used to calculate a 365-day rolling total. **Attachment 8** contains a summary of monthly natural gas usage. Daily totals are available on-site for NMED inspection.
- 2.9.4.3 The Combustion Turbine started operation on September 23, 2007. A monthly gas consumption report, containing daily turbine gas use, is generated by the plant operator. This data is used to calculate a rolling 365-day total. See **Attachment 9** for the daily and rolling 365-day totals.
- 2.9.4.4 No fuel oil was purchased or delivered during this reporting period.
- 2.9.4.5 No fuel oil was purchased or delivered during this reporting period.
- 2.9.4.6 A tracking log was created that contains the hours of start-up, normal operation, shut-down, and the hourly operating load during normal operation. The tracking logs are available on-site for NMED inspection.
- 2.9.4.7 An emission spreadsheet, containing the calculation found in this permit condition, is used to calculate the NO_x pound per hour (pph) and ton per year (tpy) emission rates. This data is compared with the permit emission limits listed in permit condition 2.9.2. On October 22 and October 23, 2008, the static emission factor and calculation in this condition resulted in a deviation. LANL has been working with the NMED-AQB permitting group to modify the permit to remove this condition and replace it with a condition that represents actual emissions. It was agreed that the current emission factor and calculation in this condition do not provide a reasonable estimate of emissions from the combustion turbine. Using an emission factor derived from data in the initial compliance test, conducted on October 5, 2007, emissions for the two days were determined to be much lower than the 23.8 pph permit limit. For October 22nd, using the compliance test emission factor resulted in 11.9 pph, as compared to the calculation in this permit condition which resulted in 24.3 pph. For October 23rd, the compliance test emission factor resulted in 12.5 pph, as compared to 25.4 pph using the calculation in this permit condition. By using the compliance test data, which contains actual emission results, no excess emission occurred. The permit modification request submitted to NMED consists of replacing the calculation in this permit condition with an annual emission test.
- 2.9.4.8 An emission spreadsheet, containing the calculation found in this permit condition, is used to calculate the CO pound per hour (pph) and ton per year (tpy) emission rates. This data is compared with the permit emission limits listed in permit condition 2.9.2. On October 22 and October 23, 2008, the static emission factor and calculation in this condition resulted in a deviation. LANL has been working with the NMED-AQB permitting group to modify the permit to remove this condition and replace it with a condition that represents actual

emissions. It was agreed that the current emission factor and calculation in this condition do not provide a reasonable estimate of emissions from the combustion turbine. Using an emission factor derived from data in the initial compliance test, conducted on October 5, 2007, emissions for the two days were determined to be much lower than the 170.9 pph permit limit. For October 22nd, using the compliance test emission factor resulted in 2.5 pph, as compared to the calculation in this permit condition which resulted in 173 pph. For October 23rd, the compliance test emission factor resulted in 2.6 pph, as compared to 180 pph using the calculation in this permit condition. By using the compliance test data, which contains actual emission results, no excess emission occurred. The permit modification request submitted to NMED consists of replacing the calculation in this permit condition with an annual emission test.

- 2.9.4.9 Daily gas use data is entered into the above mentioned spreadsheet at least once each calendar quarter. The spreadsheet uses the required calculation to provide both NO_x and CO hourly and annual emissions.
- 2.9.4.10 LANL uses 40 CFR Part 60, Appendix A, Method 9 to determine compliance with the opacity limitation. Delivery of pipeline quality natural gas is specified in the transportation contract with the supplier. Opacity measurements performed at the Power Plant are provided in **Attachment 10**.
- 2.9.4.11 An initial compliance test was performed on the combustion turbine within 60 days following the unit achieving maximum normal production. The unit achieved its maximum normal production rate on September 27, 2007, and the compliance test was performed on October 5, 2007. The test report was provided to NMED on October 22, 2007. The test consisted of the EPA test methods identified in this permit condition.
- 2.9.4.12 The natural gas used by the combustion turbine meets the definition of natural gas in 60.331(u). The sulfur monitoring requirement is met under 40 CFR 60.334(h)(3)(i), which allows the use of a current and valid transportation contract that specifies the maximum total sulfur content is 20 grains per 100 scf or less. The transportation contract specifies a sulfur content not to exceed 2 grains of total sulfur per 100 scf. A copy of the transportation contract is available at the facility.

**Attachment 8
Power Plant Natural Gas and Fuel Oil Usage**

TA-3 Power Plant Fuel Use Totals 2008 (Data Entry)

DATA ENTRY								
	TA-3-22 Power Plant^d Boiler # 1 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant^d Boiler # 2 (Edgemoor Iron Works, 210 MMBTU/hr)		TA-3-22 Power Plant^d Boiler # 3 (Union Iron Works, 210 MMBTU/hr)		Monthly Totals	
Month	Natural Gas (MCF)^a	Fuel Oil (gallons)^a	Natural Gas (MCF)^a	Fuel Oil (gallons)^a	Natural Gas (MCF)^a	Fuel Oil (gallons)^a	Natural Gas (MMCF)^a	Fuel Oil (gallons)^a
January	6,912	328	63,171	0	1,108	0	71.191	328
February	19,497	493	34,960	0	3,618	0	58.075	493
March	617	603	50,578	0	866	384	52.061	987
April	0	0	37,023	219	4,276	0	41.299	219
May	0	0	23,792	0	7,242	331	31.034	331
June	148	55	11,048	0	9,920	0	21.116	55
July	9,607	55	11,565	0	1,085	0	22.257	55
August	568	0	14,574	0	23	0	15.165	0
September	219	55	20,859	0	394	40	21.472	95
October	49	164	12,359	0	23,640	0	36.048	164
November	129	0	26,123	212	21,713	0	47.965	212
December	8,068	0	1,813	0	57,018	0	66.899	0
Annual Totals:	45,814	1,753	307,865	431	130,903	755	484.582	2939
Jan. - June	27,174	1,479	220,572	219	27,030	715	274.776	2413
July - Dec.	18,640	274	87,293	212	103,873	40	209.806	526

Month	12-Mo. Rolling Total Natural Gas (MMscf)	12-Mo. Rolling Total Fuel Oil (gallons)
January	447.5	83343
February	446.5	83489
March	446.9	83420
April	446.2	83036
May	442.6	4903
June	463.7	4958
July	485.9	5013
August	485.7	5013
September	481.4	4670
October	480.0	4012
November	482.2	3652
December	484.6	2939

Permit Limits:	2000 MMscf	500,000 gallons
-----------------------	-------------------	------------------------

Attachment 9
Daily and Rolling 365-Day Gas Use Totals

2008 Daily Turbine Gas Use (MCF), 365 Day Rolling Total Gas Use, & Hours of Operation																								
Day	Jan		Feb		Mar		Apr		May		Jun		Jul		Aug		Sep		Oct		Nov		Dec	
	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs	Gas Use	Hrs
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0	0	33	0.7	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	42	1	0	0	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	70	0.75	0	0	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	8	0.75	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	6	0.6	0	0	0	0	0	0	4	0.75	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	16	1.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.5	0	0
9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.5	0	0
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	110	2.5	0	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0	0	178	1.2	0	0	0	0	0	0	0	0	103	1.75
18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0	0	301	2.3	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	11	0.75	0	0	0	0	0	1889	8.7
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5409	24
22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5430	23
23	7	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2468	10
24	3	1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	1
25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8	0.67	0	0	0	0	0	0	0
28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SUM	10	2.5	0	0	29	2.35	0	0	115	3	413	4.05	255	3.35	19	1.42	0	0	15984	79.5	0	0	0	0
Rolling Gas Use (MSCF)	First Half Gas Use: 567		MCF Second Half Gas Use: 16258		MCF 6947 Apr. 6947 May 6947		MCF 16258		MCF 6482 June 6875		Annual Gas Use: 16825		MCF 16825		MCF 16825		MCF 16825		MCF 16825		MCF 16825		MCF 16825	

The SCFH value (fuel flow rate) in the cell equation is from the compliance test report (223620 SCFH or 223.6 MSCFH) or 646,000 MSCF

Attachment 10
Power Plant Opacity Reports

Summary Table, Reports Attached

Source	Date	Time	Average Opacity ^(a)
TA-3 Power Plant	07-17-08	12:07 pm	1.5%
	August 2008	N/A	^(b)
	09-11-08	12:28 pm	0%
	10-09-08	10:20 am	0%
	11-20-08	10:30 am	0%
	December 2008	N/A	^(b)

- (a) Average opacity for the Power Plant is the sum of the highest consecutive 40 readings divided by 40 (10 minutes of readings). The method is in accordance with EPA Method 9 and 20.2.61 NMAC.
- (b) There were no visible emission observations taken in August and December. No fuel oil was used during these months.

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: *Power Plant at TA-3*

Source Location: *TA-3-22*

Type of Source: *Boiler #1* Type of Control Equipment: *No Particulate Control*

Describe Emission Point (Top of stack, etc.): *Top of boiler #1 stack*

Height Above Ground Level: *150* Feet Height Relative to Observer: *160* Feet

Distance From Observer: *200* Feet Direction of Source From Observer: *NW*

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: *Black* Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
1 ft above top of stack

Describe Background (i.e. blue sky, trees, etc.): *Blue sky*


Background Color: *Blue* Sky Conditions: *Partly cloudy*

Wind Speed: *4-6* mph Wind Direction: *From ESE*
 (provide from/to, i.e. from North to South)

Ambient Temperature: *75* °F Relative Humidity: *44* %

Additional Comments/Information:
Fuel Oil burn exercise

Observation Date		Start Time				End Time
7-17-08		1207				1217
Min	Sec	0	15	30	45	Comments
1	0	10	20	25		
2	5	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: *1.50*

Range of Opacity Readings
 Min. *0*% Max. *25*%

OBSERVER (please print)
 Name: *Don Stone* Title: *Engineer*

Signature: *Don Stone* Date: *7-17-08*

Observer Organization: *KSL*

Certified by: *ETA* Certification Date: *2-29-08*

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: LANL Power Plant

Source Location: TA-3-22

Type of Source: Boiler #1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): Top of Boiler #1 stack

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NNE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: N/A Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
2 ft above top of stack

Describe Background (i.e. blue sky, trees, etc.): Gray sky


Background Color: Gray Sky Conditions: cloudy

Wind Speed: 2-4 mph Wind Direction: From NE
 (provide from/to, i.e. from North to South)

Ambient Temperature: 66 °F Relative Humidity: 43 %

Additional Comments/Information:
Fuel Oil burn exercises

Observation Date		Start Time				End Time
9-11-08		1228				1238
Min	Sec	0	15	30	45	Comments
	1		0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print)
 Name: Don Stone Title: Engineer
 Signature: Don Stone Date: 9-11-08
 Observer Organization: KSL

Certified by: ETA Certification Date: 8-27-08

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: LANL Power Plant

Source Location: TA-3-22

Type of Source: Boiler #1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): Top of Boiler #1 stack

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NW

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coning
 No Plume Present

Emission Color: N/A Plume Type: No Plume Present
 Continuous Fugitive Intermittent

Water Droplets Present?
 NO YES IF YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
2 ft above top of stack


Describe Background (i.e. blue sky, trees, etc.): Blue sky

Background Color: Blue Sky Conditions: Clear

Wind Speed: 2-4 mph Wind Direction: From ESE
 (provide from/to, i.e. from North to South)

Ambient Temperature: 58 °F Relative Humidity: 36 %

Additional Comments/Information:
Fuel oil burn exercises



Observation Date		Start Time				End Time
10-9-08		1020				1030
Min	Sec	0	15	30	45	Comments
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Average 10-Minute Opacity		Range of Opacity Readings				
<u>0%</u>		Min.	Max.			
		<u>0%</u>	<u>0%</u>			
OBSERVER (please print)						
Name: <u>Don Stone</u>			Title: <u>ENGINEER</u>			
Signature: <u>Don Stone</u>			Date: <u>10-9-08</u>			
Observer Organization: <u>KSL</u>						
Certified by: <u>ETA</u>			Certification Date: <u>8-27-08</u>			

LOS ALAMOS NATIONAL LABORATORY (LANL)
VISIBLE EMISSION OBSERVATION FORM (10 MINUTE)

Source Name: LANL Power Plant

Source Location: TA-3-22

Type of Source: Boiler #1 Type of Control Equipment: No Particulate Control

Describe Emission Point (Top of stack, etc.): Top of Boiler #1 stack

Height Above Ground Level: 150 Feet Height Relative to Observer: 140 Feet

Distance From Observer: 200 Feet Direction of Source From Observer: NE

Description of Plume (stack exit only)
 Lofting Trapping Looping Fanning Coasting
 No Plume Present

Emission Color: N/A Plume Type: No Plume Present
 Continuous Fugitive Intermitent

Water Droplets Present?
 NO YES If YES, droplet plume is Attached Detached

At what point in the plume was opacity determined?
1/2 ft. above top of stack

Describe Background (i.e. blue sky, trees, etc.): Blue sky


Background Color: Blue Sky Conditions: Clear

Wind Speed: 6-10 mph Wind Direction: From SE
 (provide from to, i.e. from North to South)

Ambient Temperature: 45 °F Relative Humidity: 43%

Additional Comments/Information:
Fuel Oil burn exercise

Observation Date	Start Time	End Time				
<u>11-20-08</u>	<u>10:30</u>	<u>10:40</u>				
	Sec					Comments
Min	0	15	30	45		
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						



Average 10-Minute Opacity: 0% Range of Opacity Readings: Min. 0% Max. 0%

OBSERVER (please print)
 Name: Don Stone Title: Engineer
 Signature: [Signature] Date: 11-20-08
 Observer Organization: KSL

Certified by: ETA Certification Date: 8-27-08

Part 2

Deviation Summary Report

1. Were any deviations reported to the Air Quality Bureau during this reporting period? If NO, answer question 2 below. If YES, complete the "Summary of Deviations Previously Reported" table below, then answer question 2.

Yes No

SUMMARY OF DEVIATIONS PREVIOUSLY REPORTED

Unit # and description

Date deviation reported

Tracking Number

2. Are there any deviations not yet reported? If No, no further information is required on the Deviation Summary Report. If Yes, answer question 3 below and enter the required information in the Deviation Summary Table.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3. Did any of the deviations result in excess emissions? For deviations resulting in excess emissions a completed Excess Emission Form for each deviation must be attached to this report.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Deviation Summary Table for deviations not yet reported.

No.	Applicable Requirement (Include Rule Citation)	Emission Unit ID(s)	Cause of Deviation	Corrective Action Taken
1	Operating permit P100M2 conditions 2.9.4.7 and 2.9.4.8. 20.2.72.210.B.4 NMAC	TA-3-22 CT-1	An emission spreadsheet, containing the calculations found in permit conditions 2.9.4.7 and 2.9.4.8, is used to calculate the NOx and CO pound per hour (pph) and ton per year (tpy) emission rates. This data is compared with the permit emission limits listed in permit condition 2.9.2. On October 22 and October 23, 2008, the static emission factors and calculations in these conditions resulted in a deviation. LANL has been working with the NMED-AQB permitting group to modify the permit to remove these conditions and replace them with conditions that represent actual emissions. It was agreed that the current emission factors and calculations in these conditions do not provide a reasonable estimate of emissions from the combustion turbine. Using an emission factor derived from data in the initial compliance test, conducted on October 5, 2007, emissions for the two days were determined to be much lower than the permit limits. For October 22nd, using the compliance test emission	The permit modification request submitted to NMED consists of replacing the calculation in these permit conditions with an annual emission test.

			factor resulted in 11.9 pph of NOx and 2.5 pph of CO, as compared to the calculation in this permit condition which resulted in 24.3 pph of NOx and 173 pph of CO. For October 23rd, the compliance test emission factor resulted in 12.5 pph of NOx and 2.6 pph of CO, as compared to the calculation in these permit conditions which resulted in 25.4 pph NOx and 180 pph CO. By using the compliance test data, which contains actual emission results, no excess emissions occurred.	
2				
3				

Deviation Summary Table (cont.)

	Deviation Started		Deviation Ended					Did you attach an excess emission form?
No.	Date	Time	Date	Time	Pollutant	Monitoring Method	Amount of Emissions	
1	10/22/2008	00:00	10/23/2008	23:59	NOx & CO	Emission Calculation	Oct. 22 11.9 pph NOx 2.5 pph CO ----- Oct. 23 12.5 pph NOx 2.6 pph CO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
2								<input type="checkbox"/> Yes <input type="checkbox"/> No
3								<input type="checkbox"/> Yes <input type="checkbox"/> No