

LA-UR-14-28940

Approved for public release; distribution is unlimited.

Title: Emissions Inventory Report Summary for Los Alamos National Laboratory
for Calendar year 2013

Author(s): Whetham, Walter Wiley

Intended for: Report
Environmental Programs

Issued: 2014-11-19 (rev.1)

Disclaimer:

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By approving this article, the publisher recognizes that the U.S. Government retains nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

LA-UR-14-28940

November 2014

Emissions Inventory Report Summary for Los Alamos National Laboratory for Calendar Year 2013



Prepared by the Environmental Protection Division

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the Los Alamos National Security, LLC, for the National Nuclear Security Administration of the U.S. Department of Energy under contract DE-AC52-06NA25396. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; as an institution, however, the Laboratory does not endorse the viewpoint of a publication or guarantee its technical correctness.

CONTENTS

ABSTRACT	1
1.0 INTRODUCTION	1
1.1 Regulatory Basis.....	1
1.2 Contents of Annual Emissions Inventory Submittal.....	3
1.3 Contents of the Semi-annual Title V Operating Permit Emissions Reports.....	3
2.0 REPORTED EMISSION SOURCES	3
2.1 Power Plant.....	4
2.2 Small Boilers and Heaters	5
2.3 Asphalt Plant.....	6
2.4 Data Disintegrator.....	6
2.5 Degreasers	6
2.6 Permitted Beryllium-Machining Operations	7
2.7 Generators.....	7
2.8 Combustion Turbine.....	8
2.9 Emissions from Chemical Use Activities	8
2.9.1 VOC Emissions.....	8
2.9.2 HAP Emissions	9
2.9.3 HAP Metals.....	10
2.10 Emissions Summary by Source	10
3.0 REPORTING EXEMPTIONS	12
3.1 Boilers.....	12
3.2 Generators.....	12
3.3 VOC Emissions	13
3.4 HAP Emissions.....	14
3.5 Paints	14
4.0 EMISSIONS SUMMARY	15
4.1 2013 Emissions Summary	15
REFERENCES	19
ATTACHMENT A: Emission Calculation Worksheets for Individual Emission Units	20
ATTACHMENT B: 2013 Annual Emissions Inventory Submittal to NMED	51
ATTACHMENT C: 2013 Semi-annual Emissions Reports Submitted Under Title V Operating Permit Requirements	95

Figures

Figure 2.1-1. TA-3 power plant.	5
Figure 2.9-1. Example of a laboratory fume hood at LANL.	8
Figure 4.1-1. Emissions of criteria pollutants by source in 2013.....	16
Figure 4.1-2. Comparison of facility-wide annual reported emissions from 2004 to 2013.	17
Figure 4.1-3. VOC and HAP emissions from chemical use from 2003 to 2013.....	18

Tables

Table 2.0-1. Sources Included in LANL’s 2013 Annual Emissions Inventory and Semi-annual Emissions Reports.....	4
Table 2.10-1. Summary of LANL 2013 Reported Emissions for Annual Emissions Inventory.....	11
Table 2.12-2. Summary of LANL 2013 Semi-annual Emissions as Reported Under Title V Operating Permit Requirements.....	11
Table 3.3-1. Exemptions Applied for Chemical Use Activities.....	14
Table 4.1-1. LANL Facility-Wide Criteria Pollutant Emissions for 2013.....	15
Table 4.1-2. LANL HAP Emissions from Top Five Chemicals Used in 2013.....	15

Acronyms

AIRS	Aerometric Information Retrieval System
AQB	Air Quality Bureau
CAS	Chemical Abstracts Service
CFR	Code of Federal Regulations
CMRR	Chemistry and Metallurgy Research Replacement (Facility)
CO	carbon monoxide
EPA	(United States) Environmental Protection Agency
FGR	flue gas recirculation
gal.	gallon
HAP	hazardous air pollutant
hr	hour
LANL	Los Alamos National Laboratory
lb	pound
mmHg	millimeter of mercury
MSDS	material safety data sheet
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NO _x	nitrogen oxides
oz.	ounce
PM	particulate matter
PM _{2.5}	particulate matter with diameter less than 2.5 micrometers
PM ₁₀	particulate matter with diameter less than 10 micrometers
PSD	Prevention of Significant Deterioration
R&D	research and development
RLUOB	Radiological Laboratory/Utility/Office Building
SO _x	sulfur oxides
SO ₂	sulfur dioxide
TA	Technical Area
TSP	total suspended particulates
µm	micrometer
VOC	volatile organic compound
yr	year

EMISSIONS INVENTORY REPORT SUMMARY FOR LOS ALAMOS NATIONAL LABORATORY FOR CALENDAR YEAR 2013

by
Environmental Stewardship Group

ABSTRACT

Los Alamos National Laboratory (LANL) is subject to annual emissions reporting requirements for regulated air pollutants under Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The applicability of the requirements is based on LANL's potential to emit 100 tons per year of suspended particulate matter, nitrogen oxides, carbon monoxide, sulfur oxides, or volatile organic compounds. Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the New Mexico Environment Department/Air Quality Bureau, under 20.2.70 NMAC and the permit was modified on June 15, 2013. This Title V Operating Permit (Permit No. P100-R1-M1) includes emission limits and operating limits for all regulated sources of air pollution at LANL. The Title V Operating Permit also requires semi-annual emissions reporting for all sources included in the permit. This report summarizes both the annual emissions inventory reporting and the semi-annual emissions reporting for LANL for calendar year 2013. LANL's 2013 emissions are well below the emission limits in the Title V Operating Permit.

1.0 INTRODUCTION

1.1 Regulatory Basis

Los Alamos National Laboratory (LANL or the Laboratory) has reported on air pollutants generated from its operations since the 1970s when Air Quality Control Regulation 703, Registration of Air Contaminant Sources, was promulgated. According to the regulation, the Laboratory was required to register air pollutant sources that emitted more than 2,000 lbs per year of any air contaminant. This regulatory requirement later evolved into Title 20 of the New Mexico Administrative Code, Chapter 2, Part 73 (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The objective of the reporting requirement is to provide emissions data to the New Mexico Environment Department (NMED)/Air Quality Bureau (AQB) so its staff can determine whether LANL meets state and federal air pollutant standards.

Annual emissions inventory reporting requirements under 20.2.73 NMAC apply to any stationary source that

- has been issued a construction permit under 20.2.72 NMAC;
- has been required to file a Notice of Intent under 20.2.73.200 NMAC; or

- emits in excess of
 - 1 ton per year of lead or
 - 10 tons per year of
 - total suspended particulates (TSP);
 - particulate matter (PM) with diameter less than 10 micrometers (PM₁₀);
 - PM with diameter less than 2.5 micrometers (PM_{2.5});
 - sulfur dioxide (SO₂);
 - nitrogen oxides (NO_x);
 - carbon monoxide (CO); or
 - volatile organic compounds (VOCs).

The annual emissions inventory must be submitted to NMED/AQB by April 1 of each year. The NMED/AQB enters the data into the Aerometric Information Retrieval System (AIRS) (EPA 2013). This nationwide system, administered by the United States Environmental Protection Agency (EPA), is used to help ensure ambient air quality standards are maintained and to track the state's air pollutant emissions. AIRS is a large air pollution database that contains information, requirements, and data on air pollution and air quality in the United States and various World Health Organization member countries. The program is operated by the EPA and state/local air pollution control agencies. The AIRS database tracks each state's progress towards achieving and maintaining National Ambient Air Quality Standards for criteria pollutants. The database is also used as a tool to help improve each state's air quality programs by enabling program members to access and compare past data and view data from other states.

Additionally, on April 30, 2004, LANL was issued a Title V Operating Permit from the NMED/AQB, under 20.2.70 NMAC. The NMED/AQB issued a modified permit (P100-R1-M1) on June 15, 2013 (NMED 2013). A condition of the Title V Operating Permit is that LANL must submit semi-annual emissions reports to NMED documenting that emissions from all permitted sources are below permitted emission levels. Section A109.B of the permit states:

“A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emissions estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table106.B.”

In 2004, the Laboratory began submitting the semi-annual emissions reports as well as the annual emissions inventory. There are a few differences in which sources are included in the two emissions reports. These differences are explained in the following sections.

1.2 Contents of Annual Emissions Inventory Submittal

NMED requested that LANL submit annual emissions inventory data for 2013 via electronic format for entry into AIRS. The information required for submittal includes the following:

- facility name, organization name, and agency ID;
- facility contact information;
- signed certification statement by a responsible facility official; and
- specific information for each emission unit such as fuel type, materials processed, materials consumed, fuel heating value, percent sulfur of fuel, percent ash of fuel, percent carbon content, and details of operating schedule.

This annual emissions inventory submittal includes air pollutant data for PM, PM₁₀, PM_{2.5}, CO, NO_x, sulfur oxides (SO_x), VOCs, beryllium, and hazardous air pollutants (HAPs).

1.3 Contents of the Semi-annual Title V Operating Permit Emissions Reports

The semi-annual Title V Operating Permit emissions reports include actual estimated emissions for the reporting period for each emission source or source category included in the Title V Operating Permit. For each source category, the actual emissions are compared with emission limits listed in the permit. The emissions are calculated using operating data from logbooks and records maintained on site. All emission calculations are consistent with calculation methods used for the annual emissions inventory.

The semi-annual emissions reports include a few source categories not included in the annual emissions inventory. The Laboratory requested emission limits in their Title V Operating Permit for two source categories that are considered insignificant sources for the annual emissions inventory. These source categories are 1) small boilers and heaters and 2) stationary standby generators. LANL requested emission limits for these source categories to obtain federally-enforceable limits that would keep the Laboratory under the major source threshold for Prevention of Significant Deterioration (PSD) applicability (20.2.74 NMAC). LANL's actual emissions from these insignificant sources have historically been very low; however, without federally-enforceable limits on their operation, the potential to emit from these sources was quite high. To demonstrate that LANL is below the PSD applicability and is in compliance with the emission limits placed on these emission sources, LANL now must include these emissions in the semi-annual Title V Operating Permit emissions reports.

2.0 REPORTED EMISSION SOURCES

Table 2.0-1 shows the emission sources included in the Laboratory's 2013 annual emissions inventory report (LANL 2013a) and the 2013 semi-annual emissions reports (LANL 2013b and 2014c). The source categories and the methodology used to calculate emissions are described in the following sections.

The following subsections describe emission sources included in the 2013 emissions inventory and semi-annual emissions reports and emission calculation methodology for each source type. A summary table of actual reported emissions by source is included in Section 2.12. Attachment A includes worksheets showing detailed emission calculations for individual emissions sources. A copy of the 2013 emissions inventory as submitted to NMED is presented in Attachment B. The 2013 semi-annual emissions reports are included as Attachment C.

Table 2.0-1. Sources Included in LANL's 2013 Annual Emissions Inventory and Semi-annual Emissions Reports

Included in Annual Emissions Inventory	Included in Semi-annual Emissions Reports	Comment
Power Plant (TA-3)	Power Plant (TA-3)	n/a ^a
Boilers greater than 5 MMBTU/hr ^b (14 units)	All small and large boilers and heaters (approximately 175 units)	Small boilers less than 5 MMBTU/hr are exempt from annual emissions inventory requirements (see Section 3.1).
Asphalt Plant	Asphalt Plant	n/a
Degreasers	Degreasers	n/a
Data Disintegrator	Data Disintegrator	n/a
Permitted Beryllium Sources	Permitted Beryllium Sources	n/a
Facility-wide Chemical Use	Facility-wide Chemical Use	The semi-annual emissions reports also include separate emission data for the CMRR-RLUOB building.
Process Generators	Process Generators and Stationary Standby Generators (approximately 45 units)	Stationary standby generators are exempt from annual emissions inventory requirements (see Section 3.2).
TA-3 Turbine	TA-3 Turbine	n/a

a: n/a = Not Applicable. b: one million British thermals units per hour.

2.1 Power Plant

The Laboratory operates a power plant at Technical Area (TA) 3. The power plant produces steam for heating and electricity for much of the Laboratory when sufficient power from outside sources is not available. The heat produced from the power plant is used for comfort heat and hot water and to support facility processes. The power plant has three boilers that are fueled primarily with natural gas with No. 2 fuel oil as a backup. The Laboratory operated a second power plant at TA-21 that was shut down in 2007.

For the 2013 emissions inventory, NMED requested that emissions from natural gas and No. 2 fuel oil be reported separately for the boilers located at each of the power plants. The TA-3 power plant was originally included in LANL's emissions inventory as a single unit. When a modification to the plant was made in 2001, the TA-3 power plant was separated into three separate units for emissions reporting purposes. Because each of the three boilers has the capability of burning either natural gas or No. 2 fuel oil, the TA-3 power plant is now reported as six units (ID 24, ID 25, and ID 26 for the natural gas and ID 137, ID 138, and ID 141 for the No. 2 fuel oil).

The 2013 emissions inventory reporting year used the updated emission factors for fuel oil for PM, PM₁₀, and PM_{2.5} as described for the TA-3 power plant boilers.

Actual estimated emissions are calculated on the basis of metered fuel consumption and emission factors. The primary source of emission factors is AP-42, the EPA's Compilation of Air Pollutant Emission Factors (EPA 1998). However, emission factors from stack tests conducted at the TA-3 power plant when burning natural gas were also used, as appropriate.

The TA-3 power plant has historically been the largest source of NO_x emissions at the Laboratory. In 2002, a voluntary project to install pollution control equipment on the three boilers at the TA-3 power plant was completed. The three boilers were fitted with flue gas recirculation (FGR) equipment to reduce NO_x emissions. Stack testing for NO_x and CO was conducted before FGR equipment was installed and again after it was operational. Based on these stack test results, FGR reduced NO_x emissions by approximately 64%. Figure 2.1-1 shows a picture of the TA-3 power plant building and stacks.



Figure 2.1-1. TA-3 power plant.

2.2 Small Boilers and Heaters

The Laboratory operates approximately 175 small boilers and heaters, used primarily for seasonal comfort heat. Most of the boilers are exempt from permitting requirements because of their small size and use as comfort boilers and are not included in the annual emissions inventory. The exemption analysis applied to boilers is discussed in Section 3.1 of this report.

The boilers that are not exempt and reported in the 2013 annual emissions inventory include the following:

- two boilers at TA-53 (ID 11 and ID 12);
- two boilers at TA-55 (ID 29 and ID 30);
- five boilers at the Chemistry and Metallurgy Research Replacement (CMRR) Facility (ID 90, ID 104, ID 105, ID 106, and ID 107); and
- two boilers at TA-16 (ID 53 and ID 134).

All of the reported boilers burn natural gas. Operating logs of actual fuel used for the TA-55 and the CMRR boilers were used to quantify emissions from these units. Fuel use for all other boilers was estimated based on the total amount of natural gas used by the Laboratory minus the amount supplied to metered sources. The amount of natural gas left after subtracting out metered sources was apportioned to the various boilers based on their size. Since virtually all of the small boilers are seasonal boilers used for building heating, it was assumed they would all operate approximately the same amount of time over the course of the year. Some emission factors were available from stack tests (TA-55), some were provided by the boiler manufacturer (Sellers Engineering Company), and the rest were taken from AP-42

(EPA 1998). Copies of spreadsheets showing fuel use and emission factors for each boiler are included in Attachment A.

For the semi-annual emissions reports, emissions from small boilers are included as a source category. These boilers include TA-16-1484-BS-1, TA-16-1484-BS-2, TA-53-365-BHW-1, TA-53-365-BHW-2, TA-55-6-BHW-1, TA-55-6-BHW-2, CMRR-BWH-1, CMRR-BWH-2, CMRR-BWH-3, and CMRR-BWH-4. Additionally, emissions from each of the CMRR boilers are included as separate source categories. To estimate emissions, all unmetered fuel use was multiplied by AP-42 emission factors for small boilers burning natural gas (EPA 1998). Total emissions of each pollutant from all boilers and heaters in this source category were then summed and reported on the semi-annual emissions reports.

2.3 Asphalt Plant

The TA-60 asphalt plant (ID 116) began operations in July 2005. This unit replaced the TA-3 asphalt plant, which was dismantled and removed in September 2003. Information on the amount of asphalt produced and the duration of daily operation at the TA-60 asphalt plant was provided as part of a monthly site support contractor data deliverable. The total asphalt produced in 2013 was 335 tons.

The emissions from the asphalt plant include criteria pollutants, NO_x and CO. None of the emissions were significant in regard to the overall Laboratory emissions. The largest pollutant emitted from the asphalt plant was CO at 0.53 tons per year.

2.4 Data Disintegrator

The data disintegrator is included in the 2013 emissions inventory as ID 89. Operation of this source started in August 2004. Emissions are calculated using the methodology described in the original permit application dated June 23, 2003. Emissions of PM, PM₁₀, and PM_{2.5} are calculated based on the number of boxes shredded, the amount of dust estimated to enter the exhaust (provided by the manufacturer), and the control efficiency of the cyclone and baghouse (also provided by the manufacturer). The permit application included PM_{2.5} emission estimates. Therefore, an emission methodology had to be developed for the emission inventory reporting. No specific PM size distribution data were available. However, the manufacturer reported that dust into the exhaust would be in the size range of 5 to 20 μm. Based on visual observation and engineering judgment, a particle size distribution in the exhaust was estimated as follows:

- PM_{2.5} 15%
- PM₁₀ 90%
- TSP 100%

The number of boxes of material shredded is provided in a monthly data deliverable from the site support contractor. The total number of boxes shredded at the data disintegrator in 2013 was 1,752.

2.5 Degreasers

The halogenated solvent cleaning machine at TA-55 has a capacity of 18 liters and is registered with NMED/AQB as required under the National Emissions Standards for Hazardous Air Pollutants, 40 Code of Federal Regulations (CFR) 63 Subpart T, Halogenated Solvent Cleaning. The solvent used in the machine, trichloroethylene (Chemical Abstracts Service [CAS] No. 79-01-6), is a VOC and a HAP. This

emission unit is included in the annual emissions inventory as ID 21. LANL uses a mass balance approach to estimate emissions. Logbooks are kept on the amount of solvent added and removed from the machine. Additionally, solvent levels in the machine are logged monthly. LANL has two additional halogenated solvent cleaning machines registered with NMED (ID 29 and ID 30). These units were not operational in 2013. The emissions from the TA-55 degreaser for this reporting period are 15.8 lbs or 0.008 tons per year. This source category is reported in both the annual emissions inventory and the semi-annual emissions reports.

2.6 Permitted Beryllium-Machining Operations

The Laboratory operates four permitted beryllium-machining operations that are subject to 40 CFR 61, Subpart C, and National Emission Standards for Beryllium. Emissions reported for the Beryllium Test Facility (ID 3) are from actual stack emissions measurements. Emissions for the Target Fabrication Facility (ID 2) are from initial compliance stack testing and are reported as permitted emission levels. In addition, emissions from the Plutonium Facility (ID 6) are reported at permitted emission levels. Foundry operations within the Plutonium Facility did not occur during this reporting period. Total emissions from all permitted beryllium operations are included in the semi-annual emissions reports.

2.7 Generators

LANL has four permitted generators (ID 56, ID 119, ID 120, and ID 135) with internal combustion engines located at TA-33 to support research activities. NMED issued a construction permit (Permit No. 2195-F) in October 2002 for installing the initial generator, and this unit is included in LANL's Title V Operating Permit. The unit first operated in May 2006. The unit (ID 56) operated for 19.8 hours in 2013. This generator was replaced in December 2013 by a Cummins Portable Diesel Generator (ID 146). The new generator did not operate in 2013. Three more units were permitted in August 2007 at TA-33 (Permit No. 2195-P); they operated for a total of 63.2 hours in 2013.

LANL also has three permitted generators with internal combustion engines located at the CMRR Radiological Laboratory/Utility/Office Building (RLUOB), TA-55-400, which began operating in 2013. The generators were added to the newest Title V Operating Permit and are included in the semi-annual emissions report as three separate units. However, they are listed in the emissions inventory report as one unit. The three generators operated for a total of 92.8 hours in 2013.

The Laboratory maintains approximately 37 stationary standby generators that are considered exempt sources under the Construction Permit regulations (20.2.72.202.b NMAC) and the annual emissions inventory requirements. These sources are included in LANL's Title V Operating Permit with operating limits and emission limits. Therefore, these sources must be included in the semi-annual emissions reports. All stationary standby generators at LANL are tested on a routine schedule to ensure they are operational and will function properly if needed. All units are equipped with hour meters to document how many hours they are used. The Laboratory maintains records on a semi-annual basis to document hour meter readings. The number of hours each generator is used in a reporting period is multiplied by AP-42 emission factors for diesel-fired internal combustion engines or natural-gas-fired internal combustion engines (EPA 1996). Emissions are then summed for each pollutant and reported on the semi-annual emissions reports for this source category.

2.8 Combustion Turbine

LANL has one combustion turbine located at the TA-3 power plant (ID 112). A revised construction permit was issued by NMED July 2004 to add the TA-3 combustion turbine as a new permitted source. This unit started operations in September 2007. Emission calculations are based on the initial stack compliance tests performed in 2007, AP-42 Tables 3.1-2a and 3.1-3, and information provided by the manufacturer. In 2013, this combustion turbine operated for 465.8 hours.

2.9 Emissions from Chemical Use Activities

A significant amount of the Laboratory's work is devoted to research and development (R&D) activities. Varying operating parameters, as well as amounts and types of chemicals, are used in these activities. R&D activities occur at virtually all technical areas within the Laboratory, typically in small quantities in laboratory settings. Figure 2.9-1 shows a typical laboratory at LANL where chemicals are used.

For the purposes of annual emissions inventory reporting, one equipment number has been assigned for all R&D chemical use (ID 7). Facility-wide chemical use emissions are reported on both the annual emissions inventory and the semi-annual emissions reports. The methods used to quantify emissions of VOC and HAPs from R&D activities are discussed below.



Figure 2.9-1. Example of a laboratory fume hood at LANL.

2.9.1 VOC Emissions

The Laboratory tracks chemical purchases through a facility-wide chemical tracking system called ChemLog. A download from the ChemLog inventory system was created that included all chemical containers added to LANL's inventory between January 1, 2013, and December 31, 2013. This dataset included 41,365 separate line items of chemicals purchased.

The dataset was reviewed electronically to identify all VOCs purchased and received at LANL in 2013. With the exception of specific listed chemicals, VOCs are any compounds of carbon that participate in

atmospheric photochemical reactions. VOCs include commonly used chemicals such as ethanol, methanol, trichloroethylene, and isopropanol. The general assumption used in estimating VOC emissions from chemical use is

$$\text{Purchasing} = \text{Use} = \text{Emissions}$$

From the dataset of chemicals purchased in 2013, certain categories of chemicals were separated and eliminated from the analysis. The classifications assigned and corresponding reasons (noted in parentheses) for exclusion of chemicals from inventory records are noted below.

- Solid materials (not a significant source of air emissions based on their low vapor pressure)
- Non-VOC materials as defined by 40 CFR 51.100 (specific chemicals in 40 CFR 51.100 are listed as having negligible photochemical reactivity and are exempt from the definition of VOC)
- Paints (paints were evaluated separately—see Section 3.5)
- Inorganic chemicals (inorganics are not compounds of carbon)
- Oils (not a significant source of air emissions based on low vapor pressure and primarily used for maintenance)
- Fuels used for combustion purposes (emissions from fuel combustion are reported for each combustion unit)

The following categories of chemicals were eliminated based on guidance from NMED (NMED 2001).

- Container sizes of 1 lb or less
- Chemicals with vapor pressures less than 10 mmHg
- Chemicals used to calibrate equipment
- Maintenance chemicals
- Use of office equipment and products
- Chemicals used for boiler water treatment operations
- Chemicals used for oxygen scavenging (deaeration) of water
- Chemicals used in bench-scale chemical analysis¹

After the elimination of chemicals and categories of chemicals listed above, the remaining chemical inventory records were matched with a list of known VOCs by CAS number. For mixtures (chemicals without CAS numbers), material safety data sheets (MSDSs) were reviewed to determine if any VOCs were present and, if so, to determine the associated percent volatile. As a conservative estimate, VOCs identified in ChemLog records were assumed to be 100% emitted to air. Estimated emissions of VOCs from chemical use in 2013 totaled 9.59 tons.

2.9.2 HAP Emissions

Section 112(b) of the 1990 Clean Air Act Amendments listed 188 unique HAPs identified for potential regulation by EPA. In 1995, caprolactam was delisted as a HAP, and methyl ethyl ketone was delisted in

¹ This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied (see Table 3.3-1).

2005. Of the remaining 187 listed HAPs, 17 are classes of compounds (e.g., nickel compounds). Use of the 187 listed chemicals in activities at the Laboratory was evaluated and quantified for the annual emissions inventory submittal to NMED.

The ChemLog inventory system 2013 dataset was analyzed to identify HAPs. The identification process was similar to that used for VOCs. Pure chemicals (i.e., chemicals with CAS numbers), classes of compounds, and mixtures were evaluated to determine if the chemicals themselves were HAPs or if they contained HAP constituents. For mixtures, MSDSs were reviewed to determine if any HAPs were present and, if so, to determine the associated HAP percentages. Listed below are certain chemical types or categories that were identified and removed from this analysis (refer to Section 2.9.1 and Table 3.3-1 for explanations on removal of these chemicals):

- Paints;
- Oils;
- Maintenance chemicals;
- Chemicals used to calibrate equipment;
- Container sizes of 1 lb or less;
- Chemicals used in bench-scale chemical analysis;
- Use of office equipment and products;
- Chemicals used for boiler water treatment operations; and
- Chemicals used for oxygen scavenging (deaeration) of water.

Total HAP emissions were estimated by summing 1) pure HAP chemicals, 2) classes of compounds that are HAPs, and 3) the HAP constituents from mixtures. The resulting total amount of HAPs from chemical use reported for 2013 was 3.49 tons.

The HAP emissions reported generally reflect quantities procured in the calendar year. In a few cases, procurement values and operational processes were further evaluated so that actual air emissions could be reported instead of procurement quantities. Additional analyses for certain metals and acids were performed and are described below.

2.9.3 HAP Metals

Purchases of beryllium, chromium, lead, manganese, mercury, and nickel compounds were evaluated to determine usage and potential air emissions. Several of the purchases were identified as laboratory calibration standards containing only parts per million quantities of the metals. These were exempt from emissions inventory requirements because of their use as standards for calibrating laboratory equipment. Other purchasers of relatively large quantities of metal compounds that were contacted confirmed that the material was still in use or in storage and had not resulted in air emissions.

2.10 Emissions Summary by Source

Table 2.10-1 provides a summary of LANL's 2013 actual emissions, as submitted for the annual emissions inventory. The table presents emissions by pollutant and by source, with a facility total at the

bottom of the table. Attachment A provides detailed information on how emissions were calculated for each emission unit.

Table 2.10-1. Summary of LANL 2013 Reported Emissions for Annual Emissions Inventory

	NO _x (tons/yr)	SO _x (tons/yr)	PM ₁₀ (tons/yr)	PM _{2.5} (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)
TA-3 Power Plant Boilers	12.40	0.15	1.63	1.62	8.55	1.18	0.40
Non-Exempt Boilers	2.98	0.02	0.32	0.32	1.74	0.18	0.056
CMRR Boilers	0.066	0.003	0.010	n/a*	0.082	0.056	0.004
Asphalt Plant	0.015	0.001	0.009	n/a	0.533	0.001	0.001
Data Disintegrator	n/a	n/a	0.07	n/a	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.008	0.008
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	9.59	3.49
TA-33 Generators	0.50	0.07	0.02	n/a	0.36	0.01	0.0005
TA-3 Turbine	2.40	0.16	0.32	0.32	0.50	0.10	0.07
TOTAL	18.36	0.40	2.38	2.26	11.77	11.13	4.03

* n/a = Not Applicable.

Table 2.12-2 provides a summary of 2013 emissions as reported on the semi-annual emissions reports required by the Title V Operating Permit. Attachment A provides detailed information on how emissions were calculated for each emission source category.

Table 2.12-2. Summary of LANL 2013 Semi-annual Emissions as Reported Under Title V Operating Permit Requirements

	NO _x (tons/yr)	SO _x (tons/yr)	PM ₁₀ (tons/yr)	PM _{2.5} (tons/yr)	CO (tons/yr)	VOC (tons/yr)	HAPs (tons/yr)
TA-3 Power Plant Boilers	12.40	0.15	1.63	1.62	8.55	1.18	0.40
Small Boilers	23.97	0.15	1.92	n/a*	19.40	1.39	0.46
CMRR Boilers	0.066	0.003	0.010	n/a	0.082	0.056	0.004
Asphalt Plant	0.015	0.001	0.009	n/a	0.533	0.001	0.001
Data Disintegrator	n/a	n/a	0.07	n/a	n/a	n/a	n/a
Degreaser	n/a	n/a	n/a	n/a	n/a	0.008	0.008
R&D Chemical Use	n/a	n/a	n/a	n/a	n/a	9.59	3.49
CMRR Generators	2.23	0.038	0.07	n/a	0.49	0.07	0.0004
Stationary Standby Generators	2.71	0.12	0.14	n/a	0.61	0.14	0.001
TA-33 Generators	0.50	0.07	0.02	n/a	0.36	0.01	0.0005
TA-3 Turbine	2.40	0.16	0.32	0.32	0.50	0.10	0.07
TOTAL	44.29	0.69	4.19	1.94	30.53	12.55	4.43

* n/a = Not Applicable.

3.0 REPORTING EXEMPTIONS

Specific activities that are determined to be insignificant under NMED's Operating Permit program (20.2.70 NMAC) are exempt from reporting under the emissions inventory requirements (20.2.73.300 NMAC). NMED has designated exempt sources, activities, or thresholds in the following lists:

- List of Insignificant Activities, March 25, 2005 (NMED 2005) and
- List of Trivial Activities, January 10, 1996 (NMED 1996).

Laboratory sources and activities that qualify as insignificant or trivial as specified in these lists are not included in the annual emissions inventory. The following subsections of this report provide information and examples of the Laboratory's exempt activities as well as analyses performed to determine exempt status.

3.1 Boilers

The Laboratory's boiler inventory was evaluated against the List of Insignificant Activities (NMED 2005). Specifically, boilers were exempted from emissions inventory reporting requirements if they met one of the following requirements:

- Fuel-burning equipment that uses gaseous fuel has a design rate less than or equal to 5 MMBTU/hr, and is used solely for heating buildings for personal comfort or for producing hot water for personal use, or
- Any emissions unit . . . that has the potential to emit no more than **1 ton/yr** of any regulated pollutant

Any boiler that was not used exclusively for comfort heating or hot water was evaluated for the one ton per year exemption. For purposes of determining exemptions, boiler design ratings were used to estimate potential to emit. Any boiler not qualifying for one of these two exemptions is included in the annual emissions inventory with its own unique equipment number.

For the semi-annual emissions reports, emissions from all boilers and heaters were summed and reported for the entire source category.

3.2 Generators

The Laboratory maintains an inventory of approximately 73 portable generators. Portable generators are used at the Laboratory for temporary operations requiring remote power or to provide emergency backup power during power outages at various sites. The portable generators are fueled by gasoline and/or diesel fuel.

In addition to portable generators, the Laboratory maintains and operates approximately 45 stationary standby generators. Stationary generators are used on standby (emergency) status to provide power to critical systems at the Laboratory during power outages. The stationary generators are fueled by natural gas, propane, gasoline, or diesel.

The insignificant activity exemptions applicable to the Laboratory's generators are the following:

- Portable engines and portable turbines that have a design capacity . . . less than or equal to
 - 200-horsepower engine if fueled by diesel or natural gas and
 - 500-horsepower engine if fueled by gasoline.
- Emergency generators which on a temporary basis replace equipment used in normal operation, and which either have an allowable emission rate or potential to emit for each pollutant that is equal to or less than the equipment replaced, or which do not operate for a period exceeding 500 hours per calendar year.

On the basis of size, portable generators used for temporary power at remote locations are exempt from emissions inventory reporting requirements. Further, LANL's small portable generators are considered trivial activities and are not included in the Title V Operating Permit or semi-annual emissions reports. All stationary generators are designated as standby equipment under the Operating Permit Program and are used solely to provide emergency backup power for less than 500 hours per year. Therefore, they are considered insignificant sources and are also exempt from annual emissions inventory reporting requirements. However, the stationary standby generators were voluntarily included as a source category in the Title V Operating Permit and are included in the semi-annual emissions reports.

3.3 VOC Emissions

A number of insignificant and trivial activities were applicable for exempting materials from the VOC chemical use total in the emissions inventory. The basis of the exemptions and corresponding insignificant or trivial activities are explained in Table 3.3-1.

Fuels such as propane, kerosene, and acetylene were analyzed separately and are not listed in Table 3.3-1. When fuels are burned in an open flame, almost all of the fuels are consumed and VOC emissions are minimal. Emissions from fuel combustion are accounted for using emission factors for each fuel-burning unit.

Table 3.3-1. Exemptions Applied for Chemical Use Activities

Basis of Exemption	Activity Type	Activity
Container sizes of 1 lb or less	Trivial	Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16-oz. capacity or less.
Chemicals with vapor pressures less than 10 mmHg	Insignificant	Any emissions unit, operation, or activity that handles or stores a liquid with vapor pressure less than 10 mmHg or in quantities less than 500 gal.
Calibration chemicals	Trivial	Routine calibration and maintenance of laboratory equipment or other analytical instruments, including gases used as part of those processes.
Maintenance chemicals and oils	Trivial	Activities that occur strictly for maintenance of grounds or buildings, including lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas. Activities for maintenance and repair of equipment, pollution-control equipment, or motor vehicles either inside or outside of a building.
Use of office equipment and products	Trivial	Use of office equipment and products, not including printers or businesses primarily involved in photographic reproduction.
Chemicals used for boiler water treatment	Trivial	Boiler water treatment operations, not including cooling towers.
Chemicals used for oxygen scavenging	Trivial	Oxygen scavenging (deaeration of water).
Chemicals used in bench-scale chemical analysis	Trivial	Bench-scale laboratory equipment used for physical or chemical analysis but not lab fume hoods or vents. Note: This exemption was applied only to biological research solutions. Otherwise, this exemption was not applied.

3.4 HAP Emissions

The HAP chemical use exemption analysis, similar to the VOC chemical use exemption analysis, resulted in application of several of the same exemptions from NMED/AQB List of Insignificant Activities (NMED 2005) and List of Trivial Activities (NMED 1996) (refer to Table 3.3-1).

3.5 Paints

An analysis of VOC and HAP emissions resulting from painting activities at the Laboratory was performed to determine if certain exemptions apply. Paint information for 2013 was gathered from the ChemLog chemical inventory system. These records were evaluated for applicability of exemptions for trivial and insignificant activities.

The following exemptions from NMED/AQB Operating Permit Program List of Trivial Activities (NMED 1996) were used in the paint analysis:

- Activities that occur strictly for maintenance of grounds or buildings, including the following: lawn care; pest control; grinding; cutting; welding; painting; woodworking; sweeping; general repairs; janitorial activities; plumbing; re-tarring roofs; installing insulation; steam-cleaning and water-washing activities; and paving of roads, parking lots, and other areas.

- Activities for maintenance and repair of equipment, pollution control equipment, or motor vehicles either inside or outside of a building.
- Paint or nonpaint materials dispensed from prepackaged aerosol cans of 16 oz. or less capacity. The amount of paint that did not qualify for a Trivial Activity totaled to 3,960 lbs (1.98 tons) which is less than the two-ton emission limit for insignificant activities.
- Surface coating of equipment, including spray painting and roll coating, for sources with facility-wide total cleanup solvent and coating actual emissions of less than two tons per year.

4.0 EMISSIONS SUMMARY

4.1 2013 Emissions Summary

Table 4.1-1 presents facility-wide estimated actual emissions of criteria pollutants for 2013 as reported in the annual emissions inventory and the semi-annual emissions reports. In addition, the Title V Operating Permit emissions limits are included. Table 4.1-2 presents estimated actual emissions for HAPs from chemical use. Emission unit information and detailed emissions calculations are included in Attachment A. The 2013 emissions inventory report as submitted to NMED is presented in Attachment B. Attachment C includes semi-annual emissions reports for 2013.

Table 4.1-1. LANL Facility-Wide Criteria Pollutant Emissions for 2013

Pollutant	Estimated actual Emissions for Annual Emissions Reporting (tons/yr)	Estimated actual Emissions for Semi-annual Title V Operating Permit Reporting (tons/yr)	Title V Operating Permit Facility-Wide Emission Limits (tons/yr)
NO _x	18.36	44.3	245
SO _x	0.40	0.69	150
CO	11.77	30.53	225
PM	2.38	4.19	120
PM ₁₀	2.38	4.19	120
PM _{2.5}	2.26	1.94	120
VOC	11.13	12.55	200

Table 4.1-2. LANL HAP Emissions from Top Five Chemicals Used in 2013

Pollutant	Chemical Use HAP Emissions (tons/yr)
Hydrochloric Acid	0.83
Methanol	0.42
Glycol Ethers	0.38
Methylene Chloride	0.34
Ethylene Glycol	0.32
All other HAPs from Chemical Use	1.20
Total HAPs	3.49

HAP emissions from combustion sources are included in the emissions reports; however, they are negligible and do not contribute significantly to facility-wide HAP emissions.

Figure 4.1-1 shows criteria air pollutant emissions by source for 2013, excluding the very small emissions sources such as the data disintegrator, asphalt plant, degreasers, and carpenter shop. As the figure shows, the TA-3 power plant and the sum of emissions from small boilers and were the largest sources of CO and NO_x emissions in 2013. R&D chemical use was the largest source of VOC emissions.




Figure 4.1-1. Emissions of criteria pollutants by source in 2013.

Emission Trends and Title V Permit Limits

A comparison of historical emissions to the facility-wide emission limits in the Title V Operating Permit is provided in this section. It should be noted that the facility-wide emission limits in the Operating Permit include emissions from some sources that are not included in the annual emissions inventory, most notably small (insignificant) boilers and emergency standby generators. However, historical data are only available for emission sources that were included in the annual emissions inventory submittals.

Figure 4.1-2 provides a comparison of the past 10 years' facility-wide emissions for criteria air pollutants as reported to NMED in the annual emissions inventory submittal. The facility-wide emission limits included in LANL's Title V Operating Permit are also shown on the graph.




Figure 4.1-2. Comparison of facility-wide annual reported emissions from 2004 to 2013.

Figure 4.1-3 presents VOC and HAP emissions from chemical use activities for the last 11 years. The continued fluctuation in both VOC and HAP emissions is due to both variations in actual chemical purchases and improvements the Laboratory has made to the chemical tracking system.




Figure 4.1-3. VOC and HAP emissions from chemical use from 2003 to 2013.

REFERENCES

- EPA (U.S. Environmental Protection Agency), 2013. "Aerometric Information Retrieval System (AIRS)," <http://www.epa.gov/enviro/html/airs/> (accessed January 2013).
- EPA (U.S. Environmental Protection Agency), 1998. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 1.4–Natural Gas Combustion, July 1998, and Section 1.3–Fuel Oil Combustion, <http://www.epa.gov/ttn/chief/ap42/> (September 1998).
- EPA (U.S. Environmental Protection Agency), 1996. "Compilation of Air Pollutant Emission Factors," AP-42, Fifth Edition, Section 3.3–Gasoline and Diesel Industrial Engines, and Section 3.4–Large Stationary Diesel and All Stationary Dual-Fuel Engines, <http://www.epa.gov/ttn/chief/ap42/> (October 1996).
- LANL (Los Alamos National Laboratory), 2014. "Semi-Annual Emissions Report, July–December 2013," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-14-21663 (March 2014).
- LANL (Los Alamos National Laboratory), 2013a. "2013 Emissions Inventory Report Submittal to the New Mexico Environment Department," Los Alamos National Laboratory document LA-UR-13-22031 (March 2013).
- LANL (Los Alamos National Laboratory), 2013b. "Semi-Annual Emissions Report, January–June 2013," submitted to the New Mexico Environment Department, Los Alamos National Laboratory document LA-UR-13-26818 (September 2013).
- NMED (New Mexico Environment Department, Air Quality Bureau), 2013. "Clean Air Act, Title V Operating Permit No. P100-R1-M1," (June 2013).
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 2005. "List of Insignificant Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/InsignificantListTitleV.pdf> (March 2005).
- NMED (New Mexico Environment Department, Air Quality Bureau), 2001. Letter from Mary Uhl, NMED/AQB to LANL, dated January 30, 2001.
- NMED (New Mexico Environment Department, Air Quality Bureau, Operating Permit Program), 1996. "List of Trivial Activities under Title V Operating Permits," <http://www.nmenv.state.nm.us/aqb/forms/TrivialListTitleV.pdf> (January 1996).

ATTACHMENT A:

Emission Calculation Worksheets for Individual Emission Units

2013 TA-60 BDM Asphalt Plant

Data Reviewed By / Date:

Month	Data Entry Asphalt Produced (Tons)
January	4
February	24
March	0
April	127
May	44
June	19
6 mo. Total	218

Month	Data Entry Asphalt Produced (Tons)
July	44
August	0
September	0
October	73
November	0
December	0
6 mo. Total:	117

Month	12-Month Rolling Total	12-Month Rolling Total
July	786	292
August	757	269
September	630	269
October	641	342
November	439	342
December	307	335

Month	Hours	Month	Hours
Jan	0.8	Jul	4.1
Feb	8.8	Aug	0
Mar	0.0	Sep	0
Apr	16.5	Oct	11.6
May	9.5	Nov	0.0
Jun	3.3	Dec	0.0
Total:	38.9	Total:	15.7

2013 Asphalt Produced (Tons): **335**

12-Month Rolling Permit Limit is 13,000 Tons

Annual Total (to date): 54.58 Hours

Hours are Limited to 4380 per Year.

Emission Calculations

Pollutant	Emission Factor (lbs/hr)	Annual Emissions (tons)	Emissions (tons) Jan-June	Emissions (tons) July-Dec	Reference
NOx	0.56	0.015	0.011	0.004	(b)
CO	19.53	0.533	0.380	0.153	(b)
PM	0.33	0.009	0.006	0.003	(b)
Pollutant	Emission Factor (lb/ton)	Annual Emissions (tons)	Emissions (tons) Jan-June	Emissions (tons) July-Dec	Reference
PM-10	0.006	0.001	0.001	0.000	(c)
PM-2.5	0.006	0.001	0.001	0.000	(c)
SOx	0.0046	0.001	0.001	0.000	(a)
VOC	0.0082	0.001	0.001	0.000	(a)
HAPs					
Acetaldehyde	0.00032	0.000	0.000	0.000	(d)
Benzene	0.00028	0.000	0.000	0.000	(d)
EthylBenzene	0.0022	0.000	0.000	0.000	(d)
Formaldehyde	0.00074	0.000	0.000	0.000	(d)
Napthalene	0.000036	0.000	0.000	0.000	(d)
POM	0.00011	0.000	0.000	0.000	(d)
Quinone	0.00027	0.000	0.000	0.000	(d)
Toluene	0.001	0.000	0.000	0.000	(d)
Xylene	0.0027	0.000	0.000	0.000	(d)
TOTAL HAPS		0.001	0.001	0.000	
EPCRA 313		tons	lbs./year		

Reference
(a) AP-42, Sec. 11.1, Hot Mix Asphalt Plants, Table 11.1-5 & 11.1-6, Updated 4/2004
(b) Calculated using stack test results performed on May 18, 2009 by TRC Air Measurements. Pound per hour values were determined at a throughput rate of 45 tons/hour (the highest achievable rate during the test).
(c) PM-10 emission factor is calculated as 64% of the PM emission factor (from stack test), using the same ratio of PM to PM-10 as provided in AP-42 Table 11.1-1. No data provided for PM-2.5, assume same as PM-10. Convert to lb/ton by dividing by 45 tons/hr (test rate).
(d) AP-42, Table 11.1-9, Hot Mix Asphalt Plants, Updated 4/2004
(e) AP-42, Table 11.1-11, Hot Mix Asphalt Plants, Updated 4/2004
(f) Assume all SOx is converted to sulfuric acid
(g) EPCRA PAC Guidance Document, EPA-260-B-01-03, June 2001, Table 2-3
(h) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-1, "Default CO2 Emission Factors and High Heat Values for Various Types of Fuel." (Federal Register/Vol. 74, No. 209, 10/30/2009).

Lead	8.90E-07	1.49E-07	0.0003	(e)
Sulfuric Acid	0.0046	7.71E-04	1.54	(f)
Mercury	4.10E-07	6.87E-08	0.0001	(e)
PACs	2.70E-08	4.52E-09	9.05E-06	(d)
Benzo(g,h,i) perylene	5.00E-10	8.38E-11	1.68E-07	(g)

Greenhouse Gases Emissions	Emission Factors (kg / mmbtu) ^{(h),(i)}	Calendar Year (metric tons)	Fiscal Year (metric tons)	(l)
Carbon Dioxide (CO ₂)	61.46	76.35	73.39	(h)
Methane (CH ₄)	0.003	0.0037	0.0036	(i)
Nitrous Oxide (N ₂ O)	0.0006	0.0007	0.0007	(j)
TOTAL CO₂ EQUIVALENT^(k):		76.66	73.69	(k)

- (i) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-2, "Default CH₄ and N₂O Emission Factors for Various Types of Fuel." (Federal Register/Vol. 74, No. 209, 10/30/2009).
- (j) Heat content was taken from National Propane Gas Association web page (<http://npga.org/4a/pages/index.cfm?pageid=633>). The EPA value of 0.091 mmbtu/gallon, listed in 40 CFR Part 98, Subpart C, Table C-1, "Default CO₂ Emission Factors and High Heat Values for Various Types of Fuel" is consistent with this value. The NPGA value is used as it includes more accuracy.
- (k) CO₂ equivalent values were calculated using 40 CFR Part 98, Subpart A, Table A-1, "Global Warming Potentials." (Federal Register/Vol. 74, No. 209, 10/30/2009).
- (l) Fiscal year begins on October 1st and ends on September 30th of the following year.

Month	Data Entry	Data Entry
January	Boxes ^(c) Shredded	Boxes ^(c) Shredded
February	88	119
March	117	228
April	117	153
May	125	118
June	201	170
July	171	145
6 mo. Total:	819	933

Annual Boxes:	1,752
---------------	-------

Emission Calculations

	Percent Material in Exhaust ^(b)	% in Exhaust ^(e)	Control ^(d) Efficiency (Cyclone)	Control ^(d) Efficiency (Baghouse)
PM 2.5	15%	15%	0%	95.0%
PM 10	15%	90%	75%	95.0%
TSP	15%	100%	75%	95.0%

Average Box Weight^(a)
45 Pounds

	Amount Processed (pounds)	PM-2.5 Emissions (pounds)	PM-10 Emissions (pounds)	PM-10 Emissions (tons)	TSP Emissions (pounds)	TSP Emissions (tons)
Annual	78,840	88.7	133.0	0.07	147.8	0.07
January - June	36,855	41.5	62.2	0.03	69.1	0.03
July - December	41,985	47.2	70.8	0.04	78.7	0.04
July - Dec 2012		0.02	0.04	0.04	0.04	0.04
Semi-Annual Rolling Total ^(f)		0.04		0.07		0.07

Reference

<p>(a). Estimated maximum box weight is 45 pounds. Information provided by shredding operations. Full box weight of tightly packed paper.</p>	<p>(b). Emission Factor (percentage of material shredded that will enter into the exhaust) obtained from the manufacturer of the air handling system, AGET Manufacturing Co. 15% is also listed in the construction permit application.</p>	<p>(c). Information provided by the shredding operations personnel.</p>	<p>(d). Information on control equipment efficiencies was provided by the manufacturer (SEM) of the Data Disintegrator. Those values not given were extrapolated using manufacturer data. Efficiencies of 75% for the Cyclone and 95% for the bag house are listed in the construction permit application. (see cyclone efficiency tab for more info.)</p>	<p>(e). Manufacturer provided info that the dust into the exhaust would be in the size range of 5-20 um. Conservative assumption that 15% is PM2.5, and 90% is PM10.</p>	<p>(f). Emissions calculated by summing the emissions from January-June of current year plus July-December of previous year.</p>
---	---	---	--	--	--

Maximum Annual emission rate is: 9.9 tpy or 2.3 lb/hr of Total Suspended Particulate (TSP) per year.
9.9 tpy or 2.3 lb/hr of Particulate Matter <10um (PM-10) per year.

2013 Permitted Generators

Permitted Generators

TA Bldg	ID #	Make	Serial #	MODEL	KW	Fuel Type	Reading		First Half			Second Half			* Total Run Hours
							2nd half of previous year	6 Month Reading Date	Hours Run	Reading	12 Month Reading Date	Hours Run	Reading		
33 290	G-0012	Kohler	375801	1600ROZD	1600	Diesel	Dec. 12	335.2	0.0	May-13	335.2	0.0	Dec. 13	355.0	19.8
33 151	G-0007	Caterpillar	6PK01065	XQ225	225	Diesel	Dec. 12	3423.0	11.0	May-13	3434.0	11.0	Dec. 13	3434.0	11.0
33 209	G-0008	Kohler	2025460	20EORZ	20	Diesel	Dec. 12	403.1	0.0	May-13	403.1	0.0	Dec. 13	427.6	24.5
33 280	G-0010	Kohler	2025461	20EORZ	20	Diesel	Dec. 12	185.9	0.2	May-13	186.1	0.2	Dec. 13	213.6	27.7
55 440	G-0058	Cummins	106970810	DFLE-5754172	1500	Diesel	Dec-12	119.8	9.9	May-13	129.7	9.9	Dec. 13	143.6	23.8
55 440	G-0059	Cummins	106970811	DFLE-5754172	1500	Diesel	Dec-12	78.4	5.6	May-13	84.0	5.6	Dec. 13	103.3	24.9
55 440	G-0060	Cummins	106970812	DFLE-5754172	1500	Diesel	Dec-12	64.4	27.0	May-13	91.4	27.0	Dec. 13	108.5	44.1

* The TA-33 225 kW and the two 20 kW generators have a limit of 500 hours of operation per year. The 1600 kW unit is limited to 900 hours per year.

Permit ID	ID #	Unit	First 6 Month Emissions						Second 6 Month Emissions					
			NOx (lbs)	CO (lbs)	SOx (lbs)	PM (lbs)	VOC (lbs)	HAPs (lbs)	NOx (lbs)	CO (lbs)	SOx (lbs)	PM (lbs)	VOC (lbs)	HAPs (lbs)
TA-33-G-1	G-0012	33-290	0.0	0.0	0.0	0.0	0.0	0.0E+00	855.4	697.0	126.7	28.5	15.8	1.8E-01
TA-33-G-4	G-0007	33-151	104.0	22.3	7.4	7.4	7.4	3.3E-02	0.0	0.0	0.0	0.0	0.0	0.0E+00
TA-33-G-2	G-0008	33-209	0.0	0.0	0.0	0.0	0.0	0.0E+00	20.6	4.4	1.5	1.5	1.5	6.6E-03
TA-33-G-3	G-0010	33-280	0.2	0.0	0.0	0.0	0.0	5.4E-05	23.1	5.0	1.7	1.7	1.7	7.4E-03
CMRR-GEN-1		55-440	475.2	104.0	8.0	14.9	14.9	8.6E-02	667.2	146.0	11.3	20.9	20.9	1.2E-01
CMRR-GEN-2		55-440	268.8	58.8	4.5	8.4	8.4	4.9E-02	926.4	202.7	15.6	29.0	29.0	1.7E-01
CMRR-GEN-3		55-440	1296.0	283.5	21.9	40.5	40.5	2.4E-01	820.8	179.6	13.9	25.7	25.7	1.5E-01
Permit ID	ID #	Unit	NOx (tons)	CO (tons)	SOx (tons)	PM (tons)	VOC (tons)	HAPs (tons)	NOx (tons)	CO (tons)	SOx (tons)	PM (tons)	VOC (tons)	HAPs (tons)
TA-33-G-1	G-0012	33-290	0.000	0.000	0.000	0.000	0.000	0.00E+00	0.428	0.348	0.063	0.014	0.008	9.22E-05
TA-33-G-4	G-0007	33-151	0.052	0.011	0.004	0.004	0.004	1.67E-05	0.000	0.000	0.000	0.000	0.000	0.00E+00
TA-33-G-2	G-0008	33-209	0.000	0.000	0.000	0.000	0.000	0.00E+00	0.010	0.002	0.001	0.001	0.001	3.31E-06
TA-33-G-3	G-0010	33-280	0.000	0.000	0.000	0.000	0.000	2.70E-08	0.012	0.002	0.001	0.001	0.001	3.72E-06
CMRR-GEN-1		55-440	0.238	0.052	0.004	0.007	0.007	4.32E-05	0.334	0.073	0.006	0.010	0.010	6.07E-05
CMRR-GEN-2		55-440	0.134	0.029	0.002	0.004	0.004	2.44E-05	0.463	0.101	0.008	0.014	0.014	8.42E-05
CMRR-GEN-3		55-440	0.648	0.142	0.011	0.020	0.020	1.18E-04	0.410	0.090	0.007	0.013	0.013	7.46E-05
Permit ID	NOx	CO	SOx	PM	VOC	HAPs	Permit ID	NOx	CO	SOx	PM	VOC	HAPs	
TA-33-G-1	0.428	0.348	0.063	0.014	0.008	9.2E-05	CMRR-GEN-1	0.571	0.125	0.010	0.018	0.018	1.0E-04	
TA-33-G-4	0.052	0.011	0.004	0.004	0.004	1.7E-05	CMRR-GEN-2	0.598	0.131	0.010	0.019	0.019	1.1E-04	
TA-33-G-2	0.010	0.002	0.001	0.001	0.001	3.3E-06	CMRR-GEN-3	1.058	0.232	0.018	0.033	0.033	1.9E-04	
TA-33-G-3	0.012	0.002	0.001	0.001	0.001	3.7E-06	Total 3 CMRR Gen	2.227	0.487	0.038	0.070	0.070	0.000	
TPY	0.50	0.36	0.07	0.02	0.01	5.21E-04								

Reviewed by / Date:

2013 Permitted Generators

EMISSION FACTORS	NOx lb/kw-hr	CO lb/kw-hr	SOx lb/kw-hr	PM lb/kw-hr	PM ₁₀ lb/kw-hr	VOC lb/kw-hr
TA-33 1600kW ^(a)	0.027	0.022	0.004	0.0009	0.0009	0.0005
Small Diesel fired ^(b)	0.042	0.009	0.003	0.003	0.003	0.003
TA-55 (RLUOB) ^(c)	0.032	0.007	5.4E-04	0.001	0.001	0.001

References:

447 kw is the size limit for determining large vs. small diesel fired generator. This information was taken from the operating permit application.

(a) TA-33-290 1600kw generator uses manufacturer supplied emission factors for NOx, CO, and VOCs. Emission factors for SOx, PM, and PM10 from AP-42, Table 3.3-1 & Table 3.4-1. The AP-42 (fifth edition) emissions factor uses units of lb/hp-hr. There are 1.341 hp-hrs in a kwh. Therefore, take pounds/hp-hr x 1.341 hp-hr/kwh to obtain the emission factor in lb/kwh.

(b) Emission factors for small diesel fired boilers were taken from AP-42 (fifth edition) Tables 3.3-1 and 3.3-2.

(c) TA-55 (RLUOB) generator emission factors were taken from AP-42 (fifth edition) Tables 3.4-1, 3.4-2, 3.4-3, and 3.4-4.

TA-33-G-1 - 2013
(1600 kW Generator, 1500 kW Derated for Altitude)
12-Month Rolling kilowatt-hours

Month	Hour Meter Reading	Hours Operated	Rolling Total kw-hr	Month	Hour Meter Reading	Hours Operated	Rolling Total kw-hr
January	335.2	0.0	9,750	July	335.2	0.0	9,750
February	335.2	0.0	9,750	August	335.2	0.0	9,750
March	335.2	0.0	9,750	September	335.2	0.0	7,800
April	335.2	0.0	9,750	October	335.2	0.0	0
May	335.2	0.0	9,750	November	355.0	19.8	29,700
June	335.2	0.0	9,750	December	355.0	0.0	29,700

Generator is limited to 1,350,000 kWh/year

2013 Permitted Generators

HAPS (lbs)									
Emission Factors (lb/kwh)	Benzene		Toluene		Xylenes		1,3-Butadiene		Formaldehyde
Diesel (small)	3.19E-06	2nd Half	1.40E-06	9.73E-07	1.34E-07	4.03E-06			
Diesel (large)	2.65E-06	1st Half	9.60E-07	6.59E-07	2.69E-07				
Location	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	
33-290	0.00E+00	8.40E-02	0.00E+00	3.04E-02	0.00E+00	2.09E-02	0.00E+00	0.00E+00	8.54E-03
33-151	7.89E-03	0.00E+00	3.46E-03	0.00E+00	2.41E-03	0.00E+00	3.31E-04	0.00E+00	0.00E+00
33-209	0.00E+00	1.56E-03	0.00E+00	6.84E-04	0.00E+00	4.77E-04	0.00E+00	6.54E-05	1.97E-03
33-280	1.27E-05	1.75E-03	5.59E-06	7.68E-04	3.89E-06	5.35E-04	5.34E-07	7.34E-05	2.22E-03
55-440	3.94E-02	5.53E-02	1.43E-02	2.00E-02	9.79E-03	1.37E-02	0.00E+00	4.00E-03	5.62E-03
55-440	2.23E-02	7.67E-02	8.06E-03	2.78E-02	5.54E-03	1.91E-02	0.00E+00	2.26E-03	7.80E-03
55-440	1.07E-01	6.80E-02	3.89E-02	2.46E-02	2.67E-02	1.69E-02	0.00E+00	1.09E-02	6.91E-03
(lbs)	1.77E-01	2.87E-01	6.46E-02	1.04E-01	4.44E-02	7.16E-02	3.31E-04	1.39E-04	2.72E-02
Tons/Half/HAP	8.84E-05	1.44E-04	3.23E-05	5.21E-05	2.22E-05	3.58E-05	1.66E-07	6.94E-08	1.36E-05
Tons/year/HAP	2.32E-04	8.45E-05	5.80E-05	2.35E-07	3.01E-05				
Tons/Year Total	5.21E-04								

Emission Factors from AP-42, Volume 1, Fifth Edition (Small Diesel Engines Table 3.3-2, Large Diesel Engines Table 3.4-4, Natural Gas 4-Stroke Engines Table 3.2-3)

Greenhouse Gas Emission Calculations

Permit ID	Unit Location	Fuel Use		Calendar Year			Fiscal Year (e)		
		Fuel Rate (GPH)	Annual Fuel Use (Gal.)	CO2 (metric tons)	CH4 (metric tons)	N2O (metric tons)	CO2 (metric tons)	CH4 (metric tons)	N2O (metric tons)
TA-33-G-1	TA-33-290	148	2930.4	29.91	1.21E-03	2.43E-04	19.86	8.06E-04	1.61E-04
TA-33-G-4	TA-33-151	15.8	173.8	1.77	7.20E-05	1.44E-05	1.77	7.20E-05	1.44E-05
TA-33-G-2	TA-33-209	1.7	41.65	0.43	1.72E-05	3.45E-06	0.22	8.73E-06	1.75E-06
TA-33-G-3	TA-33-114	1.7	47.09	0.48	1.95E-05	3.90E-06	0.24	9.89E-06	1.98E-06
CMRR-Gen-1	TA-55-440	103.6	2465.68	25.17	1.02E-03	2.04E-04	0.24	9.89E-06	1.98E-06
CMRR-Gen-2	TA-55-440	103.6	2579.64	26.33	1.07E-03	2.14E-04	0.24	9.89E-06	1.98E-06
CMRR-Gen-3	TA-55-440	103.6	4568.76	46.63	1.89E-03	3.78E-04	0.24	9.89E-06	1.98E-06
Totals:				130.71	5.30E-03	1.06E-03	22.83	0.001	0.000
Total CO2 Equivalent:				131.16					
Annual Fuel Use:				12807.02					

2013 Permitted Generators

HAPS (lbs)										Individual Generator HAP Emissions (lbs)	
Acetaldehyde	Acrolein			Naphthalene			PAH			1st Half	2nd Half
	2.62E-06	3.16E-07	2.90E-07	2.90E-07	4.44E-07	5.74E-07	7.24E-07	1st Half	2nd Half		
8.61E-08	2.69E-08	4.44E-07	7.24E-07	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	0.00E+00	1.84E-01
0.00E+00	2.73E-03	0.00E+00	8.53E-04	0.00E+00	1.41E-02	0.00E+00	2.29E-02	0.00E+00	2.29E-02	3.35E-02	0.00E+00
6.48E-03	0.00E+00	7.82E-04	0.00E+00	7.17E-04	0.00E+00	1.42E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.62E-03
0.00E+00	1.28E-03	0.00E+00	1.55E-04	0.00E+00	1.42E-04	0.00E+00	2.81E-04	0.00E+00	2.81E-04	5.41E-05	7.44E-03
1.05E-05	1.44E-03	1.26E-06	1.74E-04	1.16E-06	1.59E-04	2.30E-06	3.16E-04	1.08E-02	1.51E-02	8.64E-02	1.21E-01
1.28E-03	1.79E-03	4.00E-04	5.61E-04	6.59E-03	9.26E-03	3.79E-03	1.29E-02	6.08E-03	2.10E-02	4.89E-02	1.68E-01
7.23E-04	2.49E-03	2.26E-04	7.79E-04	3.79E-03	1.29E-02	6.08E-03	2.10E-02	2.93E-02	1.86E-02	2.36E-01	1.49E-01
3.49E-03	2.21E-03	1.09E-03	6.90E-04	1.80E-02	1.14E-02	2.90E-02	4.76E-02	4.76E-02	7.82E-02	4.05E-01	6.38E-01
1.20E-02	1.19E-02	2.50E-03	3.21E-03	2.90E-02	4.79E-02	4.76E-02	7.82E-02	2.38E-05	3.91E-05		
5.99E-06	5.97E-06	1.25E-06	1.61E-06	1.45E-05	2.39E-05	2.38E-05	3.91E-05				
1.20E-05		2.86E-06		3.84E-05		6.29E-05					

References:

(a) Emission Factor/High Heat Value is from 40 CFR Part 98, Subpart C, Table C-1, "Default CO₂ Emission Factors and High Heat Values for Various Types of Fuel." (Federal Register/Vol. 74, No. 209, 10/30/2009)

(b) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-2, "Default CH₄ and N₂O Emission Factors for Various Types of Fuel." (Federal Register/Vol. 74, No. 209, 10/30/2009).

(c) Hour readings for each of the generators listed are collected twice a year by ENV-ES.

(d) Fuel use rates were taken from manufacturer literature. Data for some units may not be available due to age, but data for a similar unit was used when unit specific data was not available.

(e) Fiscal year begins on October 1st of the following year and ends on September 30th of the current year.

Emission Factors

Fuel Oil Heat Value ^(a) (mmBtu/Gal)	CO ₂ ^(a) (kg/mmBtu)	CH ₄ ^(b) (kg/mmBtu)	N ₂ O ^(b) (kg/mmBtu)
0.138	73.96	0.003	0.0006

TA	Bldg	ID #	Manufacturer	MODEL	KW	Fuel Type	Previous Reading Date	Previous Reading	First 6 Month Readings			Second 6 Month Readings			Annual Total Hours Run		
									6 Month Reading Date	6 Month Reading	Hours Run	12 Month Reading Date	12 Month Reading	Hours Run			
3	40	G-0013	Onan Sons	1500DVE16531374B	150	Diesel	Dec-12	50.0	Jun-13	55.0	5.0	Dec-13	60.0	5.0	10.0		
3	440	G-0020	Cummins	DFGA-5002210	500	Diesel	Dec-12	203.0	Jul-13	210.0	7.0	Dec-13	215.1	5.1	12.1		
3	1076	G-0022	Cummins	DC9B-8601289	35	Diesel	Dec-12	235.8	Jun-13	238.0	2.2	Dec-13	268.0	50.0	52.2		
3	1400	G-0024	Cummins	DFEH-8698616	400	Diesel	Dec-12	191.0	Jun-13	196.0	5.0	Dec-13	200.0	4.0	9.0		
3	1404	G-0023	Cummins	DFLC-5554001	1250	Diesel	Dec-12	591.9	Jun-13	594.0	2.1	Dec-13	595.2	1.2	3.3		
3	1488	G-0017	Caterpillar	SR-4	600	Diesel	Dec-12	399.0	Jul-13	404.0	5.0	Dec-13	411.0	7.0	12.0		
3	2322	G-0021	Onan Sons	DGDA-5005757	80	Diesel	Dec-12	414.3	Jul-13	417.3	3.0	Dec-13	424.0	6.7	9.7		
16	980	G-0033	Cummins	KTAG0-G2	1100	Diesel	Dec-12	428.0	Jul-13	431.0	3.0	Dec-13	432.6	1.6	4.6		
16	1374	G-0032	Onan Sons	60ENA	60	Nat. Gas	Dec-12	1414.0	Jul-13	1451.8	37.8	Dec-13	1479.0	27.2	65.0		
35	2	G-0034	Onan Sons	100DGB	100	Diesel	Dec-12	115.5	Jun-13	115.5	0.0	Dec-13	115.5	0.0	0.0		
35	402	G-0037	Cummins	DGCB-5674244	60	Diesel	Dec-12	377.2	Jun-13	400.0	22.8	Jan-14	423.4	23.4	46.2		
43	1	G-0031	Cummins	4BT3.9-GC	50	Diesel	Dec-12	463.0	Jul-13	472.6	9.6	Dec-13	478.0	5.4	15.0		
43	1	G-0030	Onan Sons	DVE	100	Diesel	Dec-12	910.0	Jul-13	943.0	33.0	Dec-13	967.0	24.0	57.0		
46	335	G-0036	Onan Sons	300DFCB	300	Diesel	Dec-12	1330.2	Jul-13	1374.0	43.8	Dec-13	1411.0	37.0	80.8		
48	45	G-0043	Onan Sons	DFCB-5740130	300	Diesel	Dec-12	215.0	Jun-13	231.0	16.0	Dec-13	238.0	7.0	23.0		
50	37	G-0039	Cummins	630FDR6595F	500	Diesel	Dec-12	502.8	Jul-13	502.8	0.0	Dec-13	502.8	0.0	0.0		
50	69	G-0040	Onan	DGDB-4687482	100	Diesel	Dec-12	359.7	Jun-13	365.6	5.9	Dec-13	367.9	2.3	8.2		
50	184	G-0044	Onan Sons	DGFA-568741	150	Diesel	Dec-12	492.0	Jun-13	523.0	31.0	Dec-13	523.0	0.0	31.0		
50	188	G-0038	Onan Sons	L340563879	1250	Diesel	Dec-12	149.0	Jun-13	149.0	0.0	Dec-13	149.0	0.0	0.0		
53	1	G-0004	Onan Sons	60ENA	60	Nat. Gas	Dec-12	1847.0	Jul-13	1852.6	5.6	Dec-13	1858.0	6.4	12.0		
53	2	G-0005	Kato Eng.	Kamsag-14	50	Diesel	Dec-12	196.5	Jun-13	196.5	0.0	Dec-13	196.5	0.0	0.0		
53	3N	G-0011	Onan	1500JC-18R	15	Propane	Dec-12	408.6	Jun-13	408.6	0.0	Dec-13	409.9	1.3	1.3		
54	412	G-0045	Olymplan	95M-07874-F	500	Diesel	Dec-12	349.1	Jun-13	349.1	0.0	Dec-13	service	0.0	0.0		
55	5	G-0049	Kohler	100RZ71	100	Propane	Dec-12	182.4	Jul-13	182.4	0.0	Dec-13	182.4	0.0	0.0		
55	8	G-0050	Delco/Detroit	E7014DD	600	Diesel	Dec-12	889.7	Jul-13	896.0	6.3	Dec-13	896.0	0.0	6.3		
55	364	G-0051	Onan Sons	1250DFLC-4887	1250	Diesel	Dec-12	246.7	Jul-13	261.4	14.7	Dec-13	278.0	16.6	31.3		
55	28	G-0047	Onan Sons	40DL6T	40	Diesel	Dec-12	144.1	Jul-13	144.1	0.0	Dec-13	145.2	1.1	1.1		
55	47	G-0048	Onan Sons	1465	200	Diesel	Dec-12	619.0	Jul-13	619.0	0.0	Dec-13	619.3	0.3	0.3		
55	142	G-0046	Cummins	DFEB-4963414	400	Diesel	Dec-12	183.0	Jul-13	185.6	2.6	Dec-13	186.3	0.7	3.3		
55	371	G-0053	Cummins	DFHD-4964979	1000	Diesel	Dec-12	673.0	Jul-13	673.0	0.0	Dec-13	673.0	0.0	0.0		
60	vard	G-0041	Onan Sons	250DVG	250	Diesel	Dec-12	240.0	Jul-13	249.0	9.0	Dec-13	283.0	34.0	43.0		
64	1	G-0041	Onan Sons	250DVG	250	Diesel	Dec-12	175.0	Jul-13	182.0	7.0	Dec-13	185.3	3.3	10.3		
69	33	G-0055	Cummins	DFLC-568730	1250	Diesel	Dec-12	175.0	Jul-13	182.0	7.0	Dec-13	185.3	3.3	10.3		
33 Generators														TOTAL	277.4	TOTAL	283.1

N/R = Not Read

Reviewed By / Date:

First half average hours per unit 8.4

Second half average hours per unit 8.9

Annual Average of hours per unit 10.2

EMISSION FACTORS	NOx	CO	SOx ⁹⁰	PM	PM10	VOC
Large Diesel fired ^{91(a)}	lb/kw-hr 0.032	lb/kw-hr 0.007	lb/kw-hr 5.4E-04	lb/kw-hr 0.001	lb/kw-hr 0.001	lb/kw-hr 0.001
Small Diesel fired ^{91(a)}	0.042	0.009	0.003	0.003	0.003	0.003
Natural Gas fired ⁹¹	0.008	0.013	2.0E-06	3.4E-05	3.2E-05	1.0E-04

References:

- 447
447 kw (600 hp) is the size limit for determining large vs. small diesel fired generator. This information was taken from the operating permit application and is also found in AP-42.
- (a) The AP-42 (fifth edition), Table 3.4-1, Emissions factor uses units of lb/HP-hr. There are 1,341 hp-hrs in a kw. Therefore, take pounds/HP-hr x 1,341 hp-hr/kwh to obtain the emission factor in lb/kwh.
- (b) Emission factors for large diesel fired engines were taken from AP-42 (fifth edition) Tables 3.4-1, 3.4-2, 3.4-3, and 3.4-4.
- (c) Emission factors for small diesel fired engines were taken from AP-42 (fifth edition) Tables 3.3-1 and 3.3-2.
- (d) The AP-42 (fifth edition) emission factors for natural gas burning 4-stroke rich-burn engines (Table 3.2-3) provides units of lb/MMBTU. There are 3413 Btu in a kilowatt-hr (kwh) or 2,928 x 10⁴ kwh per BTU. Therefore, take lb/MMBTU x 3413 / 1 x 10⁶ or lb/MMBTU / 062,928 x 10⁴ to obtain the emissions factor in lb/kwh. The differences between the Title V application emission factors and those listed here, are that the application used the 2-stroke table, and the above emission factors are for rich burn 4-stroke engines. Most generator engines have been verified with the KSL generator crew to be 4-stroke.
- (e) The Sulfur Oxide (SOx) emission factor for large diesel engines was calculated using AP-42 Table 3.4-1 (fifth edition). The calculation requires the sulfur percent found in the fuel. It was verified in March of 2007, that ultra fuel supplied to the generators around LANL will be Ultra Low Sulfur Diesel (ULSD) (Sulfur <= 15 ppm). Due to the low hours (and associated low fuel use) of most generators, the previous LANL tested fuel sulfur concentration of 0.05% will continue to be used for the rest of 2007 to allow for refueling of generators and use of the new ULSD. Calculation is 0.00809 * 0.05 * 0.608 * 2.2 = 5.4 x 10⁻⁴.

Location	First 6 Month Emissions						Second 6 Month Emissions					
	NOx (lb)	CO (lb)	SOx (lb)	PM (lb)	VOC (lb)	HAPs (lb)	NOx (lb)	CO (lb)	SOx (lb)	PM (lb)	VOC (lb)	HAPs (lb)
3-40	31.5	6.8	2.3	2.3	2.3	1.1E-02	31.5	6.8	2.3	2.3	2.3	1.0E-02
3-440	112.0	24.5	1.9	3.5	3.5	2.4E-02	81.6	17.9	1.4	2.6	2.6	1.5E-02
3-1076	3.2	0.7	0.2	0.2	0.2	1.1E-03	73.5	15.8	5.3	5.3	5.3	2.4E-02
3-1400	84.0	18.0	6.0	6.0	6.0	2.8E-02	67.2	14.4	4.8	4.8	4.8	2.2E-02
3-1404	84.0	18.4	1.4	2.6	2.6	1.8E-02	48.0	10.5	0.8	1.5	1.5	8.7E-03
3-1498	96.0	21.0	1.6	3.0	3.0	2.0E-02	134.4	29.4	2.3	4.2	4.2	2.4E-02
3-2322	10.1	2.2	0.7	0.7	0.7	3.4E-03	22.5	4.8	1.6	1.6	1.6	7.2E-03
16-980	105.6	23.1	1.8	3.3	3.3	2.2E-02	56.3	12.3	1.0	1.8	1.8	1.0E-02
16-1374	18.1	29.5	0.0	0.1	0.2	2.6E-01	13.1	21.2	0.0	0.1	0.2	1.8E-01
35-2	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
35-402	57.5	12.3	4.1	4.1	4.1	1.9E-02	59.0	12.6	4.2	4.2	4.2	1.9E-02
43-1	20.2	4.3	1.4	1.4	1.4	6.7E-03	11.3	2.4	0.8	0.8	0.8	3.7E-03
43-1	207.9	44.6	14.9	14.9	14.9	6.9E-02	151.2	32.4	10.8	10.8	10.8	4.9E-02
46-335	551.9	118.3	39.4	39.4	39.4	1.8E-01	466.2	99.9	33.3	33.3	33.3	1.5E-01
48-45	201.6	43.2	14.4	14.4	14.4	6.7E-02	88.2	18.9	6.3	6.3	6.3	2.9E-02
50-37	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
50-69	24.8	5.3	1.8	1.8	1.8	8.3E-03	9.7	2.1	0.7	0.7	0.7	3.1E-03
50-184	195.3	41.9	14.0	14.0	14.0	6.5E-02	0.0	0.0	0.0	0.0	0.0	0.0E+00
50-186	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
53-1	2.7	4.4	0.0	0.0	0.0	3.8E-02	3.1	5.0	0.0	0.0	0.0	4.3E-02
53-2	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
53-3N	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.2	0.3	0.0	0.0	0.0	1.9E-03
54-412	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
55-5	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
55-8	121.0	26.5	2.0	3.8	3.8	2.6E-02	0.0	0.0	0.0	0.0	0.0	0.0E+00
55-364	588.0	128.6	9.9	18.4	18.4	1.2E-01	664.0	145.3	11.2	20.8	20.8	1.2E-01
55-28	0.0	0.0	0.0	0.0	0.0	0.0E+00	1.8	0.4	0.1	0.1	0.1	5.9E-04
55-47	0.0	0.0	0.0	0.0	0.0	0.0E+00	2.5	0.5	0.2	0.2	0.2	8.1E-04
55-142	43.7	9.4	3.1	3.1	3.1	1.5E-02	11.8	2.5	0.8	0.8	0.8	3.8E-03
55-371	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
60-year	0.0	0.0	0.0	0.0	0.0	0.0E+00	0.0	0.0	0.0	0.0	0.0	0.0E+00
64-1	94.5	20.3	6.8	6.8	6.8	3.2E-02	357.0	76.5	25.5	25.5	25.5	1.1E-01
69-53	280.0	61.3	4.7	8.8	8.8	5.9E-02	132.0	28.9	2.2	4.1	4.1	2.4E-02
lbs/6 months	2933.5	664.2	132.4	152.4	152.6	1.1	2486.0	560.7	115.5	131.6	131.8	0.9
Tons/6 months	1.47	0.33	0.07	0.08	0.08	5.48E-04	1.24	0.28	0.06	0.07	0.07	4.34E-04
YEARLY TOTAL Tons/year	2.71	0.61	0.12	0.14	0.14	0.001						

Unit Data		Greenhouse Gas Emissions					References		
Location	ID #	Fuel Use Rate ^(a) (GPH/SCFH)	Calendar Year			Fiscal Year ^(b)			
			CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	
		Annual Fuel Use (Gal. or MMSCF)	CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	
3-40	G-0013	12.3	122.5	1.3	5.1E-05	1.0E-05	1.3	5.3E-05	1.1E-05
3-40	G-0020	21.8	263.9	2.7	1.1E-04	2.2E-05	3.0	1.2E-04	2.4E-05
3-1076	G-0022	2.9	154.7	1.5	6.3E-05	1.3E-05	0.8	3.3E-05	6.5E-06
3-1400	G-0024	27.3	245.4	2.5	1.0E-04	2.0E-05	2.8	1.1E-04	2.3E-05
3-1404	G-0023	87.3	288.1	2.9	1.2E-04	2.4E-05	12.5	5.1E-04	1.0E-04
3-1498	G-0017	42.7	512.4	5.2	2.1E-04	4.2E-05	6.1	2.5E-04	4.9E-05
3-2322	G-0021	6.3	61.1	0.6	2.5E-05	5.1E-06	0.6	2.3E-05	4.6E-06
16-980	G-0033	79.4	365.2	3.7	1.5E-04	3.0E-05	7.8	3.2E-04	6.3E-05
16-1374	G-0032	850.1	0.0553	3.0	5.6E-05	5.6E-06	3.4	6.5E-05	6.5E-06
35-2	G-0034	7.5	0.0	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
35-002	G-0037	4.7	217.1	2.2	9.0E-05	1.8E-05	2.2	9.1E-05	1.8E-05
43-1	G-0031	4.2	63.0	0.6	2.6E-05	5.2E-06	0.7	2.7E-05	5.3E-06
43-1	G-0031	12.3	698.3	7.1	2.9E-04	5.8E-05	9.1	3.7E-04	7.4E-05
46-335	G-0036	22.5	1818.0	18.6	7.5E-04	1.5E-04	18.1	7.3E-04	1.5E-04
48-45	G-0043	22.5	517.5	5.3	2.1E-04	4.3E-05	6.5	2.7E-04	5.3E-05
50-37	G-0039	34.4	0.0	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
50-69	G-0040	7.5	61.5	0.6	2.5E-05	5.1E-06	0.8	3.1E-05	6.1E-06
50-184	G-0044	11.1	344.1	3.5	1.4E-04	2.8E-05	5.6	2.3E-04	4.5E-05
53-2	G-0038	87.3	0.0	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
53-1	G-0004	850.1	0.0102	0.6	1.0E-05	1.0E-06	0.5	9.8E-06	1.5E-06
53-3N	G-0005	4.2	0.0	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
53-001	G-0011	116.6	0.0002	0.0	1.1E-06	2.3E-07	0.1	3.3E-06	6.5E-07
54-412	G-0045	36.6	0.0	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
55-5	G-0049	511.0	0.0000	0.0	0.0E+00	0.0E+00	0.0	0.0E+00	0.0E+00
55-8	G-0050	42.7	269.0	2.7	1.1E-04	2.2E-05	2.7	1.1E-04	2.2E-05
55-364	G-0051	87.3	2732.5	27.9	1.1E-03	2.3E-04	27.8	1.1E-03	2.3E-04
55-28	G-0047	4.5	4.9	0.1	2.0E-06	4.1E-07	0.1	4.8E-06	9.7E-07
55-47	G-0048	16.4	4.9	0.1	2.0E-06	4.1E-07	0.0	1.0E-06	2.0E-07
55-142	G-0046	27.3	90.1	0.9	3.7E-05	7.5E-06	2.1	8.4E-05	1.7E-05
55-371	G-xxxx	70.0	1575.0	16.1	6.5E-04	1.3E-04	9.1	3.7E-04	7.4E-05
60-yard	G-0053	87.3	0.0	0.0	0.0E+00	0.0E+00	1.3	5.4E-05	1.1E-05
64-1	G-0041	89.3	3539.9	39.2	1.6E-03	3.2E-04	28.7	1.2E-03	2.3E-04
69-33	G-0055	90.3	930.1	9.5	3.9E-04	7.7E-05	13.5	5.5E-04	1.1E-04
Totals:			158.46	6.4E-03	1.3E-03	167.49	6.7E-03	1.3E-03	168.06
Total CO₂ Equivalent:			154.90	6.28E-03	1.26E-03				
Emissions From Diesel:			3.5429	0.0001	0.0000				
Emissions From Natural Gas:			0.0234	0.0000	0.0000				
Emissions From Propane:									
Total Fuel Oil Use:			-15176.3	Gallons					

Fuel Type	Emission Factors (kg/mmBtu)	
	CO ₂ ^(a) (kg/mmBtu)	CH ₄ ^(a) N ₂ O ^(b) (kg/mmBtu)
Diesel	73.96	0.003
Nat. Gas	10.21	0.001
Propane	25.16	0.003

HHV is in units of mmbtu/gal for liquids and mmbtu/mmscf for gases.

Fuel Type	Emission Factors (kg/mmBtu)	
	CO ₂ ^(a) (kg/mmBtu)	CH ₄ ^(a) N ₂ O ^(b) (kg/mmBtu)
Diesel	73.96	0.003
Nat. Gas	10.21	0.001
Propane	25.16	0.003

HHV is in units of mmbtu/gal for liquids and mmbtu/mmscf for gases.

Emission Factors (lb/kwh)	HAPS (lbs)												HAPS (lbs)																	
	Benzene			Toluene			Xylenes			1,3-Butadiene			Formaldehyde			Acetaldehyde			Acrolein			Naphthalene			1,1,2,2-Tetrachloroethane			1,1,2-Trichloroethane		
Natural Gas	3.19E-06	1.91E-06	6.66E-07	7.30E-04	7.30E-04	7.30E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04		
Diesel (small)	3.19E-06	1.91E-06	6.66E-07	7.30E-04	7.30E-04	7.30E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04		
Diesel (large)	2.65E-06	1.40E-06	9.73E-07	6.59E-07	6.59E-07	6.59E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	1.34E-07	
Location	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half	1st Half	2nd Half
3-40	2.39E-03	2.39E-03	1.43E-03	1.05E-03	7.30E-04	7.30E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04	1.00E-04
3-440	9.28E-03	6.76E-03	6.67E-03	2.44E-03	1.69E-03	1.69E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3-107	2.45E-04	5.58E-03	1.47E-03	2.44E-03	7.49E-03	1.03E-03	2.34E-04	3.10E-04	7.05E-03	2.02E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04	2.19E-04
3-140	6.37E-03	5.10E-03	3.81E-03	2.23E-03	1.95E-03	1.56E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3-400	6.96E-03	3.98E-03	5.00E-03	1.24E-03	1.73E-03	9.89E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3-1498	7.95E-03	1.11E-02	5.72E-03	4.03E-03	1.98E-03	2.77E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
9-2322	7.65E-04	1.71E-02	4.74E-04	7.49E-04	2.34E-04	5.22E-04	3.20E-05	7.16E-05	6.07E-04	2.16E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03	6.29E-04	1.40E-03
16-980	8.75E-03	4.66E-03	6.29E-03	1.69E-03	2.18E-03	1.09E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
16-1374	1.22E-02	8.81E-03	6.29E-03	3.11E-03	1.51E-03	1.09E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
35-2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
35-402	4.36E-03	4.47E-03	2.61E-03	1.96E-03	1.33E-03	1.37E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
43-1	1.53E-03	8.60E-04	9.15E-04	3.77E-04	4.67E-04	2.63E-04	6.91E-05	3.81E-05	1.93E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03
43-1	1.58E-02	1.15E-02	9.43E-03	5.03E-03	4.82E-03	3.50E-03	6.01E-04	4.81E-04	1.99E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02	1.46E-02
46-335	4.19E-02	3.59E-02	2.90E-02	1.53E-02	1.28E-02	1.08E-02	7.95E-03	1.74E-03	1.99E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02
48-45	1.53E-02	6.69E-03	9.15E-03	2.93E-03	4.67E-03	2.04E-03	6.41E-04	2.80E-04	1.99E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02	3.44E-02
50-37	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
50-69	1.88E-03	7.33E-04	1.12E-03	3.21E-04	5.74E-04	2.24E-04	7.88E-05	3.07E-05	2.38E-03	3.27E-04	1.95E-03	6.02E-04	1.88E-04	7.27E-05	1.71E-04	6.66E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
50-184	1.48E-02	0.00E+00	3.88E-03	0.00E+00	4.53E-03	0.00E+00	6.21E-04	0.00E+00	1.87E-02	0.00E+00	1.22E-02	0.00E+00	1.47E-03	0.00E+00	1.35E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
50-188	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
53-1	1.81E-03	2.07E-03	6.40E-04	7.32E-04	2.24E-04	2.56E-04	7.61E-04	8.70E-04	2.35E-02	2.68E-02	3.20E-03	3.66E-03	3.02E-03	3.45E-03	1.11E-04	1.27E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
53-2	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
53-3N	0.00E+00	1.05E-04	0.00E+00	3.72E-05	0.00E+00	1.30E-05	0.00E+00	4.42E-05	0.00E+00	1.37E-03	0.00E+00	1.86E-04	0.00E+00	1.75E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
54-412	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
55-5	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
55-8	1.00E-02	0.00E+00	7.20E																											

2013 Small Boilers Data Entry / Gas Use

Data Entry	Metered Boilers		Total Gas Use ^(a) (Mscf)	Non-Metered Gas Use (MMscf)	12-Month Rolling Total for all Small Boilers (MMscf) ^(e)
	TA-55 Boiler Gas Use (Mscf) ^(c)	CMRR-RLUOB Gas Use (Mscf)			
	BHW-1B (B-602) ID (B-0016)	BHW-2B (B-603) ID (B-0017)			
Month	All 3 Boilers NMED IDs 90, 104, and 105		(MMscf)	(MMscf)	
January	2639	548	83,623	79.87	520.61
February	1952	33	67,185	64.65	522.88
March	1359	592	54,795	52.40	522.23
April	1738	2.0	43,060	40.91	524.94
May	1507	0.8	25,295	23.51	527.63
June	790	0	11,491	10.46	527.07
July	1158	2	11,317	10.00	525.25
August	497	794	11,389	9.95	521.96
September	252	1274	10,374	8.66	513.68
October	1878	7	38,938	36.73	517.71
November	1267	728	56,805	54.37	508.61
December	0.6	2187	72,975	70.25	487.25
TOTAL	15038	6168	487,247	461.76	870
			12 Month Permit Limit (MMscf) = 870		

2013 Non Metered Boiler Pool Capacity:	287.8	MMBTU/hr ^(f)
Estimated Gas-Use per MMBtu rating Jan-June:	0.94	MMscf/MMBtu/hr
Estimated Gas-Use per MMBtu rating July-Dec:	0.66	MMscf/MMBtu/hr
Estimated Gas-Use per MMBtu - Annual	1.60	MMscf/MMBtu/hr
Estimated Gas-Use per MMBtu - Fiscal Year	1.70	MMscf/MMBtu/hr

Gas Use Non-Metered ^(g) (MMSCF)			
NMED ID:	11	12	Insignificant Units ^(h)
Location:	TA-53-365	TA-53-365	Lab Wide
Equipment ID:	BHW-1	BHW-2	Various
Database ID:	B-0042	B-0043	B-0093/0092
Design Rate ⁽ⁱ⁾ (MMBTU/hr)	7.115	7.115	12.700
Calculated Gas Use-Jan-June	6.719	6.719	11.994
Calculated Gas Use-July-Dec	4.696	4.696	8.383
Calculated Gas Use-Annual	11.415	11.415	20.377

Reviewed By / Date:

Definitions:
MMSCF= Million Standard Cubic Feet
MSCF = Thousand Standard Cubic Feet

Emission Factors (lb/MMscf)				
Criteria Pollutant	Small Uncontrolled Boilers ¹	TA-16 Low NOx Boilers ⁴	TA-55-6 Boilers ³	RLUOB Boilers
NOX	100	37.08	138	29.9
SOX	0.6	0.6	0.6	0.6
PM ²	7.6	7.6	14.2	4.9
PM-10 ²	7.6	7.6	14.2	4.9
PM-2.5 ²	7.6	7.6	14.2	4.9
CO	84	37.08	38.2	38.1
VOC	5.5	5.5	5.98	25.8
HAPS⁹				

Arsenic	0.0002
Benzene	0.0021
BE	0.000012
Cadmium	0.0011
Chromium	0.0014
Cobalt	0.000084
Dichlorobenzene	0.0012
Formaldehyde	0.075
Hexane	1.8
Lead	0.0005
Manganese	0.00038
Mercury	0.00026
Napthalene	0.00061
Nickel	0.0021
POM	0.000088
Selenium	0.000024
Toluene	0.0034

References for Emission Factors

- (1) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers.
- (2) Emission factors for natural gas of PM-10 and PM-2.5 are roughly equal to those of PM, Natural Gas Combustion, Table 1.4-2.
- (3) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers for SOX. Stack test on 3/00 for NOx. Otherwise, Emission factors from Sellers Engineering Co.
- (4) AP-42, 7/98, Section 1.4, Natural Gas Combustion, Small Boilers; Emission factors for NOx and CO from Sellers Engineering Co (low-NOx boilers).
- (5) All HAP emission factors from AP-42 7/98, Section 1.4, Natural Gas Combustion, Tables 1.4-3, 1.4-4.

CMRR Boiler Fuel Oil Use (2013):

Date \ Boiler	BHW-1 (gal.)	BHW-2 (gal.)	BHW-3 (gal.)
1/8/2013	15.6	19.5	29.4
1/9/2013	23.4	7.5	48.7
1/10/2013	4.1	46	7.6
No additional fuel oil burned in these units since January 10, 2013			

Reading provided by Randy Johnson
 Reading provided by Randy Johnson
 Reading provided by Randy Johnson
 as of July 1, 2013, per Randy Johnson

2013 Small Boilers Emission Summary

Total Emissions (tons)

Pollutant Criteria	Annual* Emissions (Includes Insignificant Sources)	Jan-June* (Includes Insignificant Sources)	July-Dec* (Includes Insignificant Sources)	Jan-June CMRR-RLUOB Boilers	July-Dec CMRR-RLUOB Boilers
NOx	23.974	14.020	9.954	0.037	0.027
SOx	0.146	0.086	0.061	0.001	0.001
PM	1.916	1.118	0.798	0.006	0.004
PM-10	1.916	1.118	0.798	0.006	0.004
PM-2.5	1.916	1.118	0.798	0.006	0.004
CO	19.403	11.395	8.008	0.047	0.034
VOC	1.388	0.813	0.575	0.032	0.023
HAPs					
Arsenic	4.87E-05	2.85E-05	2.02E-05	2.49E-07	1.79E-07
Benzene	5.12E-04	3.00E-04	2.12E-04	2.61E-06	1.88E-06
BE	2.92E-06	1.71E-06	1.21E-06	1.49E-08	1.07E-08
Cadmium	2.68E-04	1.57E-04	1.11E-04	1.37E-06	9.85E-07
Chromium	3.41E-04	2.00E-04	1.41E-04	1.74E-06	1.25E-06
Cobalt	2.05E-05	1.20E-05	8.48E-06	1.05E-07	7.52E-08
Dichlorobenzene	2.92E-04	1.71E-04	1.21E-04	1.49E-06	1.07E-06
Formaldehyde	1.83E-02	1.07E-02	7.57E-03	9.34E-05	6.71E-05
Hexane	4.39E-01	2.57E-01	1.82E-01	2.24E-03	1.61E-03
Lead	1.22E-04	7.14E-05	5.04E-05	6.23E-07	4.48E-07
Manganese	9.26E-05	5.42E-05	3.83E-05	4.73E-07	3.40E-07
Mercury	6.33E-05	3.71E-05	2.62E-05	3.24E-07	2.33E-07
Napthalene	1.49E-04	8.71E-05	6.15E-05	7.59E-07	5.46E-07
Nickel	5.12E-04	3.00E-04	2.12E-04	2.61E-06	1.88E-06
POM	2.14E-05	1.26E-05	8.88E-06	1.10E-07	7.88E-08
Selenium	5.85E-06	3.43E-06	2.42E-06	2.99E-08	2.15E-08
Toluene	8.28E-04	4.85E-04	3.43E-04	4.23E-06	3.04E-06
TOTAL HAPs	0.460	0.270	0.191	0.002	0.002

* The totals include exempt, non-exempt, metered, and non-metered boilers (all boilers except Power Plant boilers).

REFERENCES

- (a) Information on non-metered boilers is provided in the facility wide gas use report by Utilities and Infrastructure and contains all gas use at LANL minus those non-LANL sources which feed from the LANL main line and LANL sources that are individually metered. Total Gas use does not include the TA-3 Power Plant. All other sources are included in this total.
- (b) TA-16 Boilers include 2 boilers in plant 5. Gas use was difficult to obtain, so, the boilers were included in the "boiler pool" to determine gas use. Plant 6 has been taken off line and is not expected to be reused or boilers relocated. The removal of these boilers will be requested in the next operating permit revision.
- (c) TA-55 has two boilers with separate AIRs numbers. Each boiler has a gas meter. The gas use information is provided monthly by the Utility and Infrastructure personnel and is included in the facility wide gas report.
- (d) The TA-50-RLWTF, TA-48-1 BS-1, and TA-59-1 BHW-2 boilers were removed from service in 2011. These units will be removed from the operating permit. The boilers were removed from these emission calculations for FY 2012. Replacement boilers for TA-48 and TA-59 are small comfort heat boilers and are exempt sources.
- (e) The 12-month rolling average includes all gas use from all boilers listed in this spreadsheet. Boilers not included in this report due to their large size or design are powerplant boilers at TA-3. A gas use limit of 870 MMscf/yr, 12-month rolling average is a permit limit in Section 2.4 of the LANL operating permit.
- (f) The non-metered boiler pool capacity is the sum of all active non-metered boilers design ratings (derated value, called design rating in boiler data base) in MMBTU. This number is used to estimate the gas use rate (total non-metered gas use divided by the non-metered boiler pool capacity number). This value is taken from the boilers database (Access) on the database drive on the cleanair server within ENV-ES.
- (g) The non-metered boilers gas use section provides estimates of gas use for each boiler. This is calculated using the non-metered gas rate, as discussed in reference (f). The individual boiler design rating is multiplied by the gas use rate to provide the estimated gas used per reporting period (in MMSCF). Boilers previously included at TA-48 and TA-59 were replaced with smaller exempt boilers an removed from these calcs on 10-15-12.
- (h) NMED List of Insignificant Activities (9/95), Item (3.) exempts fuel burning equipment which uses gaseous fuel, has a design rate less than or equal to 5 MMBTU/hr, and is used for heating buildings for personal comfort or for producing hot water for personal use. This value contains natural gas fired HVAC units as well as some NG heating units.
- (i) The design rate for boilers includes a correction for elevation. LANL is at approximately 7,500 feet above sea level. Corrections are made for atmospheric boilers using 4% reduction (derated) for each 1,000 feet above sea level ($4\% \times 7.5 = 30\%$). For forced draft and power burner boilers, the reduction is half that of atmospheric at 15%. The correction is made using the boiler plate input rating minus the appropriate percentage.

2013 Non-Exempt Boiler Emissions for Annual EI Reporting (Tons)

Pollutant	AI RS 018 TA-53-365 BHW-1	AI RS 019 TA-53-365 BHW-2	AI RS 024 TA-16 BS-1	AI RS 024 TA-16 BS-2	AI RS 037 TA-55-6 BHW-1B	AI RS 038 TA-55-6 BHW-2B	AI RS New TA-55-440 B-1	AI RS New TA-55-440 B-2	AI RS New TA-55-440 B-3	Total
NOx	0.571	0.571	0.189	0.189	1.038	0.426	0.021	0.021	0.021	3.046
SOx	0.003	0.003	0.003	0.003	0.005	0.002	0.0004	0.0004	0.0004	0.021
PM	0.043	0.043	0.039	0.039	0.107	0.044	0.004	0.004	0.004	0.325
PM-10	0.043	0.043	0.039	0.039	0.107	0.044	0.004	0.004	0.004	0.325
PM-2.5	0.043	0.043	0.039	0.039	0.107	0.044	0.004	0.004	0.004	0.325
CO	0.479	0.479	0.189	0.189	0.287	0.118	0.027	0.027	0.027	1.823
VOC	0.031	0.031	0.028	0.028	0.045	0.018	0.018	0.018	0.018	0.237
HAPs										
Arsenic	1.14E-06	1.14E-06	1.02E-06	1.02E-06	1.50E-06	6.17E-07	1.43E-07	1.43E-07	1.43E-07	6.87E-06
Benzene	1.20E-05	1.20E-05	1.07E-05	1.07E-05	1.58E-05	6.48E-06	1.50E-06	1.50E-06	1.50E-06	7.21E-05
BE	6.85E-08	6.85E-08	6.11E-08	6.11E-08	9.02E-08	3.70E-08	8.56E-09	8.56E-09	8.56E-09	4.12E-07
Cadmium	6.28E-06	6.28E-06	5.60E-06	5.60E-06	8.27E-06	3.39E-06	7.85E-07	7.85E-07	7.85E-07	3.78E-05
Chromium	7.99E-06	7.99E-06	7.13E-06	7.13E-06	1.05E-05	4.32E-06	9.99E-07	9.99E-07	9.99E-07	4.81E-05
Cobalt	4.79E-07	4.79E-07	4.28E-07	4.28E-07	6.32E-07	2.59E-07	5.99E-08	5.99E-08	5.99E-08	2.89E-06
Dichlorobenzene	6.85E-06	6.85E-06	6.11E-06	6.11E-06	9.02E-06	3.70E-06	8.56E-07	8.56E-07	8.56E-07	4.12E-05
Formaldehyde	4.28E-04	4.28E-04	3.82E-04	3.82E-04	5.64E-04	2.31E-04	5.35E-05	5.35E-05	5.35E-05	2.58E-03
Hexane	1.03E-02	1.03E-02	9.17E-03	9.17E-03	1.35E-02	5.55E-03	1.28E-03	1.28E-03	1.28E-03	6.18E-02
Lead	2.85E-06	2.85E-06	2.55E-06	2.55E-06	3.76E-06	1.54E-06	3.57E-07	3.57E-07	3.57E-07	1.72E-05
Manganese	2.17E-06	2.17E-06	1.94E-06	1.94E-06	2.86E-06	1.17E-06	2.71E-07	2.71E-07	2.71E-07	1.31E-05
Mercury	1.48E-06	1.48E-06	1.32E-06	1.32E-06	1.95E-06	8.02E-07	1.85E-07	1.85E-07	1.85E-07	8.93E-06
Napthalene	3.48E-06	3.48E-06	3.11E-06	3.11E-06	4.59E-06	1.88E-06	4.35E-07	4.35E-07	4.35E-07	2.10E-05
Nickel	1.20E-05	1.20E-05	1.07E-05	1.07E-05	1.58E-05	6.48E-06	1.50E-06	1.50E-06	1.50E-06	7.21E-05
POM	5.02E-07	5.02E-07	4.48E-07	4.48E-07	6.62E-07	2.71E-07	6.28E-08	6.28E-08	6.28E-08	3.02E-06
Selenium	1.37E-07	1.37E-07	1.22E-07	1.22E-07	1.80E-07	7.40E-08	1.71E-08	1.71E-08	1.71E-08	8.24E-07
Toluene	1.94E-05	1.94E-05	1.73E-05	1.73E-05	2.56E-05	1.05E-05	2.43E-06	2.43E-06	2.43E-06	1.17E-04
TOTAL HAPs	1.08E-02	1.08E-02	9.62E-03	9.62E-03	1.42E-02	5.82E-03	1.35E-03	1.35E-03	1.35E-03	0.06

EPCRA 313 Chemical ^a	Emissions from all Small Boilers ^b		References
	Emission Factor (lbs/MMscf)	Emission (lbs)	
Lead ^c	5.0E-04	2.56E-01	(a) Amount of EPCRA chemical in fuel is considered "otherwise used" for EPCRA 313 threshold determination
Sulfuric Acid ^d	0.6	307.64	(b) Combustion compounds emitted are considered "manufactured" for EPCRA 313 threshold determinations. Lead and mercury are included with lead compounds and mercury compounds respectively.
Mercury ^c	2.6E-04	1.33E-01	(c) Emission Factors from AP-42, Section 1.4, Natural Gas Combustion, Tables 1.4-2, 1.4-3 and 1.4-4, July 1998
PACs ^e	8.69E-07	4.46E-04	(d) Assume all SOx emissions are converted to sulfuric acid in the stack.
Benzo(g,h,i) perylene ^c	1.20E-06	6.15E-04	(e) EPCRA PAC Guidance Document, Table 2-3

Greenhouse Gas Emissions

Emission Factors		References	
CO ₂ ^(a)	53.02 kg/mmBtu	(a)	From 40 CFR Part 98, Subpart C, Table C-1, "Default CO ₂ Emission Factors and High Heat Values for Various Types of Fuel."
CH ₄ ^(b)	0.001 kg/mmBtu	(b)	From 40 CFR Part 98, Subpart C, Table C-2, "Default CH ₄ and N ₂ O Emission Factors for Various Types of Fuel."
N ₂ O ^(b)	0.0001 kg/mmBtu	(c)	The average high heat value (HHV) is shown. Initial HHV is provided in Btu/SCF. HHV is taken from the monthly "Totalizer Report".
LANL Natural Gas High Heat Value ^(c) : 1020.8 mmBtu/mmSCF			
Equation: Fuel Use MMscf/year * Nat. Gas MMBTU/MMscf * Emission Factor kg/MMBTU * metric ton/1000 kg			

Metered Boilers		Calendar Year		Fiscal Year ^(e)		
Location	Unit No.	NMED ID	CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	Total CO ₂ Equivalents (metric tons)
TA-55-6	BHW-1	29	813.91	0.015	0.002	814.8
TA-55-6	BHW-2	30	333.83	0.006	0.001	334.2
TA-55-440	B-1thru3		231.66	0.004	0.0004	231.9
Metered Total			1379.39	0.026	0.003	1148.9

Non-Metered Boilers		Calendar Year		Fiscal Year ^(e)		
Location	Unit No.	NMED ID	CO ₂ (metric tons)	CH ₄ (metric tons)	N ₂ O (metric tons)	Total CO ₂ Equivalents (metric tons)
TA-53-365	BHW-1	11	617.83	0.012	0.001	618.5
TA-53-365	BHW-2	12	617.83	0.012	0.001	618.5
TA-16-1484	Plant 5	53	1102.88	0.021	0.002	1104.0
Lab Wide	Various	None	22654.32	0.427	0.043	22677.7
Non-Metered Total			24992.86	0.471	0.047	25018.7
Total CO₂ Equivalents (metric tons)						26167.6
						Total CO₂ Equivalents (metric tons)
						27592.3

2013 Combustion Turbine Emissions (Actual)

Pollutant Criteria	Emission Factors (lb/MMscf)	Unit Emissions (Tons)				Reference	References:
		TA-3-2422 Combustion Turbine					
		Annual (tons)	Jan-June (tons)	July-Dec (tons)			
NOx	50.5	2.393	0.925	1.468	a	(a) Values are from the initial compliance test (TRC - October 22, 2007). Test shows average NOx as 11.29 lbs/hr and CO as 2.35 lbs/hr. These were divided by the gas flow rate of 0.223620 MMscf/hr to get 50.48 lb/MMscf (rounded to 50.5) for NOx and 10.5 lb/MMscf for CO. The SCFH value (fuel flow rate) from the compliance test report (223620 SCFH or 223.6 MSCFH)	
SOx	3.5	0.166	0.064	0.102	b		
PM	6.8	0.322	0.124	0.198	c		
PM ₁₀	6.8	0.322	0.124	0.198	c		
PM _{2.5}	6.8	0.322	0.124	0.198	c	(b) The SOx emission factor was taken from AP-42 Table 3.1-2a. The default value is used when percent sulfur is unknown (0.0034 lb/mmBtu). This is equivalent to converting the 2 grains per 100 scf to percent. The 0.0034 lb/mmBtu was converted to lb/mmscf by multiplying by 1030 btu/scf (the heat value of natural gas), to provide 3.5 lb/mmscf.	
CO	10.5	0.497	0.192	0.305	a		
VOC	2.2	0.104	0.040	0.064	d		
HAPs / TRI							
Acetaldehyde	4.12E-02	1.95E-03	7.54E-04	1.20E-03	e, f, g	(c) PM was calculated by taking the AP-42, Table 3.1-2a, EF of 6.6E-3 lb/MMBtu and multiplying it by 1030 BTU/scf to get 6.8 lb/MMscf. PM10 was calculated the same as PM, as most PM from natural gas combustion is less than 1 micrometer.	
Acrolein	6.59E-03	3.12E-04	1.21E-04	1.92E-04	e, f, g		
Benzene	1.24E-02	5.86E-04	2.26E-04	3.59E-04	e, f, g		
Benzo (a) anthracene	3.09E-03	1.46E-04	5.66E-05	8.98E-05	f, h		
1,3-Butadiene	4.43E-04	2.10E-05	8.11E-06	1.29E-05	e, f, g		
Cadmium	7.11E-03	3.37E-04	1.30E-04	2.07E-04	f, h	(d) The VOC emission factor was taken from AP-42 Table 3.1-2a. The factor, 2.1 E-03 lb/mmBtu, was converted to lb/mmscf by multiplying by 1030 giving 2.2 lbs/mmscf.	
Chromium	1.34E-02	6.34E-04	2.45E-04	3.89E-04	f, h		
Copper	7.11E-02	3.37E-03	1.30E-03	2.07E-03	f, h		
Ethylbenzene	3.30E-02	1.56E-03	6.03E-04	9.58E-04	e, f, g	(e) These chemicals are HAPs	
Fluoranthene	1.24E-03	5.86E-05	2.26E-05	3.59E-05	f, h	(f) These chemicals are EPCRA 313 listed chemicals.	
Formaldehyde	7.31E-01	3.46E-02	1.34E-02	2.13E-02	e, f, g	(g) Emission factor from AP-42, table 3.1-3 (lb/mmBtu). This was multiplied by 1030 Btu/scf to provide the lb./mmscf factor.	
Manganese	8.24E-02	3.90E-03	1.51E-03	2.40E-03	f, h		
Mercury	6.80E-03	3.22E-04	1.24E-04	1.98E-04	f, h	(h) Emission factors from EPA FIRE database (SCC: 20300202 & 20200201). These values were also converted from lb/mmBtu to lb/mmscf. Retrieved 4-14-08.	
Napthalene	1.34E-03	6.34E-05	2.45E-05	3.89E-05	e, f, g		
Nickel	1.18E-01	5.61E-03	2.17E-03	3.44E-03	f, h		
PAH	2.27E-03	1.07E-04	4.15E-05	6.59E-05	e, f, g	(i) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-1. "Default CO2 Emission Factors and High Heat Values for Various Types of Fuel." Units are kg/mmBtu.	
Phenol	1.34E-02	6.34E-04	2.45E-04	3.89E-04	e, f, g		
Propylene Oxide	2.99E-02	1.42E-03	5.47E-04	8.68E-04	e, f, g		
Toluene	1.34E-01	6.34E-03	2.45E-03	3.89E-03	e, f, g	(j) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-2. "Default CH4 and N2O Emission Factors for Various Types of Fuel." Units are kg/mmBtu.	
Xylenes (isomers)	6.59E-02	3.12E-03	1.21E-03	1.92E-03	e, f, g		
TOTAL HAPs		6.52E-02	2.52E-02	4.00E-02			
Greenhouse Gases	Emission Factors (kg/mmBtu)	Calender Yr (metric tons)	Fiscal Yr (metric tons)	Fiscal Yr (metric tons)	Reference		
CO ₂	53.02	5128.9	6602.5	6602.5	i, l	(k) Average high heat values for natural gas used at LANL were calculated each month. The average was taken from the monthly "TA-3 Power Plant Totalizer Report."	
CH ₄	0.001	0.097	0.1	0.1	j, l	(l) Fiscal year begins on October 1st and ends on September 30th of the following year.	
N ₂ O	0.0001	0.010	0.0	0.0	j, l		
CO₂ Equivalent Emissions (metric tons):		5134.2	6609.4	6609.4			

Monthly Emission Calculation - 2013
Unit TA-3-22-CT-1 TA-3 - Combustion Turbine
 (Required by Condition A1307.A of Title V Permit P100-R1-M1)

Monthly Average Hourly Emissions Rate (pph)

	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Allowable
NOx	11.38	9.48	9.76	9.61	9.62	9.54	10.25	10.32	10.39	10.52	10.73	8.65	23.8
SOx	0.79	0.66	0.68	0.67	0.67	0.66	0.71	0.72	0.72	0.73	0.74	0.60	1.7
PM	1.53	1.28	1.31	1.29	1.30	1.28	1.38	1.39	1.40	1.42	1.45	1.16	1.9
PM-10	1.53	1.28	1.31	1.29	1.30	1.28	1.38	1.39	1.40	1.42	1.45	1.16	1.9
PM-2.5	1.53	1.28	1.31	1.29	1.30	1.28	1.38	1.39	1.40	1.42	1.45	1.16	1.9
CO	2.37	1.97	2.03	2.00	2.00	1.98	2.13	2.15	2.16	2.19	2.23	1.80	29
VOC	0.50	0.41	0.43	0.42	0.42	0.42	0.45	0.45	0.45	0.46	0.47	0.38	0.6

12-Month Rolling Emission Rate* (TPY)

	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Allowable
NOx	4.288	3.172	2.871	2.586	2.703	2.887	3.165	3.328	3.080	2.368	2.432	2.393	59.4
SOx	0.297	0.220	0.199	0.179	0.187	0.200	0.219	0.231	0.213	0.164	0.169	0.166	4.2
PM	0.577	0.427	0.387	0.348	0.364	0.389	0.426	0.448	0.415	0.319	0.327	0.322	4.8
PM-10	0.577	0.427	0.387	0.348	0.364	0.389	0.426	0.448	0.415	0.319	0.327	0.322	4.8
PM-2.5	0.577	0.427	0.387	0.348	0.364	0.389	0.426	0.448	0.415	0.319	0.327	0.322	4.8
CO	0.892	0.660	0.597	0.538	0.562	0.600	0.658	0.692	0.640	0.492	0.506	0.497	72.3
VOC	0.187	0.138	0.125	0.113	0.118	0.126	0.138	0.145	0.134	0.103	0.106	0.104	1.5

* Using rolling fuel use

TA-3 Power Plant Fuel Use Totals 2013 (Data Entry)

DATA ENTRY						
	TA-3-22 Power Plant ^o Boiler # 1 (Edgemoor Iron Works, 210 mmBtu/hr)	TA-3-22 Power Plant ^o Boiler # 2 (Edgemoor Iron Works, 210 mmBtu/hr)	TA-3-22 Power Plant ^o Boiler # 3 (Union Iron Works, 210 mmBtu/hr)	Monthly Totals		
Month	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a	Natural Gas (mmscf) ^a	Fuel Oil (gallons) ^a
January	58,093	1,517	28	0	2,062	2,485
February	6,010	0	41,409	0	2,279	0
March	6	0	34,046	0	9,252	0
April	0	0	474	0	36,679	0
May	6,679	0	0	0	20,692	0
June	16,782	0	0	0	0	0
July	16,569	0	2	0	388	0
August	57	0	4	0	13,364	0
September	9,684	0	0	0	8,495	0
October	31,261	0	0	0	4,325	0
November	47,377	0	0	0	1,248	0
December	59,173	0	0	0	401	0
Annual Totals:	251,691	1,517	75,962	0	99,186	2,485
Jan. - June	87,570	1,517	75,956	0	70,964	2,485
July - Dec.	164,121	0	6	0	28,221	0

Month	12-Mo. Rolling Total		12-Mo. Rolling Total		Hours of Operation		Hours of Operation		Hours of Operation		*12-Month Rolling Total Hours (All Boilers)		
	Natural Gas (mmscf)	Fuel Oil (gallons)	Natural Gas (mmscf)	Fuel Oil (gallons)	Gas Boiler 1	Gas Boiler 2	Gas Boiler 3	Fuel Oil Boiler 1	Fuel Oil Boiler 2	Fuel Oil Boiler 3	Fuel Oil Boiler 1	Fuel Oil Boiler 2	Fuel Oil Boiler 3
January	424.9	4,002	723.7	0.0	41.5	0.0	0.0	2.9	0.0	0.0	6.7	0.0	0.0
February	418.9	4,002	85.9	572.5	34.5	572.5	34.5	0.0	0.0	0.0	0.0	0.0	0.0
March	415.6	4,002	0.0	576.0	177.2	576.0	177.2	0.0	0.0	0.0	0.0	0.0	0.0
April	417.0	4,002	0.0	11.4	717.7	11.4	717.7	0.0	0.0	0.0	0.0	0.0	0.0
May	416.9	4,002	227.9	0.0	518.8	0.0	518.8	0.0	0.0	0.0	0.0	0.0	0.0
June	415.5	4,002	719.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
July	414.6	4,002	728.9	0.0	14.7	0.0	14.7	0.0	0.0	0.0	0.0	0.0	0.0
August	413.1	4,002	0.5	0.0	597.6	0.0	597.6	0.0	0.0	0.0	0.0	0.0	0.0
September	411.4	4,002	354.8	0.0	364.6	0.0	364.6	0.0	0.0	0.0	0.0	0.0	0.0
October	416.0	4,002	661.1	0.0	83.4	0.0	83.4	0.0	0.0	0.0	0.0	0.0	0.0
November	423.3	4,002	703.4	0.0	19.2	0.0	19.2	0.0	0.0	0.0	0.0	0.0	0.0
December	426.8	4,002	737.7	0.0	6.7	0.0	6.7	0.0	0.0	0.0	0.0	0.0	0.0
Permit Limits:	1000 MMscf	500,000 gal											

* The requirement to calculate a 12 month rolling total of hours became effective on June 15, 2012.

Data Reviewed By: _____

For References, See "Emission Summary Sheet"

12 Month Rolling Fuel Totals For Each Individual Boiler - 2013

Month	Boiler 1		Boiler 2		Boiler 3	
	Natural Gas (mmscf)	Fuel Oil (gal.)	Natural Gas (mmscf)	Fuel Oil (gal.)	Natural Gas (mmscf)	Fuel Oil (gal.)
January	279	1,517	111	0	34	2,485
February	231	1,517	153	0	35	2,485
March	214	1,517	161	0	41	2,485
April	214	1,517	126	0	77	2,485
May	221	1,517	98	0	98	2,485
June	237	1,517	80	0	98	2,485
July	254	1,517	76	0	84	2,485
August	243	1,517	76	0	94	2,485
September	233	1,517	76	0	102	2,485
October	233	1,517	76	0	107	2,485
November	248	1,517	76	0	99	2,485
December	252	1,517	76	0	99	2,485

Emissions by Boiler 2013

Pollutant Criteria	Emission Factor		Unit Emissions						Unit Emissions								
	Natural Gas (lb/mmscf)	Fuel Oil ^(f) lbs/1000 gal	Boiler #1, Stack 032			Boiler #2, Stack 033			Boiler #3, Stack 034			Boiler #3, Stack 034					
			Annual Natl Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)	Annual Natl Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)	Annual Natl Gas (tons)	Annual Fuel Oil (tons)	Jan-June (gas&oil) (tons)	July-Dec (gas&oil) (tons)			
NOX ^(c)	58	8.64	7.299	0.007	2.546	4.759	2.203	0.000	2.203	0.000	0.000	2.203	0.000	2.876	0.011	2.069	0.818
SOx ^(g)	0.6	7.4	0.076	0.006	0.032	0.049	0.023	0.000	0.023	0.000	0.000	0.023	0.000	0.030	0.009	0.030	0.008
PM ^(d)	7.6	3.3	0.956	0.003	0.335	0.624	0.289	0.000	0.289	0.000	0.000	0.289	0.000	0.377	0.004	0.274	0.107
PM-10 ^(d)	7.6	2.3	0.956	0.002	0.335	0.624	0.289	0.000	0.289	0.000	0.000	0.289	0.000	0.377	0.003	0.273	0.107
PM-2.5 ^(d)	7.6	1.55	0.956	0.001	0.334	0.624	0.289	0.000	0.289	0.000	0.000	0.289	0.000	0.377	0.002	0.272	0.107
CO ^(e)	40	5.0	5.034	0.004	1.755	3.282	1.519	0.000	1.519	0.000	0.000	1.519	0.000	1.984	0.006	1.425	0.564
VOC	5.5	0.2	0.692	0.0002	0.241	0.451	0.209	0.0000	0.209	0.0000	0.0000	0.209	0.0000	0.273	0.000	0.195	0.078
HAPS ^(h)																	
Arsenic	0.0002	0.00055	2.52E-05	4.16E-07	9.17E-06	1.64E-05	7.60E-06	0.00E+00	7.60E-06	5.90E-10	9.92E-06	6.81E-07	7.78E-06	9.92E-06	6.81E-07	7.78E-06	2.82E-06
Benzene	0.0021	-	2.64E-04	0.0	9.19E-05	1.72E-04	7.98E-05	0.0	7.98E-05	6.20E-09	1.04E-04	0.0	7.45E-05	1.04E-04	0.0	7.45E-05	2.96E-05
Beryllium	0.000012	0.00041	1.51E-06	3.12E-07	8.37E-07	9.85E-07	4.56E-07	0.00E+00	4.56E-07	3.54E-11	5.95E-07	5.11E-07	9.36E-07	5.95E-07	5.11E-07	9.36E-07	1.69E-07
Cadmium	0.0011	0.00041	1.38E-04	3.12E-07	4.85E-05	9.03E-05	4.18E-05	0.00E+00	4.18E-05	3.25E-09	5.46E-05	5.11E-07	3.95E-05	5.46E-05	5.11E-07	3.95E-05	1.55E-05
Chromium	0.0014	0.00041	1.76E-04	3.12E-07	6.16E-05	1.15E-04	5.32E-05	0.00E+00	5.32E-05	4.13E-09	6.94E-05	5.11E-07	5.02E-05	6.94E-05	5.11E-07	5.02E-05	1.98E-05
Cobalt	0.000084	-	1.06E-05	0.0	3.68E-06	6.89E-06	3.19E-06	0.0	3.19E-06	2.48E-10	4.17E-06	0.0	2.98E-06	4.17E-06	0.0	2.98E-06	1.19E-06
Dichlorober	0.0012	-	1.51E-04	0.0	5.25E-05	9.85E-05	4.56E-05	0.0	4.56E-05	3.54E-09	5.95E-05	0.0	4.26E-05	5.95E-05	0.0	4.26E-05	1.69E-05
Formaldehy	0.075	0.048	9.44E-03	3.64E-05	3.32E-03	6.15E-03	2.85E-03	0.00E+00	2.85E-03	2.21E-07	3.72E-03	5.96E-05	2.72E-03	3.72E-03	5.96E-05	2.72E-03	1.06E-03
Hexane	1.8	-	2.27E-01	0.0	7.88E-02	1.48E-01	6.84E-02	0.0	6.84E-02	5.31E-06	8.93E-02	0.0	6.39E-02	8.93E-02	0.0	6.39E-02	2.54E-02
Lead	0.0005	0.00123	6.29E-05	9.35E-07	2.28E-05	4.10E-05	1.90E-05	0.00E+00	1.90E-05	1.48E-09	2.48E-05	1.53E-06	1.93E-05	2.48E-05	1.53E-06	1.93E-05	7.06E-06
Manganese	0.00038	0.00082	4.78E-05	6.24E-07	1.73E-05	3.12E-05	1.44E-05	0.00E+00	1.44E-05	1.12E-09	1.88E-05	1.02E-06	1.45E-05	1.88E-05	1.02E-06	1.45E-05	5.36E-06
Mercury ⁽ⁱ⁾	0.00026	0.00041	3.27E-05	3.12E-07	1.17E-05	2.13E-05	9.88E-06	0.00E+00	9.88E-06	7.67E-10	1.29E-05	5.11E-07	9.74E-06	1.29E-05	5.11E-07	9.74E-06	3.67E-06
Napthalene	0.00061	-	7.68E-05	0.0	2.67E-05	5.01E-05	2.32E-05	0.0	2.32E-05	1.80E-09	3.03E-05	0.0	2.16E-05	3.03E-05	0.0	2.16E-05	8.61E-06
Nickel	0.0021	0.00041	2.64E-04	3.12E-07	9.23E-05	1.72E-04	7.98E-05	0.00E+00	7.98E-05	6.20E-09	1.04E-04	5.11E-07	7.50E-05	1.04E-04	5.11E-07	7.50E-05	2.96E-05
POM	0.000088	0.0033	1.11E-05	2.50E-06	6.36E-06	7.22E-06	3.34E-06	0.00E+00	3.34E-06	2.60E-10	4.36E-06	4.10E-06	7.22E-06	4.36E-06	4.10E-06	7.22E-06	1.24E-06
Selenium	0.000024	0.00206	3.02E-06	1.56E-06	2.61E-06	1.97E-06	9.12E-07	0.00E+00	9.12E-07	7.08E-11	1.19E-06	2.55E-06	3.40E-06	1.19E-06	2.55E-06	3.40E-06	3.39E-07
Toluene	0.0034	-	4.28E-04	0.0	1.49E-04	2.79E-04	1.29E-04	0.0	1.29E-04	1.00E-08	1.69E-04	0.0	1.21E-04	1.69E-04	0.0	1.21E-04	4.80E-05
TOTAL HAPS			2.38E-01	4.40E-05	8.27E-02	1.55E-01	7.17E-02	0.00E+00	7.17E-02	5.57E-06	9.37E-02	7.21E-05	6.71E-02	9.37E-02	7.21E-05	6.71E-02	2.66E-02

For References, see Emission Summary.

2013 Greenhouse Gas Emissions												
CALENDER YEAR												
Emission Unit Number	Natural Gas Emissions			Fuel Oil Emissions			Total Emissions			References		
	CO2 metric tons	CH4 metric tons	N2O metric tons	CO2 metric tons	CH4 metric tons	N2O metric tons	CO2 metric tons	CH4 metric tons	N2O metric tons	LANL Natural Gas High Heat Value ^(c) : Fuel Oil Default High Heat Value ^(a) :	1020.8 mmBtu/mmmscf 0.138 mmBtu/gallon	
TA-3-22-1	13622.8	0.257	0.026	15.49	0.001	0.000	13638.2	0.258	0.026	CO ₂ ^(a)	53.02 kg/mmBtu	73.96 kg/mmBtu
TA-3-22-2	4111.4	0.078	0.008	0.00	0.000	0.000	4111.4	0.078	0.008	CH ₄ ^(b)	0.001 kg/mmBtu	0.003 kg/mmBtu
TA-3-22-3	5368.4	0.101	0.010	25.36	0.001	0.000	5393.8	0.102	0.010	N ₂ O ^(b)	0.0001 kg/mmBtu	0.0006 kg/mmBtu
Totals:	23102.6	0.436	0.044	40.85	0.002	0.000	23143.5	0.437	0.044			
			Plant Totals (metric tons):			23143.5						
			CO₂ Equivalent Total Emissions (metric tons):			23167.5						
FISCAL YEAR ^(e)												
Emission Unit Number	Natural Gas Emissions			Fuel Oil Emissions			Total Emissions			References		
	CO2 metric tons	CH4 metric tons	N2O metric tons	CO2 metric tons	CH4 metric tons	N2O metric tons	CO2 metric tons	CH4 metric tons	N2O metric tons	(a) Emission Factor/High Heat Value is from 40 CFR Part 98, Subpart C, Table C-1, "Default CO ₂ Emission Factors and High Heat Values for Various Types of Fuel."	(b) Emission Factor is from 40 CFR Part 98, Subpart C, Table C-2, "Default CH ₄ and N ₂ O Emission Factors for Various Types of Fuel."	(c) Natural gas was analyzed and averaged for each month. Average high heat value for the year was taken from the monthly "TA-3 Power Plant Totalizer Report" provided by Utilities and Infrastructure. Path: Envision:\AQC\Reports\Fuel Use\Avg Nat Gas BTU Values
TA-3-22-1	12591.9	0.237	0.024	15.49	0.001	0.000	12607.4	0.238	0.024			
TA-3-22-2	4128.8	0.078	0.008	0.00	0.000	0.000	4128.8	0.078	0.008			
TA-3-22-3	5545.5	0.105	0.010	25.36	0.001	0.000	5570.8	0.106	0.011			
Totals:	22266.2	0.420	0.042	40.85	0.002	0.000	22307.1	0.422	0.042			
			Plant Totals (metric tons):			22307.1						
			CO₂ Equivalent Total Emissions (metric tons):			22330.2						
(d) Fuel use values for natural gas and fuel oil are taken from the monthly "TA-3 Power Plant Totalizer Report".												
(e) Fiscal year begins on October 1st and ends on September 30th of the following year.												

**12 Month Rolling Emissions 2013 (Tons)
All Three Boilers Combined**

Pollutant	TSP	PM10	NOx	CO	VOC	SO ₂
Permit Limit (tons/yr)	8.4	8.2	60.2	41.3	5.6	7.9
12-Month Rolling Total						
January	1.621	1.619	12.338	8.507	1.169	0.142
February	1.598	1.596	12.165	8.388	1.152	0.140
March	1.586	1.584	12.070	8.322	1.143	0.139
April	1.591	1.589	12.110	8.350	1.147	0.140
May	1.591	1.589	12.107	8.348	1.147	0.140
June	1.585	1.583	12.066	8.319	1.143	0.139
July	1.582	1.580	12.041	8.302	1.141	0.139
August	1.577	1.575	11.998	8.273	1.137	0.139
September	1.570	1.568	11.947	8.238	1.132	0.138
October	1.587	1.585	12.080	8.329	1.144	0.140
November	1.615	1.613	12.293	8.476	1.164	0.142
December	1.629	1.627	12.396	8.547	1.174	0.143

Meets permit condition A1307.A, Monitoring Condition 2.

Monthly Emission Totals (Tons)

Pollutant	TSP	PM10	NOx	CO	VOC	SO ₂
January	0.235	0.233	1.763	1.214	0.166	0.033
February	0.189	0.189	1.441	0.994	0.137	0.015
March	0.165	0.165	1.256	0.866	0.119	0.013
April	0.141	0.141	1.077	0.743	0.102	0.011
May	0.104	0.104	0.794	0.547	0.075	0.008
June	0.064	0.064	0.487	0.336	0.046	0.005
July	0.064	0.064	0.492	0.339	0.047	0.005
August	0.051	0.051	0.389	0.269	0.037	0.004
September	0.069	0.069	0.527	0.364	0.050	0.005
October	0.135	0.135	1.032	0.712	0.098	0.011
November	0.185	0.185	1.410	0.973	0.134	0.015
December	0.226	0.226	1.728	1.191	0.164	0.018
Annual Totals	1.629	1.627	12.396	8.547	1.174	0.143

Data Reviewed By: _____

Monthly Emission Calculation (Natural Gas) 2013

Average Hourly Emissions Rates (pph) for each Emission Unit

(Meets condition A1307.A, monitoring condition 1, of Title V Permit P100-R1-M3)

	Unit TA-3-22-1 (Boiler 1) pph												Allowable Emissions ^(a)
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
NOx	4.66	4.06	0.00	0.00	1.70	1.35	1.32	6.58	1.58	2.74	3.91	4.65	10.2
SOx	0.05	0.04	0.00	0.00	0.02	0.01	0.01	0.07	0.02	0.03	0.04	0.05	1.1
PM	0.61	0.53	0.00	0.00	0.22	0.18	0.17	0.86	0.21	0.36	0.51	0.61	1.3
PM-10	0.61	0.53	0.00	0.00	0.22	0.18	0.17	0.86	0.21	0.36	0.51	0.61	1.3
PM-2.5	0.61	0.53	0.00	0.00	0.22	0.18	0.17	0.86	0.21	0.36	0.51	0.61	1.3
CO	3.21	2.80	0.00	0.00	1.17	0.93	0.91	4.54	1.09	1.89	2.69	3.21	7.0
VOC	0.44	0.38	0.00	0.00	0.16	0.13	0.13	0.62	0.15	0.26	0.37	0.44	1.0

	Unit TA-3-22-2 (Boiler 2) pph												Allowable Emissions ^(a)
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
NOx	0.00	4.20	3.43	2.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.2
SOx	0.00	0.04	0.04	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.1
PM	0.00	0.55	0.45	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.3
PM-10	0.00	0.55	0.45	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.3
PM-2.5	0.00	0.55	0.45	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.3
CO	0.00	2.89	2.36	1.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.0
VOC	0.00	0.40	0.33	0.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.0

	Unit TA-3-22-3 (Boiler 3) pph												Allowable Emissions ^(a)
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
NOx	2.88	3.83	3.03	2.96	2.31	0.00	1.53	1.30	1.35	3.01	3.77	3.47	10.2
SOx	0.03	0.04	0.03	0.03	0.02	0.00	0.02	0.01	0.01	0.03	0.04	0.04	1.1
PM	0.38	0.50	0.40	0.39	0.30	0.00	0.20	0.17	0.18	0.39	0.49	0.45	1.3
PM-10	0.38	0.50	0.40	0.39	0.30	0.00	0.20	0.17	0.18	0.39	0.49	0.45	1.3
PM-2.5	0.38	0.50	0.40	0.39	0.30	0.00	0.20	0.17	0.18	0.39	0.49	0.45	1.3
CO	1.99	2.64	2.09	2.04	1.60	0.00	1.06	0.89	0.93	2.07	2.60	2.39	7.0
VOC	0.27	0.36	0.29	0.28	0.22	0.00	0.15	0.12	0.13	0.29	0.36	0.33	1.0

(a) Allowable Emissions are from table A1302A of permit P100-R1-M3

NOTE: Condition A1307.A, Monitoring Condition 3 is calculated using an emission factor for NOx of 58 lbs/MMscf, and an average Heat Value of 1,020 MMBtu/ MMscf (Reference 40 CFR Part 98, Subpart C, Table C-1). Therefore the NOx emission rate when burning natural gas is a constant of 0.057 lbs/MMBtu .

Monthly Emission Calculation (Fuel Oil) 2013

Average Hourly Emissions Rates (pph) for each Emission Unit
(Meets condition A1307.A, monitoring condition 1, of Title V Permit P100-R1-M3)

	Unit TA-3-22-1 (Boiler 1)												Allowable Emissions ^(a) Oil	
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
NOx	4.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.3
SOx	3.86	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.6
PM	1.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.3
PM-10	1.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.0
PM-2.5	0.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.0
CO	2.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.5
VOC	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.3

	Unit TA-3-22-2 (Boiler 2)												Allowable Emissions ^(a) Oil	
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
NOx	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.3
SOx	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.6
PM	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.3
PM-10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.0
PM-2.5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.0
CO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.5
VOC	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.3

	Unit TA-3-22-3 (Boiler 3)												Allowable Emissions ^(a) Oil	
	Jan.	Feb.	Mar.	Apr.	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
NOx	3.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.3
SOx	2.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.6
PM	1.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	4.3
PM-10	0.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.0
PM-2.5	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.0
CO	1.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	6.5
VOC	0.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.3

Lb/Hr Emission Calculation = (Emission Factor (lb/1000 gal) x Amt Fuel Burned (gal)) / (1000) / (Hours Unit Operated) = lbs/hr

(a) Allowable Emissions are from table A1302A of permit P100-R1-M3

NOTE: Condition A1307.A, Monitoring Condition 3 is calculated using an emission factor for NOx of 8.64 lb/1000 gallons, and an average Heat Value of 138,000 MMBtu/gal (Reference 40 CFR Part 98, Subpart C, Table C-1). Therefore the NOx emission rate when burning oil is a constant of 0.063 lbs/MMBtu .

Emission Summary TA-3 Power Plant 2013

Pollutant Criteria	Emission Factor		Annual Emissions (Natural Gas + Fuel Oil) (tons)	Jan-June Emissions (Natural Gas + Fuel Oil) (tons)	July-Dec Emissions (Natural Gas + Fuel Oil) (tons)	Reference		Reference
	Natural Gas (lb/MMscf)	Fuel Oil ^f (lb/1000 gal.)				Gas	Oil	
NOx	58	8.64	12.396	6.818	5.578	(c)	(c)	(a) AP-42, 7/98, Section. 1.4, Natural Gas Combustion, Tables 1.4-1, 1.4-2
SOx	0.6	7.4	0.143	0.085	0.058	(a)(i)	(g)(i)	(b) Fuel usage obtained from Jerry Gonzales (FWO-UJ). Values are provided in a monthly data deliverable from KSL.
PM	7.6	3.3	1.629	0.898	0.731	(d)	(d)	(c) Average of source tests conducted on all 3 boilers September 2002 burning natural gas after FGR installed. Assumed FGR resulted in similar Nox reduction for oil.
PM-10	7.6	2.3	1.627	0.896	0.731	(d)	(d)	(d) All PM from natural gas is assumed <1u, so PM-10, PM-2.5 and total PM have equal EFs. AP-42, Natural Gas Combustion, Table 1.4-2. The PM emission factor for fuel oil is the sum of filterable and condensable PM.
PM-2.5	7.6	1.55	1.625	0.894	0.731	(d)	(d)	(e) AP-42, 1/95, Section. 1.4, Natural Gas Combustion, Table 1.4-2. Consistent with previous stack tests.
CO	40	5.0	8.547	4.700	3.847	(b)	(g)	(f) AP-42, 9/98, Section. 1.3, Fuel Oil Combustion, Table 1.3-1 with Errata, Table 1.3-3, and Table 1.3-6.
VOC	5.5	0.2	1.174	0.645	0.529	(b)	(i)	(g) Boilers>100 MMBtu/hr: SOx Emission Factor (SO ₂ {142S} + SO ₃ {5.7S}) = 147.7 * S (from AP-42, Table 1.3-1 w/Errata) (S = weight % sulfur in oil)(Sulfur content per analysis on oil in tanks in August 01', no new oil delivered in 02/03)
HAPsⁿ								
Arsenic	0.0002	0.00055	4.38E-05	2.45E-05	1.92E-05	(a)	(k)	(h) HAP emission factors for natural gas from AP-42, Tables 1.4-3 an 1.4-4, for fuel oil from AP-42 Tables 1.3-8 and 1.3-10.
Benzene	0.0021	-	4.48E-04	2.46E-04	2.02E-04	(c)	(k)	(i) AP-42, Table 1.4-2, 1.4-3, and 1.4-4, July 1998
Beryllium	0.000012	0.00041	3.38E-06	2.23E-06	1.15E-06	(c)	(k)	(j) Assume all SO ₃ is converted to sulfuric acid.
Cadmium	0.0011	0.00041	2.36E-04	1.30E-04	1.06E-04	(c)	(k)	(k) AP-42, tables 1.3-9 and 1.3-10, September 1998.
Chromium	0.0014	0.00041	3.00E-04	1.65E-04	1.35E-04	(c)	(k)	(l) EPCRA PAC Guidance Document, Table 2-3.
Cobalt	0.000084	-	1.79E-05	9.85E-06	8.08E-06	(c)	(k)	Reviewed By/Date:
Dichlorobenzene	0.0012	-	2.56E-04	1.41E-04	1.15E-04	(c)	(k)	
Formaldehyde	0.075	0.048	1.61E-02	8.89E-03	7.21E-03	(c)	(k)	
Hexane	1.8	-	3.84E-01	2.11E-01	1.73E-01	(c)	(k)	
Lead	0.0005	0.001233	1.09E-04	6.11E-05	4.81E-05	(c)	(k)	
Manganese	0.00038	0.000822	8.27E-05	4.62E-05	3.65E-05	(c)	(k)	
Mercury	0.00026	0.000411	5.63E-05	3.13E-05	2.50E-05	(i)(c)	(i)(k)	S(%)= 0.05
Napthalene	0.00061	-	1.30E-04	7.15E-05	5.87E-05	(c)	(k)	(m) HAP emission factors for natural gas from AP-42, Tables 1.4-3 an 1.4-4, for fuel oil from AP-42 Tables 1.3-8 and 1.3-10.
Nickel	0.0021	0.000411	4.49E-04	2.47E-04	2.02E-04	(c)	(k)	
POM	0.000088	0.0033	2.54E-05	1.69E-05	8.46E-06	(c)	(k)	
Selenium	0.000024	0.002055	9.23E-06	6.93E-06	2.31E-06	(c)	(k)	
Toluene	0.0034	-	7.26E-04	3.99E-04	3.27E-04	(c)	(k)	
TOTAL HAPS			4.03E-01	2.22E-01	1.82E-01			
EPCRA 313				lbs./year				
Lead	0.0005	0.00123	1.09E-04	0.218		(c)	(i)(k)	
Sulfuric Acid	0.60	0.285	1.29E-01	257.24		(e)(f)	(e)(h)	
Mercury	0.00026	0.00041	5.63E-05	0.113		(c)	(i)(k)	
PACs	8.69E-07	1.65E-05	2.18E-07	4.37E-04		(f)(l)	(f)(l)	
Benzo(g,h,i) perylene	1.20E-06	2.26E-06	2.61E-07	5.21E-04		(i)(k)(c)	(f)	
Zinc	-	0.00055	1.10E-06	2.19E-03			(k)	

ATTACHMENT B:
2013 Annual Emissions Inventory Submittal to NMED



To/MS: 2013 Emissions Inventory File
Thru/MS: Alison M. Dorries, ENV-DO, K491
From/MS: Steven L. Story, ENV-CP, J978
Phone/Fax: 5-2169
LAUR: 14-21662
Symbol: ENV-DO-14-0068
Date: **MAR 26 2014**

memorandum

Environmental Protection Division

Subject: 2013 Emissions Inventory Electronic Submittal

Los Alamos National Laboratory (LANL) submitted their 2013 Emissions Inventory Report to New Mexico Environmental Department (NMED) via online reporting tool, AEIR. This report is required by Title 20, Chapter 2, Part 73 of the New Mexico Administrative Code (20.2.73 NMAC), Notice of Intent and Emissions Inventory Requirements. The report was submitted on March 26, 2014, and meets New Mexico Environmental Department's deadline of April 1st.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169 or story@lanl.gov.

AMD:SLS:WW/lm

Cy: Carl A. Beard, PADOPS, (E-File)
Hai Shen, NA-00-LA, (E-File)
Michael T. Brandt, ADESH, (E-File)
Anthony R. Grieggs, ENV-CP, (E-File)
Steven L. Story, ENV-CP, J978, (E-File)
Walter Whetham, ENV-CP, J978
IRM-RMMSO, locatsteam@lanl.gov, (E-File)
ENV-CP Title V Emissions Report File
ENV-CP Correspondence File, K490
env-correspondence@lanl.gov (E-FILE)

ENCLOSURE 1

2013 Emissions Inventory Report

ENV-DO-14-0068

LAUR-13-22031

Electronic Submittal

Date: MAR 26 2014



Subject Item List

[Home](#) [Admin Tools](#) [About AEIR](#)
[Logout](#)

Facility Annual Emissions - Subject Item List

Agency ID: 856**Facility Name:** Los Alamos National Laboratory**Organization Name:** U.S. Department of Energy National Nuclear Security Administration**Submittal Status:** 2013 Submittal (In Process)**Subject Item/Equipment**

Type	ID	Designation	Description	Complete
<input type="radio"/> Federal Agency	856	2195FR4	Los Alamos National Laboratory	
<input checked="" type="radio"/> Asphalt Drum/Burner	116	TA-60-BDM	Asphalt Plant Dryer - Propane	<input checked="" type="checkbox"/>
<input type="radio"/> Beryllium Work	2	TA-35-213	Be Target Fabrication Facility - Machining TA-35-213	<input checked="" type="checkbox"/>
<input type="radio"/> Beryllium Work	3	TA-3-141	Be Test Facility - Machining TA-3-141	<input checked="" type="checkbox"/>
<input type="radio"/> Beryllium Work	6	TA-55-PF4 (a)	Plutonium Facility Beryllium machining, weld cutting / dressing and metallography	<input checked="" type="checkbox"/>
<input type="radio"/> Beryllium Work	41	TA-3-66	Sigma Facility-electroplating/metallography	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	11	TA-53-365-BHW-1	Boiler TA-53-365-BHW-1	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	12	TA-53-365-BHW-2	Boiler TA-53-365-BHW-2	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	24	TA-3-22-1	Power Plant Boiler (pph, Natural Gas)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	25	TA-3-22-2	Power Plant Boiler (pph, Natural Gas)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	26	TA-3-22-3	Power Plant Boiler (pph, Natural Gas)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	29	TA-55-6-BHW-1	Sellers Boiler TA-55-6-BHW-1	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	30	TA-55-6-BHW-2	Sellers Boiler TA-55-6-BHW-2	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	53	TA-16-1484-BS-2	Low NOx Boiler TA-16-1484-BS-2	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	90	B-1	Boiler-CMRR	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	104	B-2	Boiler-CMRR	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	105	B-3	Boiler-CMRR	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	106	B-4	Boiler-CMRR	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	107	B-5	Boiler-CMRR	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	134	TA-16-1484-BS-1	Low NOx Boiler TA-16-1484-BS-1	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	137	TA-3-22-2	Power Plant Boiler (pph, No. 2 fuel oil)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	138	TA-3-22-3	Power Plant Boiler (pph, No. 2 fuel oil)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	141	TA-3-22-1	Power Plant Boiler (pph, No. 2 fuel oil)	<input checked="" type="checkbox"/>
<input type="radio"/> Boiler	144	All Boilers	Natural Gas and No. 2 Fuel Boilers (cap)	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	56	TA-33-G-1	Kohler Diesel Generator TA-33-G-1	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	119	TA-33-G-2	Kohler Diesel Generator TA-33-G-2 (temp located to TA-39)	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	120	TA-33-G-3	Kohler Diesel Generator TA-33-G-3 (temp located to TA-39)	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	128	3 Generators	3 Cummins Diesel Powered Generators, CMRR-GEN-1, CMRR-GEN-2, and CMRR-GEN-3	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	135	TA-33-G-4	Caterpillar Diesel Generator TA-33-G-4	<input checked="" type="checkbox"/>
<input type="radio"/> Internal combustion engine	146	TA-33-G-1P	Cummins Portable Diesel Generator	<input checked="" type="checkbox"/>
<input type="radio"/> Parts Washer	21	TA-55-DG-1	Degreaser - Ultrasonic Cold Batch TA-55-4	<input checked="" type="checkbox"/>
<input type="radio"/> Research/Testing	7	LANL-FW-CHEM	R & D Activities - Labwide (031)	<input checked="" type="checkbox"/>

<input type="checkbox"/>	Shredder	89	TA-52-11	Data Disintegrator/Industrial Shredder	<input checked="" type="checkbox"/>
<input type="checkbox"/>	Turbine	112	TA-3-22-CT-1	Combustion Turbine	<input checked="" type="checkbox"/>

Add an unpermitted source for EPA GHG calculations

- Detail
- Emissions
- Print
- Export
- Total Emissions
- Review for Submittal

Submittal Comments

2000 character maximum

Save Comments

File Attachments

Attach File to Submittal

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 116

Designation: TA-60-BDM

Description: Asphalt Plant Dryer - Propane

Type: Asphalt Drum/Burner

SCC: Industrial Processes, Mineral Products, Asphalt Concrete, Drum Mix Plant: Rotary Drum Dryer / Mixer, Natural Gas - Fired

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Propane	
Input Materials Processed:	Asphalt (INPUT)	
Materials Consumed:	13569.0	gal/y
Fuel Heating Value:	91547.0	BTU/gal
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	5
Operating Time in Weeks per Year:	26
Operating Time in Hours per Year:	1040
Percent of Operation During Winter:	10
Percent of Operation During Spring:	30
Percent of Operation During Summer:	30
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.533	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.015	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.001	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.001	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.009	tons/y	Manufacturer Specification
Sulfur Dioxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.001	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 2

Designation: TA-35-213

Description: Be Target Fabrication Facility -
Machining TA-35-213

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	5
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Estimate
Particulate Matter (total suspended):	0.0	tons/y	Estimate

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 3

Designation: TA-3-141

Description: Be Test Facility - Machining
TA-3-141

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Sample testing
Particulate Matter (total suspended):	0.0	tons/y	Sample testing

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 6

Designation: TA-55-PF4 (a)

Plutonium Facility Beryllium

Description: machining, weld cutting /
dressing and metallography

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Machining
Operations, Specify Material**

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	5
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 41

Designation: TA-3-66

Description: Sigma Facility-
electroplating/metallography

Type: Beryllium Work

SCC: Industrial Processes, Fabricated
Metal Products, Abrasive
Cleaning of Metal Parts, Polishing

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Metal (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	8
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Beryllium:	0.0	tons/y	Design calculation

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 11

Designation: TA-53-365-BHW-1

Description: Boiler TA-53-365-BHW-1

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	11.42	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	20
Percent of Operation During Summer:	0
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.479	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.01	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.571	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.031	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 12

Designation: TA-53-365-BHW-2

Description: Boiler TA-53-365-BHW-2

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	11.42	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	20
Percent of Operation During Summer:	0
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.479	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.01	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.571	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.043	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.031	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 24

Designation: TA-3-22-1

Description: Power Plant Boiler (pph, Natural Gas)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	251.7	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	5.03	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.01	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.02	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	7.3	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.96	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.96	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.96	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.08	tons/y	EPA emission factors (e.g., AP-42)

Toluene; (Methyl benzene):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.69	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 25

Designation: TA-3-22-2

Description: Power Plant Boiler (pph, Natural Gas)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	76.0	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	1.52	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.003	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.07	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	2.2	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.29	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.29	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.29	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.02	tons/y	EPA emission factors (e.g., AP-42)

Volatile Organic Compounds (VOC): 0.21 tons/y EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 26

Designation: TA-3-22-3

Description: Power Plant Boiler (pph, Natural Gas)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	99.2	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	1.98	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.09	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	2.88	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.38	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.38	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.38	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.03	tons/y	EPA emission factors (e.g., AP-42)

Volatile Organic Compounds (VOC): 0.27 tons/y EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 29

Designation: TA-55-6-BHW-1

Description: Sellers Boiler TA-55-6-BHW-1

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	15.038	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	35
Percent of Operation During Spring:	20
Percent of Operation During Summer:	10
Percent of Operation During Fall:	35

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.287	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.014	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	1.04	tons/y	Actual stack test
Particulate Matter (10 microns or less):	0.107	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.107	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.107	tons/y	Manufacturer Specification
Sulfur Dioxide:	0.005	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.045	tons/y	Manufacturer Specification

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 30

Designation: TA-55-6-BHW-2

Description: Sellers Boiler TA-55-6-BHW-2

Type: Boiler

SCC: External Combustion Boilers,
Electric Generation, Natural Gas,
Boilers < 100 Million Btu/hr
except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	6.168	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	15
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	33
Operating Time in Hours per Year:	3465
Percent of Operation During Winter:	40
Percent of Operation During Spring:	10
Percent of Operation During Summer:	10
Percent of Operation During Fall:	40

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.118	tons/y	Manufacturer Specification
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.006	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	Manufacturer Specification
Nitrogen Dioxide:	0.426	tons/y	Actual stack test
Particulate Matter (10 microns or less):	0.044	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.044	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.044	tons/y	Manufacturer Specification
Sulfur Dioxide:	0.002	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.018	tons/y	Manufacturer Specification

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 53

Designation: TA-16-1484-BS-2

Description: Low NOx Boiler TA-16-1484-BS-2

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	10.19	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Ash of Fuel:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.189	tons/y	Design calculation
Lead:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.189	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.039	tons/y	Design calculation
Particulate Matter (2.5 microns or less):	0.039	tons/y	Design calculation
Particulate Matter (total suspended):	0.039	tons/y	Design calculation
Sulfur Dioxide:	0.003	tons/y	Design calculation
Volatile Organic Compounds (VOC):	0.028	tons/y	Design calculation

Subject Item Comments

Print Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 90

Designation: B-1

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	1.43	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.027	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.021	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.018	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 104

Designation: B-2

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	1.43	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.027	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.021	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.018	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 105

Designation: B-3

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	1.43	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.027	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.021	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.018	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 106

Designation: B-4

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF/y
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit has not been built.

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 107

Designation: B-5

Description: Boiler-CMRR

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF/y
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This unit has not been built.

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 134

Designation: TA-16-1484-BS-1

Description: Low NOx Boiler TA-16-1484-BS-1

Type: Boiler

SCC: External Combustion Boilers,
Commercial/Institutional,
Natural Gas, < 10 Million Btu/hr

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	10.19	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.189	tons/y	Design calculation
Lead:	0.0	tons/y	Design calculation
Nitrogen Dioxide:	0.189	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.039	tons/y	Design calculation
Particulate Matter (2.5 microns or less):	0.039	tons/y	Design calculation
Particulate Matter (total suspended):	0.039	tons/y	Design calculation
Sulfur Dioxide:	0.003	tons/y	Design calculation
Volatile Organic Compounds (VOC):	0.028	tons/y	Design calculation

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 137

Designation: TA-3-22-2

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	0.0	g/yr
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.05	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 138

Designation: TA-3-22-3

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Distillate Oil, Grades 1 and 2 Oil

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	2485.0	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.05	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.006	tons/y	EPA emission factors (e.g., AP-42)
Formaldehyde:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Hexane:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.011	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.003	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.009	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 141

Designation: TA-3-22-1

Description: Power Plant Boiler (pph, No. 2 fuel oil)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	1517.0	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.05	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	30
Percent of Operation During Spring:	20
Percent of Operation During Summer:	20
Percent of Operation During Fall:	30

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.007	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.002	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.003	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.006	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 144

Designation: All Boilers

Description: Natural Gas and No. 2 Fuel Boilers (cap)

Type: Boiler

SCC: External Combustion Boilers, Electric Generation, Natural Gas, Boilers > 100 Million Btu/hr except Tangential

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	0.0	MM SCF/y
Fuel Heating Value:	0.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.0	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	0.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This Facility ID represents the total from the power plant boilers for both natural gas and fuel oil. However, these emissions are already captured with Facility IDs 24, 25, and 26 for natural gas and Facility IDs 137, 138, and 141 for fuel oil. In order to avoid counting the emissions twice, NMED has asked us to enter zeros for this Facility ID.

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 56

Designation: TA-33-G-1

Description: Kohler Diesel Generator
TA-33-G-1

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Electric Generation, Distillate Oil
(Diesel), Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	2930.4	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	5
Operating Time in Days per Week:	4
Operating Time in Weeks per Year:	16
Operating Time in Hours per Year:	350
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.348	tons/y	Design calculation
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.428	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.014	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.014	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.014	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.063	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.008	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 119

Designation: TA-33-G-2

Kohler Diesel Generator

Description: TA-33-G-2 (temp located to TA-39)

Type: Internal combustion engine

SCC: Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel), Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	41.7	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	2
Operating Time in Days per Week:	2
Operating Time in Weeks per Year:	10
Operating Time in Hours per Year:	25
Percent of Operation During Winter:	50
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	50

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.002	tons/y	Design calculation
Nitrogen Dioxide:	0.01	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.001	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 120

Designation: TA-33-G-3

Kohler Diesel Generator

Description: TA-33-G-3 (temp located to TA-39)

Type: Internal combustion engine

SCC: Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel), Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	47.1	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	2
Operating Time in Days per Week:	2
Operating Time in Weeks per Year:	10
Operating Time in Hours per Year:	30
Percent of Operation During Winter:	50
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	50

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.002	tons/y	Design calculation
Nitrogen Dioxide:	0.012	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.001	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.001	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.001	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Thursday, March 20, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 128

Designation: 3 Generators

3 Cummins Diesel Powered

Description: Generators, CMRR-GEN-1, CMRR-GEN-2, and CMRR-GEN-3

Type: Internal combustion engine

SCC: Internal Combustion Engines, Industrial, Distillate Oil (Diesel), Reciprocating: Cogeneration

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	9614.1	gal

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.487	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	2.227	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.07	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.07	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.07	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.038	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.07	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Print

Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 135

Designation: TA-33-G-4

Description: Caterpillar Diesel Generator
TA-33-G-4

Type: Internal combustion engine

SCC: Internal Combustion Engines,
Electric Generation, Distillate Oil
(Diesel), Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Input Materials Processed:	Diesel (INPUT)	
Materials Consumed:	173.8	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.01	percent
Percent Carbon Content:	83.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	2
Operating Time in Days per Week:	2
Operating Time in Weeks per Year:	10
Operating Time in Hours per Year:	15
Percent of Operation During Winter:	50
Percent of Operation During Spring:	50
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.011	tons/y	Design calculation
Nitrogen Dioxide:	0.052	tons/y	Design calculation
Particulate Matter (10 microns or less):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.004	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.004	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.004	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 146

Designation: TA-33-G-1P

Description: Cummins Portable Diesel Generator

Type: Internal combustion engine

SCC: Internal Combustion Engines, Electric Generation, Distillate Oil (Diesel), Reciprocating

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Diesel	
Materials Consumed:	0.0	gal/y
Fuel Heating Value:	138.0	MM BTU/M gal
Percent Sulfur of Fuel:	0.001	percent

Operating Detail

	Value
Operating Time in Hours per Day:	0
Operating Time in Days per Week:	0
Operating Time in Weeks per Year:	0
Operating Time in Hours per Year:	0
Percent of Operation During Winter:	0
Percent of Operation During Spring:	0
Percent of Operation During Summer:	0
Percent of Operation During Fall:	0

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.0	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.0	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

This generator was permitted to operate at this location in December 2013 and it did not operate in 2013.

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 21

Designation: TA-55-DG-1

Description: Degreaser - Ultrasonic Cold
Batch TA-55-4

Type: Parts Washer

SCC: Petroleum and Solvent
Evaporation, Organic Solvent
Evaporation, Degreasing,
Trichloroethylene: General
Degreasing Units

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Solvent (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	4
Operating Time in Days per Week:	1
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	208
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
TCE; (Trichloroethylene); (Trichloroethene):	0.008	tons/y	Material balance

Subject Item Comments

[Print](#) [Close](#)

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 7

Designation: LANL-FW-CHEM

Description: R & D Activities - Labwide (031)

Type: Research/Testing

SCC: Industrial Processes,
Photographic Equipment/Health
Care/Laboratories, Laboratories,
Bench Scale Reagents: Research

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Operating Detail

	Value
Operating Time in Hours per Day:	24
Operating Time in Days per Week:	7
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	8760
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Acetaldehyde; (Ethyl aldehyde):	0.0	tons/y	Material balance
Acetonitrile; (Methyl cyanide):	0.0	tons/y	Material balance
Acetophenone:	0.0	tons/y	Material balance
Acrylamide:	0.0	tons/y	Material balance
Acrylic acid:	0.0	tons/y	Material balance
Acrylonitrile:	0.0	tons/y	Material balance
Ammonia:	0.0	tons/y	Material balance
Aniline:	0.0	tons/y	Material balance
Antimony:	0.0	tons/y	Material balance
Antimony compounds:	0.0	tons/y	Material balance
Arsenic Compounds:	0.0	tons/y	Material balance
Benzene:	0.0	tons/y	Material balance
Benzyl Chloride:	0.0	tons/y	Material balance
Biphenyl:	0.0	tons/y	Material balance
Bromoform; (Tribromomethane):	0.0	tons/y	Material balance
Butadiene(1,3-):	0.0	tons/y	Material balance
Cadmium:	0.0	tons/y	Material balance
Cadmium compounds:	0.0	tons/y	Material balance
Carbon Disulfide:	0.0	tons/y	Material balance
Carbon tetrachloride; (Tetrachloromethane):	0.0	tons/y	Material balance
Carbonyl sulfide:	0.0	tons/y	Material balance

Catechol (Pyrocatechol):	0.0	tons/y	Material balance
Chlorine:	0.0	tons/y	Material balance
Chloroacetic Acid:	0.0	tons/y	Material balance
Chlorobenzene(Phenyl Chloride):	0.0	tons/y	Material balance
Chloroform; (Trichloromethane):	0.0	tons/y	Material balance
Chromium:	0.0	tons/y	Material balance
Cobalt Compounds:	0.0	tons/y	Material balance
Cresol(m-); (Methylphenol, 3-):	0.0	tons/y	Material balance
Cumene:	0.0	tons/y	Material balance
Cyanide compounds:	0.0	tons/y	Material balance
Dibutylphthalate; (Di-n-butyl phthalate):	0.0	tons/y	Material balance
Diethanolamine:	0.0	tons/y	Material balance
Dimethyl Sulfate:	0.0	tons/y	Material balance
Dimethyl formamide:	0.0	tons/y	Material balance
Dimethylhydrazine(1,1-):	0.0	tons/y	Material balance
Dioxane(1,4-) (1,4-Diethyleneoxide):	0.0	tons/y	Material balance
Epichlorohydrin; (1-Chloro-2,3-epoxypropane):	0.0	tons/y	Material balance
Epoxybutane(1,2-) (1,2-Butylene oxide):	0.0	tons/y	Material balance
Ethyl Acrylate:	0.0	tons/y	Material balance
Ethyl chloride; (Chloroethane):	0.0	tons/y	Material balance
Ethylene Glycol:	0.0	tons/y	Material balance
Ethylene dibromide; (EDB); (1.2-Dibromoethane):	0.0	tons/y	Material balance
Formaldehyde:	0.0	tons/y	Material balance
Glycol Ethers:	0.0	tons/y	Material balance
Hexachlorocyclopentadiene:	0.0	tons/y	Material balance
Hexamethylphosphoramide:	0.0	tons/y	Material balance
Hexane:	0.0	tons/y	Material balance
Hydrazine:	0.0	tons/y	Material balance
Hydrochloric acid (HCl):	0.83	tons/y	Material balance
Hydrofluoric Acid; (Hydrogen fluoride):	0.0	tons/y	Material balance
Hydroquinone:	0.0	tons/y	Material balance
Iodomethane (Methyl iodide):	0.0	tons/y	Material balance
Lead Compounds:	0.0	tons/y	Material balance
Manganese:	0.0	tons/y	Material balance
Manganese compounds:	0.0	tons/y	Material balance
Mercury compounds:	0.0	tons/y	Material balance
Methanol; (Methyl alcohol):	0.0	tons/y	Material balance
Methyl Ethyl Ketone; (MEK); (2-Butanone):	0.0	tons/y	Material balance
Methyl Methacrylate:	0.0	tons/y	Material balance
Methyl bromide; (Bromomethane):	0.0	tons/y	Material balance
Methyl chloride; (Chloromethane):	0.0	tons/y	Material balance
Methyl isobutyl ketone; (Hexone); (4-Methyl-2-pentanone):	0.0	tons/y	Material balance
Methyl tert butyl ether:	0.0	tons/y	Material balance
Methylene chloride; (Dichloromethane):	0.0	tons/y	Material balance
Methylenebiphenyl isocyanate; (MDI); (Diphenylmethane diisocyanate):	0.0	tons/y	Material balance
Naphthalene:	0.0	tons/y	Material balance
Nickel:	0.0	tons/y	Material balance
Nickel compounds:	0.0	tons/y	Material balance
Nitrobenzene; (nitro-Benzene):	0.0	tons/y	Material balance
Nitrophenol(4-); (p-Nitrophenol):	0.0	tons/y	Material balance
PCE; (Perchloroethylene); (Tetrachloroethylene); (Tetrachloroethene):	0.0	tons/y	Material balance

Phenol:	0.0	tons/y	Material balance
Phenylenediamine(p-); (Phenylenediamine):	0.0	tons/y	Material balance
Phosphine:	0.0	tons/y	Material balance
Phosphorus:	0.0	tons/y	Material balance
Phthalic anhydride:	0.0	tons/y	Material balance
Polycyclic Organic Matter:	0.0	tons/y	Material balance
Propylene oxide:	0.0	tons/y	Material balance
Selenium:	0.0	tons/y	Material balance
Selenium compounds:	0.0	tons/y	Material balance
Styrene:	0.0	tons/y	Material balance
TCE; (Trichloroethylene); (Trichloroethene):	0.0	tons/y	Material balance
Tetrachloroethane(1,1,2,2-):	0.0	tons/y	Material balance
Titanium tetrachloride:	0.0	tons/y	Material balance
Toluene diisocyanate(2,4-):	0.0	tons/y	Material balance
Toluene; (Methyl benzene):	0.0	tons/y	Material balance
Total HAP:	3.49	tons/y	Material balance
Trichloroethane(1,1,1-) (Methyl Chloroform):	0.0	tons/y	Material balance
Trichloroethane(1,1,2-):	0.0	tons/y	Material balance
Triethylamine:	0.0	tons/y	Material balance
Trimethylpentane(2,2,4-):	0.0	tons/y	Material balance
Urethane; (Ethyl carbamate):	0.0	tons/y	Material balance
Vinyl acetate; (Vinyl acetate monomer):	0.0	tons/y	Material balance
Volatile Organic Compounds (VOC):	9.59	tons/y	Material balance
Xylene(o-); (1,2-Dimethylbenzene); (ortho-Xylene):	0.0	tons/y	Material balance
Xylenes (total); (Xylol):	0.0	tons/y	Material balance
bis(2-ethylhexyl) phthalate; (Di-2-ethylhexyl phthalate); (DEHP):	0.0	tons/y	Material balance

Subject Item Comments

Print Close

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 89

Designation: TA-52-11

Description: Data Disintegrator/industrial
Shredder

Type: Shredder

SCC: Industrial Processes, Pulp and
Paper and Wood Products,
Miscellaneous Paper Products,
Other Not Classified

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

Input Materials Processed: Paper (INPUT)

Operating Detail

	Value
Operating Time in Hours per Day:	7
Operating Time in Days per Week:	5
Operating Time in Weeks per Year:	52
Operating Time in Hours per Year:	1820
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Particulate Matter (10 microns or less):	0.07	tons/y	Manufacturer Specification
Particulate Matter (2.5 microns or less):	0.04	tons/y	Manufacturer Specification
Particulate Matter (total suspended):	0.07	tons/y	Manufacturer Specification

Subject Item Comments

Facility Annual Emissions - Subject Item Submittal Review

Wednesday, March 19, 2014

Agency ID: 856

Facility Name: Los Alamos National Laboratory

Organization Name: U.S. Department of Energy National Nuclear Security Administration

Submittal Status: 2013 Submittal (In Process)

Facility ID: 112

Designation: TA-3-22-CT-1

Description: Combustion Turbine

Type: Turbine

SCC: Internal Combustion Engines,
Electric Generation, Natural Gas,
Turbine

GHG Reporting: Reports GHG to EPA

Supplemental Parameters

	Amount	Unit of Measure
Fuel Type:	Natural Gas	
Input Materials Processed:	Natural Gas (INPUT)	
Materials Consumed:	94.8	MM SCF/y
Fuel Heating Value:	1021.0	MM BTU/MM SCF
Percent Sulfur of Fuel:	0.001	percent
Percent Ash of Fuel:	0.0	percent
Percent Carbon Content:	65.0	percent

Operating Detail

	Value
Operating Time in Hours per Day:	7
Operating Time in Days per Week:	4
Operating Time in Weeks per Year:	12
Operating Time in Hours per Year:	500
Percent of Operation During Winter:	25
Percent of Operation During Spring:	25
Percent of Operation During Summer:	25
Percent of Operation During Fall:	25

Actual Pollutants

Pollutant	Amount	Unit of Measure	Calculation Method
Carbon Monoxide:	0.5	tons/y	EPA emission factors (e.g., AP-42)
Lead:	0.0	tons/y	EPA emission factors (e.g., AP-42)
Nitrogen Dioxide:	2.39	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (10 microns or less):	0.32	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (2.5 microns or less):	0.32	tons/y	EPA emission factors (e.g., AP-42)
Particulate Matter (total suspended):	0.32	tons/y	EPA emission factors (e.g., AP-42)
Sulfur Dioxide:	0.17	tons/y	EPA emission factors (e.g., AP-42)
Volatile Organic Compounds (VOC):	0.1	tons/y	EPA emission factors (e.g., AP-42)

Subject Item Comments

ATTACHMENT C:

2013 Semi-annual Emissions Reports

Submitted Under Title V Operating Permit Requirements



Environment Safety & Health

PO Box 1663, MS K491
Los Alamos, New Mexico 87545
(505)667-4218/Fax (505) 665-3811

Date: **SEP 17 2013**
Symbol: ADESH-13-046
LAUR: 13-26818

Compliance Reporting Manager
Compliance & Enforcement Section
New Mexico Environment Department
Air Quality Bureau
1301 Siler Road, Building B
Santa Fe, New Mexico 87507-3113

Dear Compliance Reporting Manager:

**SUBJECT: TITLE V SEMI-ANNUAL EMISSIONS REPORT FOR PERMIT P100-R1-M3
JANUARY 1, 2013 – JUNE 30, 2013 AI NO. 856 – LOS ALAMOS NATIONAL
LABORATORY (LANL)**

Enclosed is Los Alamos National Laboratory's (LANL) Semi-Annual Emissions report for the period January 1, 2013 through June 30, 2013. This report is required by permit condition A109 B and is submitted within 90 days from the end of the reporting period as required by that condition.

The semi-annual emissions report includes actual emissions from permitted sources included in LANL's Operating Permit. Emissions are also reported from insignificant boiler and generator sources. These sources are included to demonstrate that LANL has not exceeded Prevention of Significant Deterioration (PSD) applicability thresholds. In this report, actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169 or story@lanl.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Michael T. Brandt'.

Michael T. Brandt, DrPH, CIH
Associate Director
Environment, Safety & Health

Title V Semi-Annual Emission Report for Permit P100-R1-M3

January 1, 2013 – June 30, 2013

Identifying Information

Source Name: Los Alamos National Laboratory County: Los Alamos

Source Address:

City: Los Alamos State: NM Zip Code: 87545

Responsible Official: Michael T. Brandt Ph No. (505) 667-4218 Fax No. (505) 665-3811

Technical Contact: Steven L. Story Ph No. (505) 665-2169 Fax No. (505) 665-8858

Principal Company Product or Business: National Security and Nuclear Weapons Research Primary SIC Code: 8733

Permit No. P100-R1-M3 {IDEA/Tempo ID No. 856} Permit Issued Date: April 26, 2013

Certification of Truth, Accuracy, and Completeness

I, Michael T. Brandt certify that, based on information and belief formed after reasonable inquiry, the statements and information in the attached semi-annual emission report are true, accurate, and complete.

Signature



Date:

9/17/13

Title: Associate Director Environmental, Safety, and Health

ENCLOSURE 1

**Title V Semi-Annual Emissions Report for Permit
P100-R1-M3
January 1, 2013 – June 30, 2013**

ADESH-13-046

LAUR-13-26818

Date: SEP 17 2013

**Title V Semi-Annual Emissions Report for Permit P100-R1-M3
January 1, 2013 - June 30, 2013**

Emission Reporting Requirements

A109 Facility: Reporting Schedules

- A. A Semi-Annual Report of monitoring activities is due within 45 days following the end of every 6-month reporting period. The six month reporting periods start on January 1st and July 1st of each year.

- B. A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

A700 Beryllium Activities

A702 Emission Limits - Beryllium Activities

Source	Beryllium Particulate Matter	Aluminum Particulate Matter
Sigma Facility TA-3-66	10 gm ¹ /24 hr	N/A
Beryllium Technology Facility TA-3-141	0.35 gm/24 hr 3.5 gm/yr	N/A
Target Fabrication Facility TA-35-213	1.8 x 10 ⁻⁰⁴ gm/hr 0.36 gm/yr	N/A
Plutonium Facility TA-55-PF-4 Machining Operation	0.12 gm/24 hr 2.99 gm/yr	0.12 gm/24 hr 2.99 gm/y
Plutonium Facility TA-55-PF-4 Foundry Operation	3.49 x 10 ⁻⁰³ gm/24 hr 8.73 x 10 ⁻⁰⁴ gm/yr	3.49 x 10 ⁰⁵ gm/24 hr 8.73 x 10 ⁰⁴ gm/y

Reporting Requirement

A707 D The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO2, VOC, TSP, PM10, and PM2.5 shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A800 External Combustion

A802 Emission Limits - External Combustion

Unit No.	NO _x tpy		CO tpy		VOC tpy		SO ₂ tpy		TSP tpy		PM ₁₀ tpy		PM _{2.5} tpy		
Combined annual emissions for all units listed in Table 800 A²		80.0		80.0		50.0		50.0		50.0		50.0			
Unit No.	NO _x pph	NO _x tpy	CO pph	CO tpy	VOC pph	VOC tpy	SO ₂ pph	SO ₂ tpy	TSP pph	TSP tpy	PM ₁₀ pph	PM ₁₀ tpy	PM _{2.5} pph	PM _{2.5} tpy	
CMRR-BHW-1 (GAS)	0.7	2.9	1.1	4.8	-- ²	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4	
CMRR-BHW-1 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2		
CMRR-BHW-2 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4	
CMRR-BHW-2 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2		
CMRR-BHW-3 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4	
CMRR-BHW-3 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2		
CMRR-BHW-4 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4	
CMRR-BHW-4 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2		
All boilers - Oil ⁴	N/A	2.9	N/A	6.9	--	--	N/A	10.4	N/A	0.5	N/A	0.3	N/A	0.3	
Combined Total³		14.5		20.1		--		11.6		2.1		1.9		1.9	

Reporting Requirement

A807 B The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A800 External Combustion - continued

CMRR-BHW-4 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000			2.9
SO ₂	0.000			0.3
TSP	0.000			0.4
PM-10	0.000			0.4
PM-2.5	0.000			0.4
CO	0.000			4.8
VOCs	0.000			No Source Limit
HAPs	0.000			No Source Limit

Note: The CMRR-BHW-4 boiler has not been installed.

CMRR Boilers Totals (Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.002			2.9
SO ₂	0.001			10.4
TSP	0.000			0.5
PM-10	0.000			0.3
PM-2.5	0.000			0.3
CO	0.001			0.9
VOCs	0.001			No Source Limit
HAPs	0.000			No Source Limit

Note: The CMRR boilers operated on fuel oil for a total of 14 hours during the first 6 months of 2013.

CMRR Boilers Totals (Gas and Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.039			14.5
SO ₂	0.002			11.6
TSP	0.006			2.1
PM-10	0.006			1.9
PM-2.5	0.006			1.9
CO	0.048			20.1
VOCs	0.033			No Source Limit
HAPs	0.002			No Source Limit

A1000 Degreasers

A1002 Emission Limits - Degreasers

Unit No.	VOC/HAPs tpy
TA-55-DG-1	--

1 The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A1007 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO2, VOC, TSP, PM10, and PM2.5 shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1002 A) (tons per year)
VOCs	0.002			Source limits refer to facility-wide limits.
HAPs	0.002			

A1100 Internal Combustion- continued

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.000			0.21
SO ₂	0.000			Not Required
TSP	0.000			Not Required
PM ₁₀	0.000			Not Required
CO	0.000			0.1
VOC	0.000			Not Required
HAPs	0.00E+00			No Source Limit

Note: The TA-33-G-3 generator only operated for a 0.2 hours during the first 6 months of 2013.

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.052			2.33
SO ₂	0.004			0.16
TSP	0.004			Not Required
PM ₁₀	0.004			Not Required
CO	0.011			1.4
VOC	0.004			0.2
HAPs	1.67E-05			No Source Limit

Note: The TA-33-G-4 generator only operated for 11 hours during the first 6 months of 2013.

Stationary Standby Generators	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	1.51			No Source Specific Emission Limits for Standby Generators
SO ₂	0.07			
TSP	0.08			
PM ₁₀	0.08			
CO	0.34			
VOC	0.08			
HAPs	0.001			

Note: Standby Generators are insignificant sources.

Generator CMRR-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.238			No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.004			
TSP	0.007			
PM ₁₀	0.007			
CO	0.052			
VOC	0.007			
HAPs	4.32E-05			

Continued on the next page.

A1200 Data Disintegrator

A1202 Emission Limits - Data Disintegrator

Unit No.	TSP pph	TSP tpy	PM10 pph	PM10 tpy
TA-52-11	2.3	9.9	2.3	9.9

Reporting Requirement

A1207 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO2, VOC, TSP, PM10, and PM2.5 shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Data Disintegrator TA-52-11	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1202 A) (tons per year)
TSP	0.03			9.9
PM10	0.03			9.9

A1300 TA-3 Power Plant

Comments:

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	0.93			59.4
SOx	0.06			4.2
TSP	0.12			4.8
PM ₁₀	0.12			4.8
PM _{2.5}	0.12			4.8
CO	0.19			72.3
VOC	0.04			1.5
HAPs	0.03			No Source Limit

A102 Facility Wide Emission Limits

Table 102.A: Total Potential Criteria Pollutant Emissions from Entire Facility

Pollutant	Emissions (tons per year)
Nitrogen Oxides (NO _x)	245.0
Carbon Monoxide (CO)	225.0
Volatile Organic Compounds (VOC)	200.0
Sulfur Dioxide (SO ₂)	150.0
Total Particulate Matter (TSP)	120.0
Particulate Matter less than 10 microns (PM ₁₀)	120.0
Particulate Matter less than 2.5 microns (PM _{2.5})	120.0

Table 102.B: Total Potential HAPs that exceed 1.0 tons per year

Pollutant	Emissions (tons per year)
Individual HAP	8.0
Total HAPs	24.0

Reporting Requirement

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	2012 Annual Emissions (tons)	Facility Wide Permit Limits (Condition A102) (tons per year)
Nitrogen Oxides	24.4			245
Carbon Monoxide	17.2			225
Volatile Organic Carbons	6.9			200
Sulfur Dioxide	0.3			150
Total Particulate Matter	2.3			120
Particulate Matter less than 10 microns	2.3			120
Particulate Matter less than 2.5 microns	1.0			120
Hazardous Air Pollutants	2.3			24



Environment Safety & Health

PO Box 1663, MS K491
Los Alamos, New Mexico 87545
(505)667-4218/Fax (505) 665-3811

Date: **MAR 26 2014**
Symbol: ADESH-14-017
LAUR: 14-21663

Compliance Reporting Manager
Compliance & Enforcement Section
New Mexico Environment Department
Air Quality Bureau
1301 Siler Road, Building B
Santa Fe, New Mexico 87507-3113

Dear Compliance Reporting Manager:

**Subject: Title V Semi-Annual Emissions Report for Permit P100-R1-M3,
July 1, 2013 – December 31, 2013 AI No. 856 – Los Alamos National (LANL)**

Enclosed is Los Alamos National Laboratory's (LANL) Semi-Annual Emissions report for the period July 1, 2013 through December 31, 2013. This report is required by permit condition A109 B and is submitted within 90 days from the end of the reporting period as required by that condition.

The semi-annual emissions report includes actual emissions from permitted sources included in LANL's Operating Permit. Emissions are also reported from insignificant boiler and generator sources. These sources are included to demonstrate that LANL has not exceeded Prevention of Significant Deterioration (PSD) applicability thresholds. In this report, actual emissions are listed along with the emission limits for ease in comparing and verifying compliance. No annual emission limits were exceeded during this reporting period.

Should you have any questions or comments regarding the information provided in this report, please contact Steve Story at (505) 665-2169 or story@lanl.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Michael T. Brandt'.

Michael T. Brandt, DrPH, CIH
Associate Director
Environment, Safety & Health

MTB:SLS:WW/lm

Enclosure: 1. Title V Semi-Annual Emissions Report for Permit P100-R1-M3
July 1, 2013 – December 31, 2013

Cy: Hai Shen, NA-00-LA, (E-File)
Carl A. Beard, PADOPS, (E-File)
Michael T. Brandt, ADESH, (E-File)
Alison M. Dorries, ENV-DO, (E-File)
Steve L. Story, ENV-CP, (E-File)
Walter Whetham, ENV-CP, (E-File)
Cynthia Blackwell, LC-LESH, (E-File)
LASOmailbox@nnsa.doe.gov, (E-File)
locatsteam@lanl.gov, (E-File)
ENV-CP Title V Emissions Report File
ENV-CP Correspondence File, K490

Title V Semi-Annual Emission Report for Permit P100-R1-M3

July 1, 2013 – December 31, 2013

Identifying Information

Source Name: Los Alamos National Laboratory County: Los Alamos

Source Address:

City: Los Alamos State: NM Zip Code: 87545

Responsible Official: Michael T. Brandt Ph No. (505) 667-4218 Fax No. (505) 665-3811

Technical Contact: Steven L. Story Ph No. (505) 665-2169 Fax No. (505) 665-8858

Principal Company Product or Business: National Security and Nuclear Weapons Research Primary SIC Code: 8733

Permit No. P100-R1-M3 {IDEA/Tempo ID No. 856} Permit Issued Date: April 26, 2013

Certification of Truth, Accuracy, and Completeness

I, Michael T. Brandt certify that, based on information and belief formed after reasonable inquiry, the statements and information in the attached semi-annual emission report are true, accurate, and complete.

Signature



Date:

3/26/14

Title: Associate Director Environmental, Safety, and Health

ENCLOSURE 1

**Title V Semi-Annual Emissions Report for Permit
P100-R1-M3
July 1, 2013 – December 31, 2013**

ADESH-14-017

LAUR-14-21663

Date: MAR 26 2014

**Title V Semi-Annual Emissions Report for Permit P100-R1-M3
July 1, 2013 - December 31, 2013**

Emission Reporting Requirements

A109 Facility: Reporting Schedules

- A. A Semi-Annual Report of monitoring activities is due within 45 days following the end of every 6-month reporting period. The six month reporting periods start on January 1st and July 1st of each year.

- B. A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

A700 Beryllium Activities

A702 Emission Limits - Beryllium Activities

Source	Beryllium Particulate Matter	Aluminum Particulate Matter
Sigma Facility TA-3-66	10 gm ³ /24 hr	N/A
Beryllium Technology Facility TA-3-141	0.35 gm/24 hr 3.5 gm/yr	N/A
Target Fabrication Facility TA-35-213	1.8 x 10 ⁻⁰⁴ gm/hr 0.46 gm/yr	N/A
Plutonium Facility TA-55 PF-4 Machining Operation	0.12 gm/24 hr 2.99 gm/yr	0.12 gm/24 hr 2.99 gm/y
Plutonium Facility TA-55 PF-4 Foundry Operation	3.49 x 10 ⁻⁰³ gm/24 hr 8.73 x 10 ⁻⁰⁴ gm/yr	3.49 x 10 ⁻⁰³ gm/24 hr 8.73 x 10 ⁻⁰⁴ gm/y

Reporting Requirement

A707 D The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes

Date report submitted:

Tracking Number:

No

Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A800 External Combustion

A802 Emission Limits - External Combustion

Unit No.	NO _x tpy		CO tpy		VOC tpy		SO ₂ tpy		TSP tpy		PM ₁₀ tpy		PM _{2.5} tpy	
Combined annual emissions for all units listed in Table 800 A ²														
	80.0		80.0		50.0		50.0		50.0		50.0		50.0	
Unit No.	NO _x pph	NO _x tpy	CO pph	CO tpy	VOC pph	VOC tpy	SO ₂ pph	SO ₂ tpy	TSP pph	TSP tpy	PM ₁₀ pph	PM ₁₀ tpy	PM _{2.5} pph	PM _{2.5} tpy
CMRR-BHW-1 (GAS)	0.7	2.9	1.1	4.8	-- ²	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4
CMRR-BHW-1 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2	
CMRR-BHW-2 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4
CMRR-BHW-2 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2	
CMRR-BHW-3 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4
CMRR-BHW-3 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2	
CMRR-BHW-4 (GAS)	0.7	2.9	1.1	4.8	--	--	0.1	0.3	0.1	0.4	0.1	0.4	0.1	0.4
CMRR-BHW-4 (OIL)	1.6		0.5		--	--	5.8		0.3		0.2		0.2	
All boilers - Oil ¹	N/A	2.9	N/A	0.9	--	--	N/A	10.4	N/A	0.5	N/A	0.3	N/A	0.3
Combined Total		14.5		20.1				11.6		2.1		1.9		1.9

Reporting Requirement

A807 B The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes

Date report submitted:

Tracking Number:

No

Provide comments and identify any supporting documentation as an attachment.

Comments: Continued on the next page

A800 External Combustion - continued

CMRR-BHW-4 (Gas)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.000	0.000	0.000	2.9
SO ₂	0.000	0.000	0.000	0.3
TSP	0.000	0.000	0.000	0.4
PM-10	0.000	0.000	0.000	0.4
PM-2.5	0.000	0.000	0.000	0.4
CO	0.000	0.000	0.000	4.8
VOCs	0.000	0.000	0.000	No Source Limit
HAPs	0.000	0.000	0.000	No Source Limit

Note: The CMRR-BHW-4 boiler has not been installed.

CMRR Boilers Totals (Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.002	0.000	0.002	2.9
SO ₂	0.001	0.000	0.001	10.4
TSP	0.000	0.000	0.000	0.5
PM-10	0.000	0.000	0.000	0.3
PM-2.5	0.000	0.000	0.000	0.3
CO	0.001	0.000	0.001	0.9
VOCs	0.001	0.000	0.001	No Source Limit
HAPs	0.000	0.000	0.000	No Source Limit

Note: The CMRR boilers operated on fuel oil for a total of 14 hours during the first 6 months of 2013 and did not operate on fuel oil during the second 6 months of 2013.

CMRR Boilers Totals (Gas and Oil)	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A802 B) (tons per year)
NOx	0.039	0.027	0.066	14.5
SO ₂	0.002	0.001	0.003	11.6
TSP	0.006	0.004	0.010	2.1
PM-10	0.006	0.004	0.010	1.9
PM-2.5	0.006	0.004	0.010	1.9
CO	0.048	0.034	0.082	20.1
VOCs	0.033	0.023	0.056	No Source Limit
HAPs	0.002	0.002	0.004	No Source Limit

A1000 Degreasers

A1002 Emission Limits - Degreasers

Unit No.	VOC/HAPs tpy
TA-55-DG-1	

The VOC emissions from this source category are included in the facility-wide allowable emissions limit established in Table 106.B: 200 tpy VOC, 8.0 tpy per individual HAP, and 24.0 tpy of combined total HAPs. Any VHAPs that are also defined as a VOC shall be included in the VOC total.

Reporting Requirement

A1007 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO2, VOC, TSP, PM10, and PM2.5 shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Degreaser TA-55-DG-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1002 A) (tons per year)
VOCs	0.002	0.006	0.008	Source limits refer to facility-wide limits.
HAPs	0.002	0.006	0.008	

A1100 Internal Combustion- continued

Generator TA-33-G-3	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.000	0.012	0.012	0.21
SO ₂	0.000	0.001	0.001	Not Required
TSP	0.000	0.001	0.001	Not Required
PM ₁₀	0.000	0.001	0.001	Not Required
CO	0.000	0.002	0.002	0.1
VOC	0.000	0.001	0.001	Not Required
HAPs	0.00E+00	3.72E-06	3.72E-06	No Source Limit

Note: The TA-33-G-3 generator did not operate during the first 6 months of 2013.

Generator TA-33-G-4	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1102 A) (tons per year)
NOx	0.052	0.000	0.052	2.33
SO ₂	0.004	0.000	0.004	0.16
TSP	0.004	0.000	0.004	Not Required
PM ₁₀	0.004	0.000	0.004	Not Required
CO	0.011	0.000	0.011	1.4
VOC	0.004	0.000	0.004	0.2
HAPs	1.67E-05	0.00E+00	1.75E-05	No Source Limit

Note: The TA-33-G-4 generator only operated for 0.2 hours during the second six months of 2013.

Stationary Standby Generators	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	1.47	1.24	2.71	No Source Specific Emission Limits for Standby Generators
SO ₂	0.07	0.06	0.12	
TSP	0.08	0.07	0.14	
PM ₁₀	0.08	0.07	0.14	
CO	0.33	0.28	0.61	
VOC	0.08	0.07	0.14	
HAPs	0.001	0.000	0.001	

Note: Standby Generators are insignificant sources.

Generator CMRR-GEN-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits
NOx	0.238	0.334	0.572	No Source Specific Emission Limits for the CMRR Generators
SO ₂	0.004	0.006	0.010	
TSP	0.007	0.010	0.017	
PM ₁₀	0.007	0.010	0.017	
CO	0.052	0.073	0.125	
VOC	0.007	0.010	0.017	
HAPs	4.32E-05	6.07E-05	1.04E-04	

Continued on the next page.

A1200 Data Disintegrator

A1202 Emission Limits - Data Disintegrator

Unit No.	TSP pph	TSP tpy	PM10 pph	PM10 tpy
TA-52-11	2.3	9.9	2.3	9.9

Reporting Requirement

A1207 A The permittee shall submit reports described in Section A109 and in accordance with B110.

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NOx, CO, SO2, VOC, TSP, PM10, and PM2.5 shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: Tracking Number:

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Data Disintegrator TA-52-11	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limits (Condition A1202 A) (tons per year)
TSP	0.03	0.04	0.07	9.9
PM10	0.03	0.04	0.07	9.9

A1300 TA-3 Power Plant**Comments:**

Combustion Turbine TA-3-22 CT-1	January - June Emissions (tons)	July - December Emissions (tons)	Annual Emissions (tons)	Permit Limit (Condition A1302 A) (tons per year)
NOx	0.93	1.47	2.40	59.4
SOx	0.06	0.10	0.16	4.2
TSP	0.12	0.20	0.32	4.8
PM₁₀	0.12	0.20	0.32	4.8
PM_{2.5}	0.12	0.20	0.32	4.8
CO	0.19	0.31	0.50	72.3
VOC	0.04	0.06	0.10	1.5
HAPs	0.03	0.04	0.07	No Source Limit

A102 Facility Wide Emission Limits

Table 102.A: Total Potential Criteria Pollutant Emissions from Entire Facility

Pollutant	Emissions (tons per year)
Nitrogen Oxides (NO _x)	245.0
Carbon Monoxide (CO)	225.0
Volatile Organic Compounds (VOC)	200.0
Sulfur Dioxide (SO ₂)	150.0
Total Particulate Matter (TSP)	120.0
Particulate Matter less than 10 microns (PM ₁₀)	120.0
Particulate Matter less than 2.5 microns (PM _{2.5})	120.0

Table 102.B: Total Potential HAPs that exceed 1.0 tons per year

Pollutant	Emissions (tons per year)
Individual HAP	8.0
Total HAPs	24.0

Reporting Requirement

A109 B A Semi-Annual Report of actual emissions from all permitted sources unless otherwise specified in this permit is due within 90 days following the end of every 6-month reporting period as defined at Condition A109.A. Emission estimates of criteria pollutants NO_x, CO, SO₂, VOC, TSP, PM₁₀, and PM_{2.5} shall not include fugitive emissions. Emission estimates of HAPs shall include fugitive emissions. Emission estimates shall not include Insignificant or Trivial Activities, except that facility-wide emissions from all natural gas combustion sources shall be estimated. The reports shall include a comparison of actual emissions that occurred during the reporting period with the facility-wide allowable emission limits at Table 106.B.

Has this reporting requirement been met during this reporting period with a separate reporting submittal? Answer Yes or No below.

Yes Date report submitted: _____ Tracking Number: _____

No Provide comments and identify any supporting documentation as an attachment.

Comments:

Pollutant	January - June Emissions (tons)	July - December Emissions (tons)	2013 Annual Emissions (tons)	Facility Wide Permit Limits (Condition A102) (tons per year)
Nitrogen Oxides	24.3	19.9	44.2	245
Carbon Monoxide	17.2	13.2	30.4	225
Volatile Organic Carbons	6.9	5.6	12.5	200
Sulfur Dioxide	0.3	0.4	0.7	150
Total Particulate Matter	2.3	1.9	4.2	120
Particulate Matter less than 10 microns	2.3	1.9	4.2	120
Particulate Matter less than 2.5 microns	1.0	0.9	2.0	120
Hazardous Air Pollutants	2.3	2.1	4.4	24